



**SEWER AUTHORITY MID-COASTSIDE
Board of Directors Meeting Agenda**

Regular Board Meeting 7:00 PM, Monday, August 23, 2021

SAM Administration Building, 1000 N. Cabrillo Highway, Half Moon Bay, CA 94019

Directors will attend the meeting through teleconferencing pursuant to and as permitted by Executive Order N-29-20, as extended to September 30, 2021 per Governor issued Executive Order N-08-21. Consistent with Executive Order N-29-20, Executive Order N-08-21, and the guidance issued by the San Mateo County Health Officer, members of the public may observe and participate in the open session portions of the meeting electronically by using the following link:

Join Zoom Meeting

<https://us02web.zoom.us/j/86500205603?pwd=bkVxbE11aFE3R3NWMm0wQzh1S1hwUT09>

Meeting ID: 865 0020 5603

Passcode: 609683

One tap mobile

+16699006833,,86500205603#,,,,*609683# US (San Jose)

Dial by your location

+1 669 900 6833 US (San Jose)

Meeting ID: 865 0020 5603

Passcode: 609683

Find your local number: <https://us02web.zoom.us/j/86500205603?pwd=bkVxbE11aFE3R3NWMm0wQzh1S1hwUT09>

If you have a disability and require special assistance related to participating in this teleconference meeting, please contact the Authority at least two working days in advance of the meeting at (650) 726-0124 or via email at kishen@samcleanswater.org.

1. CALL TO ORDER

A. Roll Call:

Chair:	Barbara Dye (GCSD)
Vice-Chair:	Deborah Ruddock (HMB)
Secretary/Treasurer:	Kathryn Slater-Carter (MWSD)
Director:	Dr. Deborah Penrose (HMB)
Director:	Ric Lohman (MWSD)
Director:	Matthew Clark (GCSD)

B. July Employee Anniversaries

1. Susan Turbay , Administrative Assistant 14 years
2. Keith Harvey, Operator I - 7 years

2. PUBLIC COMMENT / ORAL COMMUNICATION

Members of the public are welcome to submit comments via e-mail by sending them to kishen@samcleanswater.org. All comments so submitted prior to 7 pm on August 23, 2021 will be read out loud during the discussion of the respective item(s) identified in the e-mail; comments without such identification shall be read during this Item. Members of the public may also provide comments telephonically or electronically on individual items following recognition by the Board Chair presiding over the meeting.

3. CONSENT AGENDA (*Consent items are considered routine and will be approved/ adopted by a single motion and vote unless a request for removal for discussion or explanation is received from the public or Board.*)

- A. Approve Minutes of August 9, 2021 Regular Board Meeting (**Attachment**)
- B. Approve Disbursements for August 23, 2021 (**Attachment**)
- C. Monthly Revenue and Expense Report for Period Ending July 31, 2021 (**Attachment**)

4. REGULAR BUSINESS (*The Board will discuss, seek public input, and possibly take action on the following items*)

A. Status Update on Recent Process Upset at the Wastewater Treatment Plant and Actions Taken by SAM to Address and Prevent Future Upsets (Informational)

(**Attachment**)

B. Authorize General Manager to issue a Purchase Order to Environmental Dynamics International for the design, supply and installation of diffusers to Aeration Basin 4

(**Attachment**)

5. GENERAL MANAGER'S REPORT

- A. Monthly Manager's Report - July 2021 (**Attachment**)

6. ATTORNEY'S REPORT

7. DIRECTORS' REPORT

8. TOPICS FOR FUTURE BOARD CONSIDERATION (**Attachment**)

9. CONVENE IN CLOSED SESSION (*Items discussed in Closed Session comply with the Ralph M. Brown Act.*)

- A. CONFERENCE WITH LEGAL COUNSEL- EXISTING LITIGATION

Pursuant to Government Code Paragraph (2) of Subdivision (d) of Section 54956.9 (FEHA Claim 202008-10882405 filed by Beverli Marshall)

B. CONFERENCE WITH LEGAL COUNSEL – EXISTING LITIGATION

Pursuant to Government Code Paragraph (1) of Subdivision (d) of Section 54956.9: (Half Moon Bay v. Granada CSD, Montara WSD & Sewer Authority Mid-Coastside)

C. CONFERENCE WITH LEGAL COUNSEL –SIGNIFICANT RISK OF LITIGATION (1 CASE) Pursuant to Government Code Section 54956.9 (d) (2)

D. CONFERENCE WITH LABOR NEGOTIATORS (§ 54957.6)

Agency designated representatives: Kishen Prathivadi, General Manager; Jeremy Jungreis, General Counsel; Christopher Boucher, Labor & Employment Counsel
Employee organizations: IUOE, Local 39 and Unrepresented Employees

10. CONVENE IN OPEN SESSION (*Report Out on Closed Session Items*)

11. ADJOURNMENT

- Upcoming Regular Board Meetings: September 13, 2021 and September 27, 2021

The meeting will end by 9:00 p.m. unless extended by Board vote.

INFORMATION FOR THE PUBLIC

This agenda contains a brief description of each item to be considered. Those wishing to address the Board on any matter not listed on the Agenda, but within the jurisdiction of the Board, may do so during the Public Comment section of the Agenda and will have a maximum of three minutes to discuss their item. The Board Chair will call forward those wishing to speak on a matter listed on the Agenda at the appropriate time.

Any writing that is a public record and relates to an agenda item for an open session of a regular meeting that is distributed to the Board less than 72 hours prior to the meeting, is available for public inspection, during normal business hours, at the Authority's office.

Board meetings are accessible to people with disabilities. Upon request, the Authority will make this agenda available in appropriate alternative formats to persons with a disability. In compliance with the Americans with Disabilities Act, the Authority will provide special assistance for participation in this meeting. Please submit requests for a disability-related modification or an accommodation in order to participate in the public meeting at least two working days in advance of the meeting by contacting the Authority at (650) 726-0124.



SEWER AUTHORITY MID-COASTSIDE

Staff Report

TO: Honorable Board of Directors
FROM: Kishen Prathivadi, General Manager
BY: Suzie Turbay, Administrative Assistant
SUBJECT: **Approve Minutes of August 9, 2021 Regular Board Meeting**

Executive Summary

The purpose of this report is for the Board of Directors to review the minutes for August 9, 2021 Regular Board Meeting.

Fiscal Impact

There is no fiscal impact from this report.

Strategic Plan Compliance

The recommendation complies with the SAM Strategic Plan Goal 4: *“A well-organized, motivated, and well-trained staff with an effective Board of Directors are the most important keys to success for SAM.”*

Background and Discussion/Report

Attached are the minutes August 9, 2021 Regular Board Meeting for review and approval.

Staff Recommendation

Staff recommends that the Board of Directors approve the minutes for the referenced Board meetings as presented.

Supporting Documents

Attachment A: Minutes August 9, 2021 Regular Board Meeting

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

MINUTES
SAM BOARD OF DIRECTORS MEETING
August 9, 2021

1. CALL TO ORDER

Chair Dye called the meeting to order at 7:07 p.m. from her residence in El Granada, CA. Directors attended the meeting through teleconferencing pursuant to and as permitted by Executive Order N-29-20. Consistent with Executive Order N-29-20, the San Mateo County Health Officer Shelter-In-Place order issued on March 16, 2020, members of the public were able to observe the open session portions of the meeting electronically by using the link that was provided on the agenda for the August 9, 2021 meeting.

A. Roll Call

Directors Penrose, Lohman, Clark, Ruddock, Slater-Carter, and Dye were present. Also present via teleconferencing were General Manager Kishen Prathivadi, Finance Officer George Evans, Supervisor of Treatment/Field Operations Tim Costello, General Counsel Jeremy Jungreis.

2. PUBLIC COMMENT/ORAL COMMUNICATION

Director Slater-Carter discussed Senate Bill 9 - Housing Development, and Senate Bill 10 - Planning and Zoning, Housing Development. A discussion ensued. Following discussion, Director Slater-Carter requested the topic of the two Senate Bills as an agenda item for the next Board meeting. General Manager Prathivadi informed the Board of two written public comments that he received. General Manager Prathivadi first read the comments from Dan Littlefield, owner of the Hop Dogma Brewing Company in Princeton Harbor. General Manager Prathivadi also informed the Board that Craig Carroll, CEO of the Half Moon Bay Brewing Company submitted documents with confidential content that will be read and discussed in closed session. After the Closed session discussion, General Counsel Jungreis requested the document from Craig Carroll also be posted on the SAM Website.

A copy of Dan Littlefield's E-Mail can be found on the SAM website at www.samcleanswater.org.

A copy of Craig Carroll's E-Mail can be found on the SAM Website at www.samcleanswater.org

3. CONSENT AGENDA *(single motion and vote approving all items)*

(Consent items are considered routine and will be approved or adopted by one vote unless a request for removal for discussion or explanation is received from the public or Board)

- A. Approve Minutes of July 26, 2021 Regular Board Meeting
- B. Approve Disbursements for August 9, 2021

Director Penrose moved, and Director Clark seconded the motion to approve the consent agenda items as presented.

Penrose/Clark/Roll Call Vote: Penrose Aye/Lohman Aye/Clark Aye/Ruddock Aye/Slater-Carter Aye/Dye Aye/8 Ayes/0 Noes. The motion passed.

4. REGULAR BUSINESS

- A. Review and Receive the Financial Report for Q3 Fiscal Year 20-21 (Budget vs Actual)

General Manager Prathivadi reviewed the staff report and Peter Medina of Maze and Associates presented the Board with a Quarterly Budget Review for Fiscal Year 20/21. He discussed the purpose, revenue and expense summary for all funds, the general fund: revenue summary, general fund analysis: admin expenses, general fund: admin and infrastructures expenses, collection fund: expenses summary, and collections fund analysis: expenses. A discussion ensued. Following discussion and a question and answer period, Director Penrose moved, and Director Slater-Carter seconded the motion to review and receive the Financial Report for Q3 Fiscal Year 20/21.

Penrose/Slater-Carter/Roll Call Vote: Penrose Aye/Lohman Aye/Clark Aye/Ruddock Aye/Slater-Carter Aye/Dye Aye/8 Ayes/0 Noes. The motion passed.

A copy of the Maze and Associates PowerPoint presentation can be found on the SAM website at www.samcleanswater.org.

5. GENERAL MANAGERS REPORT - NONE

6. ATTORNEY'S REPORT - NONE

7. DIRECTOR'S REPORT

Director Slater-Carter informed the Board that she is in attendance at the California Association of Sanitation Agencies (CASA) Conference in San Diego, and she will be sending all the links and information to General Manager Prathivadi so he can distribute them to the members of the SAM Board so they can send them off to the rest of their Boards.

8. TOPICS FOR FUTURE BOARD CONSIDERATION - NONE

9. CONVENE IN CLOSED SESSION (*Items discussed in Closed Session comply with the Ralph M. Brown Act*)

- A. CONFERENCE WITH LEGAL COUNSEL — PENDING LITIGATION
Pursuant to Paragraphs (1), (2) and (4) of Subdivision (d) of Government Code Section 54956.9 (One case - Thompson vs SAM)
- B. CONFERENCE WITH LEGAL COUNSEL- EXISTING LITIGATION
Pursuant to Government Code Paragraph (2) of Subdivision (d) of Section 54956.9 (FEHA Claim 202008-10882405 filed by Beverli Marshall)
- C. CONFERENCE WITH LEGAL COUNSEL – EXISTING LITIGATION
Pursuant to Government Code Paragraph (1) of Subdivision (d) of Section 54956.9: (Half Moon Bay v. Granada CSD, Montara WSD & Sewer Authority Mid-Coastside)
- D. CONFERENCE WITH LEGAL COUNSEL – SIGNIFICANT RISK OF LITIGATION (1 CASE)
Pursuant to Government Code Section 54956.9 (d) (2)

The Board went in to Closed Session at 7:47 p.m.

10. CONVENE IN OPEN SESSION (*Report Out on Closed Session Items*)

The Board came out of Closed Session at 8:24 p.m. General Counsel Jungreis reported on closed session Item A - CONFERENCE WITH LEGAL COUNSEL — PENDING LITIGATION Pursuant to Paragraphs (1), (2) and (4) of Subdivision (d) of Government Code Section 54956.9 (One case - Thompson vs SAM). He stated the Board voted unanimously to approve a settlement with Miss Thompson for a payment to Miss Thompson at \$25,000 in exchange for release of all claims current and future against SAM.

11. ADJOURNMENT

Chair Dye adjourned the meeting at 8:24 p.m.

Respectfully Submitted,

Approved By:

Suzie Turbay, Administrative Assistant

Board Secretary



SEWER AUTHORITY MID-COASTSIDE

Staff Report

TO: Honorable Board of Directors
FROM: Kishen Prathivadi, General Manager
BY: George Evans, Finance Officer
SUBJECT: **Approve Disbursements for August 23, 2021**

Executive Summary

The purpose of this report is for the Board of Directors to review and approve the disbursements for the referenced period.

Fiscal Impact

Expenditures are paid per the adopted General and Contract Collection Services Budgets for FY2120/22. The total expenditure amount for August 23, 2021 is \$289,698.16.

Strategic Plan Compliance

The recommendation complies with the SAM Strategic Plan Goal 3 *“Consider long-term costs, and ensure that finances are stable and understandable by the board, member agencies, and the public.”*

Background and Discussion/Report

Attached please find the A/P check register for the period of August 10, 2021 through August 23, 2021 (\$235,001.75) as well as the payroll check register for the pay period ending August 6, 2021 (\$54,696.41).

Staff Recommendation

Staff recommends that the Board approve the disbursements for the period of August 10, 2021 through August 23, 2021, and the payroll check register for the pay period ending August 6, 2021 as presented.

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

8

Supporting Documents

- Attachment A: AP Check Register for August 23, 2021
- Attachment B: Payroll Check Register for PPE August 6, 2021
- Attachment C: Visa Statement Summary for July 30, 2021

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	



Payment Dates 8/10/2021 - 8/23/2021

Payment Number	Payment Date	Vendor Name	Payable Date	Description (Item)	Amount
Vendor: 0006 - A-1 Septic Tank Service, Inc.					
104942	08/23/2021	A-1 Septic Tank Service, Inc.	07/17/2021	RAS Hauling - SVCW to Plant	1,500.00
104942	08/23/2021	A-1 Septic Tank Service, Inc.	07/18/2021	RAS Hauling - SVCW to Plant	1,875.00
104942	08/23/2021	A-1 Septic Tank Service, Inc.	07/19/2021	RAS Hauling - SVCW to Plant	1,875.00
104942	08/23/2021	A-1 Septic Tank Service, Inc.	07/20/2021	RAS Hauling - SVCW to Plant	2,250.00
104942	08/23/2021	A-1 Septic Tank Service, Inc.	07/21/2021	RAS Hauling - SVCW to Plant	1,875.00
Vendor 0006 - A-1 Septic Tank Service, Inc. Total:					9,375.00
Vendor: 0028 - Alpha Analytical Laboratories, Inc					
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/03/2021	BAL BOD Tests/Handling & Disp...	305.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/04/2021	BAL BOD Tests/Handling & Disp...	245.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/04/2021	BAL BOD Tests/Handling & Disp...	298.75
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/04/2021	BAL BOD Tests/Handling & Disp...	510.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/04/2021	BAL BOD Tests/Handling & Disp...	310.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/05/2021	BAL BOD Tests/Handling & Disp...	321.25
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/05/2021	BAL BOD Tests/Handling & Disp...	245.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/05/2021	BAL BOD Tests/Handling & Disp...	245.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/05/2021	BAL BOD Tests/Handling & Disp...	321.25
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/06/2021	BAL BOD Tests/Handling & Disp...	245.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/09/2021	BAL BOD Tests/Handling & Disp...	310.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/10/2021	BAL BOD Tests/Handling & Disp...	305.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/10/2021	BAL BOD Tests/Handling & Disp...	245.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/10/2021	BAL BOD Tests/Handling & Disp...	245.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/11/2021	BAL BOD Tests/Handling & Disp...	1,511.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/12/2021	BAL BOD Tests/Handling & Disp...	298.75
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/13/2021	BAL BOD Tests/Handling & Disp...	245.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/13/2021	BAL BOD Tests/Handling & Disp...	381.25
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/13/2021	BAL BOD Tests/Handling & Disp...	245.00
104943	08/23/2021	Alpha Analytical Laboratories, I...	08/16/2021	BAL BOD Tests/Handling & Disp...	445.00
Vendor 0028 - Alpha Analytical Laboratories, Inc Total:					7,277.25
Vendor: 0045 - APGN Inc.					
104945	08/23/2021	APGN Inc.	08/13/2021	High Speed Turbo Blowers: 202...	4,020.28
Vendor 0045 - APGN Inc. Total:					4,020.28
Vendor: 0055 - AT&T					
104938	08/10/2021	AT&T	07/31/2021	July Service 960 757-1068 555 0	1,803.92
Vendor 0055 - AT&T Total:					1,803.92
Vendor: 0096 - Brown and Caldwell					
104946	08/23/2021	Brown and Caldwell	08/12/2021	WWTP Capacity & Treatment P...	54,781.26
Vendor 0096 - Brown and Caldwell Total:					54,781.26
Vendor: 0107 - Calcon Systems, Inc.					
104947	08/23/2021	Calcon Systems, Inc.	07/30/2021	After Hours WAS Flowmeter Re...	2,330.00
104947	08/23/2021	Calcon Systems, Inc.	07/30/2021	July SCADA Service Calls: Plant	1,201.66
104947	08/23/2021	Calcon Systems, Inc.	07/30/2021	Secondary Clarifier Motor Start...	2,750.00
104947	08/23/2021	Calcon Systems, Inc.	07/30/2021	Main Plant Service Calls: July 12...	11,025.04
104947	08/23/2021	Calcon Systems, Inc.	07/30/2021	Level Transducer - Bell Moon LS...	950.00
Vendor 0107 - Calcon Systems, Inc. Total:					18,256.70
Vendor: 0134 - Cintas Corporation #464					
104950	08/23/2021	Cintas Corporation #464	08/09/2021	Uniforms	390.52
104950	08/23/2021	Cintas Corporation #464	08/09/2021	Uniforms	25.95
104950	08/23/2021	Cintas Corporation #464	08/09/2021	Uniforms	21.37
104950	08/23/2021	Cintas Corporation #464	08/09/2021	Uniforms	29.00
104950	08/23/2021	Cintas Corporation #464	08/16/2021	Uniforms	357.24
104950	08/23/2021	Cintas Corporation #464	08/16/2021	Uniforms	25.95

Check Register

Payment Dates: 8/10/2021 - 8/23/2021

Payment Number	Payment Date	Vendor Name	Payable Date	Description (Item)	Amount
104950	08/23/2021	Cintas Corporation #464	08/16/2021	Uniforms	21.37
104950	08/23/2021	Cintas Corporation #464	08/16/2021	Uniforms	29.00
Vendor 0134 - Cintas Corporation #464 Total:					900.40
Vendor: 0133 - Cintas					
104949	08/23/2021	Cintas	08/06/2021	Electrostatic Spray Admin Areas	776.60
Vendor 0133 - Cintas Total:					776.60
Vendor: 0136 - Cintas					
104948	08/23/2021	Cintas	08/05/2021	Maintain Safety Supplies Cabine...	66.61
Vendor 0136 - Cintas Total:					66.61
Vendor: 0163 - Cropper Accountancy					
104952	08/23/2021	Cropper Accountancy	07/30/2021	FY 2020/2021 Audit Billing: 1st ...	2,500.00
Vendor 0163 - Cropper Accountancy Total:					2,500.00
Vendor: 0172 - CWEA-SCVS					
104953	08/23/2021	CWEA-SCVS	08/03/2021	Association Membership - Keith...	192.00
Vendor 0172 - CWEA-SCVS Total:					192.00
Vendor: 0229 - Environmental Business Specialists, LLC					
104954	08/23/2021	Environmental Business Speciali...	07/22/2021	EBS BioStar GT - Testing/Analysi...	5,486.05
104954	08/23/2021	Environmental Business Speciali...	07/27/2021	EBS BioStar GT - Testing/Analysi...	5,183.73
104954	08/23/2021	Environmental Business Speciali...	07/27/2021	EBS BioStar GT - Testing/Analysi...	13,449.72
104954	08/23/2021	Environmental Business Speciali...	07/31/2021	EBS BioStar GT - Testing/Analysi...	430.00
Vendor 0229 - Environmental Business Specialists, LLC Total:					24,549.50
Vendor: 0225 - Environmental.com					
104955	08/23/2021	Environmental.com	07/31/2021	2021-0# Install Autosampler/S...	8,500.00
Vendor 0225 - Environmental.com Total:					8,500.00
Vendor: 0235 - Fisher Scientific					
104956	08/23/2021	Fisher Scientific	07/27/2021	Sample Fridge Thermometer: L...	58.32
Vendor 0235 - Fisher Scientific Total:					58.32
Vendor: 0289 - Hassett Hardware					
104957	08/23/2021	Hassett Hardware	08/04/2021	Fasteners: Plant	1.86
104957	08/23/2021	Hassett Hardware	08/09/2021	Pruning Sheers/VP Fuel	59.04
104957	08/23/2021	Hassett Hardware	08/10/2021	Piping Fittings: Plant	63.51
Vendor 0289 - Hassett Hardware Total:					124.41
Vendor: 0274 - Hills Brothers Chemical Co.					
104958	08/23/2021	Hills Brothers Chemical Co.	08/12/2021	Ferric Chloride 42BE: Plant	5,189.84
Vendor 0274 - Hills Brothers Chemical Co. Total:					5,189.84
Vendor: 0295 - Hue & Cry Security Systems, Inc					
104959	08/23/2021	Hue & Cry Security Systems, Inc	08/15/2021	2021 September Environmental...	178.60
Vendor 0295 - Hue & Cry Security Systems, Inc Total:					178.60
Vendor: 0299 - ICMA Retirement					
104936	08/13/2021	ICMA Retirement	08/13/2021	ICMA 457 Deferred Comp	385.00
Vendor 0299 - ICMA Retirement Total:					385.00
Vendor: 0307 - IndustryUptime, Inc					
104960	08/23/2021	IndustryUptime, Inc	08/10/2021	Various Equipment Oils/Lubrica...	1,386.13
Vendor 0307 - IndustryUptime, Inc Total:					1,386.13
Vendor: 0756 - KBA Docusys, Inc.					
104939	08/10/2021	KBA Docusys, Inc.	08/09/2021	Copier Lease Usage/Supplies	164.95
Vendor 0756 - KBA Docusys, Inc. Total:					164.95
Vendor: 0354 - Kemira Water Solutions, Inc.					
104961	08/23/2021	Kemira Water Solutions, Inc.	07/30/2021	Aluminum Chloride: Plant	5,169.84
Vendor 0354 - Kemira Water Solutions, Inc. Total:					5,169.84
Vendor: 0367 - Krystal Kleen					
104962	08/23/2021	Krystal Kleen	07/31/2021	June/July Janitorial Services: A...	1,800.00
104962	08/23/2021	Krystal Kleen	07/31/2021	June/July Janitorial Services: Pl...	500.00
Vendor 0367 - Krystal Kleen Total:					2,300.00

Check Register

Payment Dates: 8/10/2021 - 8/23/2021

Payment Number	Payment Date	Vendor Name	Payable Date	Description (Item)	Amount
Vendor: 0387 - Maze & Associates					
104963	08/23/2021	Maze & Associates	07/31/2021	Accounting Services	5,500.00
104963	08/23/2021	Maze & Associates	07/31/2021	Additional Scope: FY2020-21 Ye...	5,695.00
104963	08/23/2021	Maze & Associates	07/31/2021	Additional Scope: CAFR Convers...	2,430.00
104963	08/23/2021	Maze & Associates	07/31/2021	Additional Scope: General Cons...	565.00
104963	08/23/2021	Maze & Associates	07/31/2021	Additional Scope: FY2020-21 Q...	515.00
Vendor 0387 - Maze & Associates Total:					14,705.00
Vendor: 0121 - Michelle Dragony					
104951	08/23/2021	Michelle Dragony	07/31/2021	Monthly Promotion - July Posts	1,500.00
Vendor 0121 - Michelle Dragony Total:					1,500.00
Vendor: 0419 - National Stewardship Action Council					
104964	08/23/2021	National Stewardship Action Co...	08/04/2021	FY2021-2022 NSAC Donation	2,000.00
Vendor 0419 - National Stewardship Action Council Total:					2,000.00
Vendor: 0450 - Operating Engineers Local 39					
104937	08/13/2021	Operating Engineers Local 39	08/13/2021	Union Dues	1,247.61
104937	08/13/2021	Operating Engineers Local 39	08/13/2021	Per Capita	198.25
Vendor 0450 - Operating Engineers Local 39 Total:					1,445.86
Vendor: 0466 - Pacific Material Handling Solutions					
104965	08/23/2021	Pacific Material Handling Soluti...	03/31/2021	Routine Service: Fork Lift	359.97
Vendor 0466 - Pacific Material Handling Solutions Total:					359.97
Vendor: 0468 - Pacifica Community Television					
104966	08/23/2021	Pacifica Community Television	07/31/2021	Video Recording Sessions 06/14...	600.00
Vendor 0468 - Pacifica Community Television Total:					600.00
Vendor: 0482 - PG&E					
104940	08/10/2021	PG&E	07/31/2021	Electric & Gas Usage for July	30,749.88
Vendor 0482 - PG&E Total:					30,749.88
Vendor: 0487 - Polydyne, Inc.					
104967	08/23/2021	Polydyne, Inc.	08/05/2021	Clarifloc WE-2115	3,043.91
Vendor 0487 - Polydyne, Inc. Total:					3,043.91
Vendor: 0490 - Precision IT Consulting					
104968	08/23/2021	Precision IT Consulting	07/30/2021	Setup New Ops Computer	369.82
104968	08/23/2021	Precision IT Consulting	08/01/2021	Monthly 360 Bronze Coverage: ...	3,062.34
Vendor 0490 - Precision IT Consulting Total:					3,432.16
Vendor: 0525 - Republic Services of San Mateo County					
104969	08/23/2021	Republic Services of San Mateo ...	07/31/2021	July Disposal & Hauling Fees	5,071.01
Vendor 0525 - Republic Services of San Mateo County Total:					5,071.01
Vendor: 0580 - Shape Products					
104970	08/23/2021	Shape Products	08/04/2021	Lab Chemicals: Acetate Buffer	294.87
104970	08/23/2021	Shape Products	08/04/2021	Lab Chemicals: Potassium Iodate	379.31
Vendor 0580 - Shape Products Total:					674.18
Vendor: 0604 - Staples Business Credit					
104971	08/23/2021	Staples Business Credit	08/02/2021	Office & Lunchroom Supplies	173.11
104971	08/23/2021	Staples Business Credit	08/02/2021	Office & Lunchroom Supplies	403.91
104971	08/23/2021	Staples Business Credit	08/02/2021	9V Batteries	16.55
104971	08/23/2021	Staples Business Credit	08/02/2021	9V Batteries	38.63
104971	08/23/2021	Staples Business Credit	08/02/2021	Office & Lunchroom Supplies	4.50
104971	08/23/2021	Staples Business Credit	08/02/2021	Office & Lunchroom Supplies	10.49
Vendor 0604 - Staples Business Credit Total:					647.19
Vendor: 0643 - The UPS Store					
104972	08/23/2021	The UPS Store	08/12/2021	Overnight Service: Documents	28.03
Vendor 0643 - The UPS Store Total:					28.03
Vendor: 0646 - Thomas & Associates					
104973	08/23/2021	Thomas & Associates	07/30/2021	Gorman Rupp Pumps: Plant	4,322.92
Vendor 0646 - Thomas & Associates Total:					4,322.92
Vendor: 0663 - Umpqua Bank					
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	104.21

Check Register

Payment Dates: 8/10/2021 - 8/23/2021

Payment Number	Payment Date	Vendor Name	Payable Date	Description (Item)	Amount
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	595.00
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	29.73
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	1,302.07
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	69.37
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	42.75
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	904.54
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	210.00
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	1,381.06
104941	08/10/2021	Umpqua Bank	07/30/2021	Visa Statement	40.50
Vendor 0663 - Umpqua Bank Total:					4,679.23
Vendor: 0664 - USA North 811					
104974	08/23/2021	USA North 811	08/02/2021	CA State Fee for Regulatory Cos...	277.85
104974	08/23/2021	USA North 811	08/02/2021	CA State Fee for Regulatory Cos...	601.70
Vendor 0664 - USA North 811 Total:					879.55
Vendor: 0687 - Vapex Environmental Technologies, LLC					
104975	08/23/2021	Vapex Environmental Technolog..	08/09/2021	Pilot Rental: NANO Radical Odor..	12,906.25
Vendor 0687 - Vapex Environmental Technologies, LLC Total:					12,906.25
Grand Total:					235,001.75

Report Summary

Fund Summary

Fund	Payment Amount
100 - Operating Fund	233,621.26
300 - Contract Services	1,380.49
Grand Total:	235,001.75

Account Summary

Account Number	Account Name	Payment Amount
100-1010-5317	Outside Audit	2,500.00
100-1010-5322	Computer & Network Mai...	3,062.34
100-1010-5323	Software License & Maint...	104.21
100-1010-5330	Misc. Professional Services	15,305.00
100-1010-5411	Registration Fees	595.00
100-1010-5413	Postage	28.03
100-1010-5416	Advertising and Publishing	3,500.00
100-1010-5421	Telephones	1,803.92
100-1010-5511	Rental/Lease Equipment -...	164.95
100-1010-5610	Janitorial Services	2,576.60
100-1010-5816	Office Supplies	223.89
100-2021-5322	Computer & Network Mai...	369.82
100-2021-5324	Vehicle Maintenance Serv...	359.97
100-2021-5326	Equipment Maintenance	18,211.24
100-2021-5330	Misc. Professional Services	72,656.26
100-2021-5410	Professional dues and fees	601.70
100-2021-5411	Registration Fees	402.00
100-2021-5417	Uniform Services	747.76
100-2021-5432	Gas/Electricity	30,749.88
100-2021-5433	Solid Waste (Trash)	5,071.01
100-2021-5511	Rental/Lease Equipment -...	14,208.32
100-2021-5610	Janitorial Services	500.00
100-2021-5613	Security Services	178.60
100-2021-5814	Maintenance Supplies	124.41
100-2021-5816	Office Supplies	522.40
100-2021-5817	Chemicals	13,403.59
100-2021-5818	Safety Supplies	1,447.67
100-2021-5822	Fuel, Oil, Lubricant	1,469.38
100-2021-6131	Machinery and Equipment..	4,322.92
100-2022-5330	Misc. Professional Services	31,826.75
100-2022-5813	Laboratory Supplies	58.32
100-2022-5817	Chemicals	674.18
100-2024	Union Dues	1,445.86
100-2027	Deferred Comp	385.00
100-4041-6121	Machinery and Equipment..	4,020.28
300-3031-5417	Uniform Services	51.90
300-3031-5614	CS Repairs - HMB	950.00
300-3032-5417	Uniform Services	42.74
300-3032-5615	CS Repairs - GCSD	277.85
300-3033-5417	Uniform Services	58.00
Grand Total:		235,001.75

Project Account Summary

Project Account Key	Payment Amount
None	230,981.47
20TP01-6121	4,020.28
Grand Total:	235,001.75



Sewer Authority Mid-Coastside

Payroll Check Register Checks

Pay Period: 7/24/2021-8/6/2021

Packet: PYPKT00835 - PPE 2021-0806

Payroll Set: Sewer Authority Mid-Coastside - 01

Employee	Employee #	Check Type	Date	Amount	Number
Clark, Matthew	0026	Regular	08/13/2021	184.70	1702
Dye, Barbara	0031	Regular	08/13/2021	184.70	1703
Slater-Carter, Kathryn	0015	Regular	08/13/2021	277.05	1704



Sewer Authority Mid-Coastside

Payroll Check Register

Direct Deposits

Pay Period: 7/24/2021-8/6/2021

Packet: PYPKT00835 - PPE 2021-0806

Payroll Set: Sewer Authority Mid-Coastside - 01

Employee	Employee #	Date	Amount	Number
Aguilar-Ibal, Gabriel	0004	08/13/2021	3,664.47	3061
Costello, Timothy J	0001	08/13/2021	4,021.06	3062
Costello, Timothy J	0001	08/13/2021	100.00	3062
Harvey, Keith	0010	08/13/2021	2,526.16	3063
Hussein, Jr., Tazammal Aiyub	0040	08/13/2021	1,615.58	3064
Hussein, Jr., Tazammal Aiyub	0040	08/13/2021	500.00	3064
Hussein, Jr., Tazammal Aiyub	0040	08/13/2021	200.00	3064
Long, George J	0002	08/13/2021	4,619.13	3065
Mejia, Julio A	0044	08/13/2021	2,101.50	3066
Mendez, Carlos	0009	08/13/2021	2,975.30	3067
Ondish, Sonya L	0022	08/13/2021	3,232.13	3068
Partida, David	0006	08/13/2021	4,687.66	3069
Rovai, Angelo	0042	08/13/2021	2,975.63	3070
Ahumada, Jose	0039	08/13/2021	2,174.49	3071
Preciado , Felipe	0036	08/13/2021	2,774.30	3072
Young, Anthony Edward	0024	08/13/2021	2,983.28	3073
Evans, George	0025	08/13/2021	3,412.67	3074
Evans, George	0025	08/13/2021	250.00	3074
Prathivadi, Kishen	0012	08/13/2021	6,344.12	3075
Turbay, Susan	0007	08/13/2021	2,430.73	3076
Lohman , Richard	0017	08/13/2021	92.35	3077
Penrose, Deborah	0021	08/13/2021	184.70	3078
Ruddock, Deborah Rose	0018	08/13/2021	184.70	3079



Sewer Authority Mid-Coastside

Payroll Check Register

Report Summary

Pay Period: 7/24/2021-8/6/2021

Packet: PYPKT00835 - PPE 2021-0806

Payroll Set: Sewer Authority Mid-Coastside - 01

Type	Count	Amount
Regular Checks	3	646.45
Manual Checks	0	0.00
Reversals	0	0.00
Voided Checks	0	0.00
Direct Deposits	23	54,049.96
Total	26	54,696.41

Cardholder	GL Account	Details	Amount
Kishen	100-****-5816	Office/Kitchen Supplies	99.10
Kishen	100-1010-5411	CASA Registration-KSC	595.00
Kishen	100-1010-5323	Internet Services	104.21
Kishen	100-2021-5511	ORP Rental	1,302.07
Kishen	100-2021-5822	Forklift Propane	42.75
		Total Kishen:	2,143.13

Tim	100-2021-5326	Weather Station/Data Logger	904.54
Tim	100-2021-5411	CWEA Training	210.00
Tim	100-2021-5818	Safety Gloves	1,381.06
Tim	100-2021-5822	Forklift Propane	40.50
		Total Tim:	2,536.10

Statement Total:	4,679.23
-------------------------	-----------------




SEWER AUTHORITY MID-COASTSIDE

Staff Report

TO: Honorable Board of Directors
FROM: Kishen Prathivadi, General Manager
BY: George Evans, Finance Officer
SUBJECT: **Monthly Revenue and Expense Report for Period Ending July 31, 2021**

Executive Summary

The purpose of this report is for the Board of Directors to review the budget reports for the period ending June 30, 2022. The revenue for the period ending July 31, 2021 is \$0.606M which represents approximately 8.3% of the annual budget. The expense for period ending July 31, 2021 is \$0.750M which represents approximately 10.1% of the annual budget.



While expenses are currently almost \$150K over the average monthly budget, we always anticipate the first quarter expenses being higher than the average of the annual

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

expenses because of the multiple annual payments made during the first quarter such as insurance (\$76K annual vs \$6.3K monthly). Expenditures above expectations also include the ongoing direct costs of the upset (no less than \$126K in July). Removal of these two substantial factors would put us below the budgeted monthly average.

Fiscal Impact

There is no fiscal impact from this report.

Strategic Plan Compliance

The recommendation complies with the SAM Strategic Plan Goal 3: *“Consider long-term costs and ensure that finances are stable and understandable by the board, member agencies, and the public.”*

Background and Discussion/Report

Attached please find the revenue and expenditures report for the period ending July 31, 2021, which represents 8% of Fiscal Year 2021/22. After receiving constructive input from the Finance Committee, the attachments included on our monthly report have been revised for brevity and clarity, as well as the removal of duplication.

General Budget

The adopted General Budget for FY 2021/22 includes \$7.399 million in revenue, of which \$7.264 million is from member agency assessments, \$115,000 is from NDWSCP fees (Attachment B).

Cash Flow

The cash balances in the various accounts as of July 31, 2021 were:

<u>Account</u>	<u>Balance</u>
A/P Checking Account	\$678,826.34
Payroll Checking Account	\$123,404.90
Money Market	\$773.14
LAIF Statement	\$2,936,586.98
Total:	\$3,739,591.36

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

Staff Recommendation

Staff recommends that the Board accept the Revenue and Expense Report for period ending July 31, 2021.

Supporting Documents *

Attachment A: Aging Receivable Report for period ending July 31, 2021

**Note: Due to technical difficulties, the July Summarized Financial Statements and the July Summarized General Budget Report (comparison of Actual versus Budget) have not been included in this packet. We will have the technical issue resolved in time to have both these reports included in the August Revenue and Expense Report.*

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	



Account Number	Account Name	Account Status	Account Class									
0006	California State Parks	Active	NDWSCP									
Tran. Type	Number	Date	Trans. Date	Due Date	Description	Current	30-60	60-90	90-120	>120	Unapplied Credit	Account Balance
Invoice	INV00510	6/30/2021	6/30/2021	7/31/2021	June 2021 Trucked Waste	0.00	740.00	0.00	0.00	0.00		
Invoice	INV00520	7/31/2021	7/31/2021	8/31/2021	July 2021 Trucked Waste	630.00	0.00	0.00	0.00	0.00		
Account Total:						630.00	740.00	0.00	0.00	0.00	0.00	1,370.00
0040	Granada Community Services District	Active	MAA									
Tran. Type	Number	Date	Trans. Date	Due Date	Description	Current	30-60	60-90	90-120	>120	Unapplied Credit	Account Balance
Invoice	INV00035	3/1/2018	6/30/2018	3/1/2018	QB-3701	0.00	0.00	0.00	0.00	16,787.77		
Invoice	INV00036	3/1/2018	6/30/2018	3/1/2018	QB-3708	0.00	0.00	0.00	0.00	10,244.00		
Invoice	INV00230	5/1/2019	5/1/2019	5/31/2019	Collections Service May 2019	0.00	0.00	0.00	0.00	481.23		
Invoice	INV00241	6/1/2019	6/1/2019	6/30/2019	Collections Service June 2019	0.00	0.00	0.00	0.00	481.23		
Invoice	INV00518	7/31/2021	7/31/2021	8/31/2021	Pass Through Invoices July 2021	526.63	0.00	0.00	0.00	0.00		
Account Total:						526.63	0.00	0.00	0.00	27,994.23	0.00	28,520.86
0080	Montara Water & Sanitary District	Active	MAA									
Tran. Type	Number	Date	Trans. Date	Due Date	Description	Current	30-60	60-90	90-120	>120	Unapplied Credit	Account Balance
Invoice	INV00509	6/30/2021	6/30/2021	7/31/2021	Pass Through Invoices June 2021	0.00	620.94	0.00	0.00	0.00		
Invoice	INV00514	7/1/2021	7/1/2021	7/31/2021	O&M July 2021	0.00	127,717.35	0.00	0.00	0.00		
Invoice	INV00517	7/1/2021	7/1/2021	7/31/2021	Collections Service July 2021	0.00	27,664.41	0.00	0.00	0.00		
Invoice	INV00519	7/31/2021	7/31/2021	8/31/2021	Pass Through Invoices July 2021	5,451.01	0.00	0.00	0.00	0.00		
Account Total:						5,451.01	156,002.70	0.00	0.00	0.00	0.00	161,453.71
0100	Rocket Farms	Active	NDWSCP									
Tran. Type	Number	Date	Trans. Date	Due Date	Description	Current	30-60	60-90	90-120	>120	Unapplied Credit	Account Balance
Invoice	INV00521	7/31/2021	7/31/2021	8/31/2021	July 2021 AID/RORWW	227.15	0.00	0.00	0.00	0.00		
Account Total:						227.15	0.00	0.00	0.00	0.00	0.00	227.15
Total Accounts: 4			Report Total:			6,834.79	156,742.70	0.00	0.00	27,994.23	0.00	191,571.72

Invoice and Penalty Revenue Code Aging

Revenue Code - Revenue Code Description	Current	30-60	60-90	90-120	>120	
100-002 - JPA - GCSD	0.00	0.00	0.00	0.00	27,031.77	
100-101 - NDWSCP Revenue - Trucked Waste	630.00	740.00	0.00	0.00	0.00	
100-102 - NDWSCP Revenue - Rocket Farms	227.15	0.00	0.00	0.00	0.00	
100-MWSD Admin - MWSD Administration	0.00	22,153.22	0.00	0.00	0.00	
100-MWSD EC - MWSD Environmental Compliance	0.00	3,222.44	0.00	0.00	0.00	
100-MWSD INFRST - MWSD Infrastructure	0.00	43,577.13	0.00	0.00	0.00	
100-MWSD Treatment - MWSD Treatment	0.00	58,764.56	0.00	0.00	0.00	
300-002 - Collections Service - GCSD	0.00	0.00	0.00	0.00	962.46	
300-003 - Collections Service - MWSD	0.00	27,664.41	0.00	0.00	0.00	
300-022 - CCS Repairs - GCSD	526.63	0.00	0.00	0.00	0.00	
300-023 - CCS Repairs - MWSD	5,451.01	620.94	0.00	0.00	0.00	
	6,834.79	156,742.70	0.00	0.00	27,994.23	191,571.72



SEWER AUTHORITY MID-COASTSIDE

Staff Report

TO: Honorable Board of Directors

FROM: Kishen Prathivadi, General Manager

DATE: August 23, 2021

SUBJECT: **Status Update on Recent Process Upset at the Wastewater Treatment Plant and Actions Taken by SAM to Address and Prevent Future Upsets (Informational)**

Executive Summary

The purpose of this report is to give Status Update on the recent process upset at the Wastewater Treatment Plant and inform the Board of the actions taken by SAM to address and prevent future upsets.

Fiscal Impact

There is no fiscal impact.

Strategic Plan Compliance

The recommendation complies with the SAM Strategic Plan's Vision: "*Utilize state of the art technologies and management practices to advance public health and environmental protection.*" It also complies with the Strategic Plan's Goal 5: Infrastructure, Operations and Maintenance: "*The goals are no spills, safety, environmental protection, reliability, and long-term cost effectiveness.*"

Background and Discussion/Report

The Plant experienced high amounts of filamentous growth and bulking conditions causing poor settling in early June 2021. Filamentous bacteria are long strands of bacteria growing end to end, resembling strands of hair or spaghetti, which interlock with each other to form a mesh. These high levels of filamentous bacteria can physically inhibit the floc from forming larger, more dense pieces that would settle well, leaving behind a low level of solids in the clarifier overflow. SAM requested Brown and Caldwell

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

(BC) to assist in evaluating the immediate problem and to help identify mitigation measures. BC immediately sent an operations subject matter expert (SME), Mr. Lance Salerno to the site on June 9, 2021.

Field observations were made by BC and initial microscopic examination identified the predominant filament as Type 021N. This type of filament can be caused by, or proliferate with, conditions of septicity, nutrient imbalance and/or low dissolved oxygen.

BC carried out various investigations and submitted a draft technical memorandum (TM) which was presented to the Board on July 12, 2021.

Subsequently, periods of poor activated sludge performance and settleability have been observed through August 2021. There has been increased effluent TSS and BOD during June and July 2021 that has resulted in potential violations of effluent limitations. There have been 30 violations since October 2020.

Details are as follows:

Month	Violations			Total Violations
	BOD	TSS	Others	
October 2020	4	2		6
November 2020	2	2		4
December 2020	0	0		0
January 2021	1	2		2
February 2021	0	0		0
March 2021	0	0		0
April 2021		1	1	2
May 2021	0	0	0	0
June 2021	2	3	1	6
July 2021	3	5	2	10

Since October 2020 SAM has incurred unforeseen costs of \$600,000 due to the process upsets. A large part of these costs (\$320,000) is due to the additional testing done to investigate the upsets and the products which had to be used to mitigate them. Details of the costs are included here as Attachment A.

BC made a presentation to the Managers and Engineers of the Member Agencies on August 16, 2021.

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

BC suggested the following recommendations:

- Perform upgrades to provide additional basin volume to account for redundancy discrepancy. Alternative 1 (upgrading Basin 4 only) is recommended because it provides the lowest estimated cost and provides the most redundancy. The detailed final report from Brown and Caldwell is included here as Attachment C.
- Investigate the source of highly variable BOD loading entering the Plant. The peaking factor during the BOD spikes is significantly higher than typical.

The above two recommendations are in the process of being implemented.

- The upgrade to Aeration Basin 4 is being presented to the Board at this meeting.
- A Non-Domestic Wastewater Source Control Program is being reintroduced to decrease the number and quantity of pollutants entering the Authority member collection systems that have the potential to interfere and periodically overwhelm the Treatment Plant's biological processes.

BC will be making a presentation at the Board Meeting and will be available to answer any questions.

Staff Recommendation

None.

Supporting Documents

Attachment A: Gross Upset Costs starting October 2020

Attachment B: Draft Technical Memorandum from BC dated August 18, 2021

Attachment C: Technical Memorandum on Capacity Assessment and Alternatives
Evaluation dated August 10, 2021

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

Gross Upset Costs - Starting October 2020			
		Amount	Total
Extra Testing and Products:			
	1. Alpha	172,143.50	
	2. Aquafix	10,691.65	
	3. Chemtron	11,453.57	
	4. EBS	45,506.69	
	5. Environmental.com	70,900.00	
	6. Hills Brothers	5,189.84	
	7. Kemira	5,169.84	
			321,055.09
Legal			
	1. Rutan (Environmental)	5,460.00	
			5,460.00
Staff Overtime			
	1. Operations	35,422.18	
			35,422.18
Consulting			
	1. Brown & Caldwell	157,134.07	
	2. CFCS (Charles Fenton)	25,012.00	
	3. WMS (Dan)	50,000.00	
			232,146.07
Misc			
	1. A1 Septic	9,375.00	
			9,375.00
Grand Total:			603,458.34

18500 Von Karman Avenue, Suite 1100
Irvine, CA 92612
T: 714.730.7600

DRAFT Technical Memorandum

Subject: Operations Support for Recent Sludge Bulking Events
Date: August 8/18/2021
To: Kishen Prathivadi, P.E., PMP
From: Lance P. Salerno, QEP, Senior Principal O&M Consulting
Copy to: Michael Harrison, P.E., Director

Section 1: Observations

1.1 Activated Sludge Operations (5/30-8/17)

Periods of poor activated sludge performance and settleability have been observed between June and August 2021. There has been increased effluent TSS and BOD during June and July 2021 that has reportedly resulted in potential violations of effluent limitations.

A change-over from coarse bubble to fine bubble diffuser was completed in aeration basin 3 during May. Initially, there were no issues noted with performance. However, by early June, the MLSS decreased daily, settleability performance decreased and the associated SVI increased rapidly. Operational measures were taken to stabilize the plant during June, with good performance returning by the end of June. This pattern has repeated itself throughout the summer with brief periods where aeration basin sludge inventory and MLSS concentrations increase with improving settleability, followed by decreasing aeration basin sludge inventory and poor settleability.

The poor settleability, is reflected by the Sludge Volume Index (SVI), which is a daily settleability test that measures the amount of solids that settle (in grams) per unit volume (liters). A profile of MLSS and SVI are shown in Figure This pattern has repeated, three times thus far during the period examined, as highlighted by the profile of the period shown in Figure 1.





Figure 1. MLSS and SVI (May 30-August 17, 2021)

Field observations by plant staff and initial microscopic exam indicated high amounts of filamentous growth and bulking conditions causing the poor settling to the point where nearly the entire sludge blanket was dispersed throughout the 14-foot depth of clarifier. Microscopic examinations have been conducted in June, July and August, with filaments present in abundance. Please see those reports for detailed information. Some filaments are typical in activated sludge, however, over Abundance of filaments contributes to the inability to form a good settling floc and bulking conditions observed in the secondary clarifier.

A high variability in COD loading to the plant has been observed during the upset periods. For example, after settling improved and operations stabilized at the end of June 2021, there was a period of high variability in COD loading observed early in July, as shown by Figure 2. The settling deteriorated during this period and following this period of high loading with filaments increasing. COD is used by the plant as a surrogate parameter to BOD, as COD can be determined within a few days, where BOD is a five-day test. The high variability in day-to-day influent load makes dialing in an operation very difficult, but also the type of waste contributing to that additional COD contributes directly to the types of micro-organisms that will predominate. If the additional waste is associated with constituents, such as simple sugars and starches, that are very easy to metabolize those bacteria such as filaments will tend to form more readily.



A common causative factor that results in proliferation of the types of filaments observed over the past two months are two factors:

- Septicity/sulfides – typically generated in collection systems and pump stations
- Soluble readily metabolizable substrates (SRMS)- such as caused by simple starches, sugars that are easily processed by micro-organisms, and filaments in particular. SRMS is present as a portion of the Chemical Oxygen Demand (COD) or biochemical oxygen demand (BOD). If present in a high enough fraction of the BOD, it will result in favoring growth of filaments over other types of micro-organisms that don't absorb SRMS as efficiently.

While the plant chlorinates the return sludge as a typical approach to minimize filaments, several of the types of filaments observed have been resistant to chlorination (with doses of up to 10 pounds of chlorine per 1,000 pounds of MLSS), consistent with what is known about these types of filaments, such as O21N and Nocardia. As a result of the resistance to chlorination and severity of the bulking issues at the plant, a variety of immediate action mitigation steps have been taken by plant operation to address the situation.

1.2 Current Mitigation and Investigation Steps

- Begin investigation of sources of COD and BOD loading variability to the plant from the collection system.
- Evaluate sources of SRMS and septicity characteristics in the collection system based on filamentous types observed in abundance recently at the wastewater plant. For example, COD is a broad measure of organic strength of the waste but Volatile Fatty Acids (VFAs) are a more specific focused measurement. VFAs measure specific organic acids that are known to contribute to filaments. COD, BOD, VFA testing has commenced accordingly.
- Begin advanced analytical testing for presence of inhibitory compounds to activated sludge such as quaternary ammonia compounds (QACs), commonly used in cleaning agents.
- Continue expanded monitoring of analytical parameters to monitor the process on a day-to-day basis; recent added parameters include COD testing throughout the plant daily, Oxygen Uptake Rate (OUR), additional SVI testing, and ammonia testing. Conducting regular outside analysis of advanced filamentous bacteria type and micro-examinations.
- Maintain contingency measures available at the plant to deploy in the event of rapid deterioration in sludge settling, including but not limited to polymers, coagulants, supplemental bacteria, and a second clarifier in ready mode.
- Maintain higher dissolved oxygen setpoints in the wastewater plant aeration system. Dissolved oxygen setpoints have been increased from about 3.0 mg/L to as high as 5.0 mg/L. However, only 1-2 mg/L is normally needed for a non-nitrifying activated sludge process. Higher setpoints do risk onset of sudden nitrification which can create operational challenges.
- Plan for regular cleaning of septic pump stations to help mitigate some sources of grease and septicity.


201 North Civic Drive, Suite 300
Walnut Creek, CA 94596

Phone: 925-937-9010
Fax: 925-937-9026


Prepared for: Sewer Authority Mid-Coastside
Project Title: WWTP Capacity and Process Study
Project No.: 156642

Technical Memorandum

Subject: Capacity Assessment and Alternatives Evaluation
Date: August 10, 2021
To: Kishen Prathivadi, Sewer Authority Mid-Coastside
From: Mike Harrison, P.E., Brown and Caldwell
Copy to:

Prepared by: 
Seppi Henneman, P.E.
California License C 82684



Reviewed by: 
Mike Harrison, P.E.
California License C 59814



Linda Sawyer, P.E.
California License C 58213

Table of Contents

Executive Summary	1
Section 1: Introduction and Objectives	2
Section 2: Historical Data Review	2
2.1 Description of Composite Sampling Locations	2
2.2 Flow and Loading Assumptions	2
2.3 Primary Clarifier Performance	4
2.4 Secondary System Performance	7
2.5 BOD Spike and Process Upset	11
Section 3: Process Model Development	11
3.1.1 Calibration and Validation Results	12
Section 4: Capacity Assessment	12
4.1 Primary Clarifier Operating Guidance	12
4.2 Secondary System	13
4.2.1 Solids Loading Rate Capacity	14
4.2.2 Capacity Results	14
Section 5: Plant Optimization and Operational Improvements	16
5.1 Cost Estimating Assumptions	16
5.2 Alternative 1	16
5.2.1 Hydraulic Considerations	17
5.2.2 Cost Breakdown	17
5.3 Alternative 2	18
5.3.1 Hydraulic Considerations	19
5.3.2 Cost Breakdown	19
5.4 Alternative 3	20
5.4.1 Hydraulic Considerations	21
5.4.2 Cost Breakdown	22
5.5 Equalization Opportunity	22
5.6 Capacity Comparison of Alternatives	23
5.7 Alternative Analysis Summary	23
Recommendations	24
Section 6: References	24
Attachment A: Cost Estimate	A
Attachment B: BioWin Calibration Summary	B
Attachment C: Hydraulic Upgrade Schematics	C
Attachment D: BOD Spike Period Plots	D
Attachment E: Operations TM	E

List of Figures

Figure 2-1. Influent flow rate.....	3
Figure 2-2. Raw influent BOD and TSS loading.....	4
Figure 2-3. Primary clarifier BOD removal (top) and TSS removal (bottom)	6
Figure 2-4. Aeration basin historical MLSS and WAS profile	8
Figure 2-5. Historical RAS chlorination impact on SVI.....	9
Figure 2-6. Secondary clarifier historical performance based on SOR and SLR	10
Figure 3-1. SAM WWTP plantwide BioWin Model schematics	11
Figure 4-1. SOR Versus Influent Flow at Various Conditions.....	13
Figure 4-2. Capacity estimate based on design PDWWF of 9 mgd (top) and 6 mgd (bottom)	15
Figure 5-1. Schematic of Alternative 1	17
Figure 5-2. Alternative 1 cost breakdown	18
Figure 5-3. Schematic of Alternative 2	19
Figure 5-4. Alternative 1 Cost Breakdown.....	20
Figure 5-5. Schematic of Alternative 3	21
Figure 5-6. Alternative 1 Cost Breakdown.....	22
Figure 5-7. Capacity of each alternative with planned mode of operation (red) and with all equipped basins operating (blue).....	23

List of Tables

Table 2-1. Summary of Flow and Loading Statistics from 2018-2020	2
Table 2-2. Summary of Peaking Factors Selected.....	3
Table 2-3. Summary of Primary Clarifier Dimensions (only equipped primary clarifiers are shown)	4
Table 2-4. Summary of Primary Clarifier Performance	5
Table 2-5. Summary of Aeration Basin Data	7
Table 2-6. Summary of SVI Statistics.....	9
Table 2-7. Secondary Clarifier Information	10
Table 4-1. Summary of Recommended Primary Clarifier Operating Conditions.....	13
Table 4-2. Summary of Existing Capacity	14
Table 5-1. Alternatives Analysis Summary	23
Table B-1. Summary of primary influent fractions	B-1
Table B-2. Summary of Calibration and Validation Results	B-2

List of Abbreviations

AA	annual average
ADW	average dry weather
ADWF	average dry weather flow
BC	Brown and Caldwell
BOD	biochemical oxygen demand
CEPT	chemically enhanced primary treatment
EPDM	ethylene propylene diene monomer
FeCl ₃	ferric chloride
gpd/sqft	= gallons per day per square foot
H ₂ S	hydrogen sulfide
lb/d	pounds per day
mgd	million gallons per day
mg/L	milligrams per liter
mL/g	milliliters per gram
MLSS	mixed liquor suspended solids
MLVSS	mixed liquor volatile suspended solids
MM	maximum month
O&M	Operations and Maintenance
OPCC	opinion of probable construction costs
PD	peak day
PDWWF	peak day wet weather flow
psig	pound-force per square inch
RAS	return activated sludge
SAM	Sewer Authority Mid-Coastside
scfm	standard cubic feet per minute
SLR	solids loading rate
SOR	surface overflow rate
SVI	sludge volume index
TM	technical memorandum
TSS	total suspended solids
VSS	volatile suspended solids
WAS	waste activated sludge
WWTP	Wastewater Treatment Plant

Executive Summary

The Sewer Authority Mid-Coastside (SAM) hired Brown and Caldwell (BC) in March 2021 to complete a wastewater treatment plant (WWTP) capacity assessment and operations evaluation. This request was in response to high influent biochemical oxygen demand (BOD) loading events that occurred in October 2020 that may have contributed to process upsets at the SAM WWTP.

BC initiated the work by conducting an on-site kickoff meeting on March 30, 2021, to discuss project objectives. Immediately after the kickoff meeting, BC conducted a visual assessment of the secondary treatment facilities. Over the next three weeks, BC reviewed the historical flow and loading data and past treatment performance as a basis for determining existing treatment capacity of the primary and secondary treatment processes. BC presented this information to SAM staff on May 17, 2021 and conducted a more detailed operations assessment to further confirm process capacity. BC concluded that using industry-standard assumptions for estimating process capacity along with the information obtained during the operations assessment, that the WWTP did not have adequate capacity to treat current flow and loading with only Aeration Basin 3, and that additional modifications should be constructed to increase the capacity at the WWTP.

Furthermore, improvements at the WWTP need to be coupled with source control in the collection system to reduce BOD spikes entering the WWTP to provide higher probabilities of maintaining compliance. Biological processes tend to perform better with stable influent loadings or loadings that change slowly. Significant peak events that arrive suddenly may result in elevated effluent pollutant concentrations which may result in permit violations. It cannot be deduced from this work that the very high influent BOD spike on its own caused the subsequent process upset. It is recommended to investigate the source of high BOD spikes in the collection system through a source control program to dampen the high BOD spikes entering the WWTP and provide higher probabilities of maintaining permit compliance.

BC finalized the existing facilities capacity analysis and identified future alternatives to increase secondary treatment capacity. BC presented the capacity information and proposed future treatment alternatives to SAM operation staff on June 17, 2021. Future alternatives presented and discussed in this workshop were:

1. Alternative 1 – Outfit Aeration Basin 4 with fine-bubble diffusers to match Aeration Basin 3. Operate both Aeration Basins 3 and 4 in parallel and have existing Aeration Basins 1 and 2 serve as a backup when Aeration Basins 3 or 4 are taken out of service for inspection.
2. Alternative 2 – Retrofit Aeration Basins 1 and 2 with fine-bubble diffusers instead of outfitting Aeration Basin 4. Operate all three basins in parallel.
3. Alternative 3 – Modify Aeration Basin 2 to operate in series prior to flow entering Aeration Basin 3.
4. Equalization – Modify Aeration Basin 1 to be able to operate as equalization by enabling gravity flow into the basin and pumping flow out.

During the June 17, 2021, workshop, the decision was made to continue to investigate all four treatment alternatives. BC developed construction cost estimates and associated treatment capacities for these alternatives. Additionally, system resiliency was assessed for each alternative to factor in the probability of system upsets, system redundancy, and operational complexity. The results were presented to SAM operations staff on July 21, 2021. Following discussion with operations staff, Alternative 1 was selected as the recommended alternative as it provides the most redundancy and does so at the lowest estimated cost with the lowest of risk potential plant violations. The draft report with this recommendation was presented to the SAM board on July 26, 2021.

Section 1: Introduction and Objectives

The Sewer Authority Mid-Coastside’s (SAM) wastewater treatment plant (WWTP) observed very high biochemical oxygen demand (BOD) concentrations and loading entering the WWTP in Fall 2020. This high loading period triggered a process upset that resulted in elevated BOD and total suspended solids (TSS) concentrations in the effluent. In response, SAM staff hired Brown and Caldwell (BC) to determine the capacity of the secondary treatment process and to provide recommendations for how to increase secondary treatment capacity. The previous design documents and operations and maintenance (O&M) manual did not document how the secondary process was intended to operate, so SAM also requested that BC provide updated O&M guidance.

The purpose of this technical memorandum (TM) is to present BC findings related to the existing secondary treatment capacity and to recommend a path forward for increasing secondary treatment capacity. BC provided operational guidance as part of this project, which is documented in a separate TM.

Section 2: Historical Data Review

2.1 Description of Composite Sampling Locations

A raw influent flow meter is located at the WWTP that measures flow using water level at the influent flume. A flow-weighted composite sample collects raw influent samples. A primary effluent composite sampler is used to collect time-weighted samples. A final effluent flow-weighted composite sample is used for effluent monitoring.

2.2 Flow and Loading Assumptions

An evaluation of data from 2018-2020 was performed to determine the flow and loading basis to use for the capacity assessment. The WWTP was designed in the 1990s, and influent wastewater characteristics have changed significantly since that timeframe, especially due to changes experienced from the drought that occurred in California from 2010-2015. Tables 2-1 and 2-2 summarize the raw influent flow and loading from 2018-2020, as well as the associated peaking factors used in the analysis.

Data from 2020 is shown for reference but is omitted from the analysis because it was skewed by a very high BOD spike in Fall 2020 that is not representative of typical wastewater characteristics and was not what the WWTP was designed to treat.

Table 2-1. Summary of Flow and Loading Statistics from 2018-2020

	Influent Flow, mgd				Influent BOD Load, lb/d				Influent TSS Load, lb/d			
	ADWF	AA	MM	PD	ADWF	AA	MM	PD	ADWF	AA	MM	PD
2018	1.3	1.4	1.9	5.3	3778	3590	4,788	5,771	3,203	3,297	3,739	5,626
2019	1.3	1.7	3.1	5.7	3636	3851	4,645	5,451	3,277	3,597	4,806	5,670
2020	1.2	1.3	1.7	3.0	4561	5058	12,593	19,871	3,216	3,510	4,311	5,725

AA = annual average
ADWF = average dry weather flow
MM = maximum month
PD = peak day
mgd = million gallons per day
lb/d = pounds per day

Table 2-2. Summary of Peaking Factors Selected

Peaking Factors									
2018	1.1	1.5	4.2	1.0	1.3	1.5	1.0	1.2	1.8
2019	1.3	2.4	4.3	1.1	1.3	1.5	1.1	1.5	1.7
2020	1.1	1.4	2.4	1.1	2.8	4.4	1.1	1.3	1.8
	Peaking Factor Selected	2.4	4.3		1.3	1.5		1.5	1.7

Figures 2-1 and 2-2 display time series plots of the influent flow, and BOD and TSS loading, respectively. These are shown to provide graphical representations of the data over time.




Figure 2-1. Influent flow rate




Figure 2-2. Raw influent BOD and TSS loading

2.3 Primary Clarifier Performance

There are a total of four rectangular primary clarifiers at the WWTP. Primary Clarifiers 1 and 2 were constructed originally in the 1950s. Primary Clarifiers 3 and 4 are old Aeration Tanks 1 and 2 that were reconfigured to primary clarifiers in 1999. Primary Clarifier 4 does not have equipment in it and is, therefore, not functional. Preliminary effluent from aerated grit tanks is sent to a channel, from which effluent is distributed to all primary clarifiers via slide gates. Table 2-3 shows a summary of primary clarifier dimensions.

Table 2-3. Summary of Primary Clarifier Dimensions (only equipped primary clarifiers are shown)		
Parameter	Primary Clarifiers 1 and 2	Primary Clarifier 3
Length, feet (ft)	65	75
Width, ft	20	20
Depth, ft	11	11
Surface area, square ft	1,300	1,500

The primary clarifiers at SAM have performed well over the period of data reviewed (January 2018–March 2021). Ferric chloride has been added upstream of the aerated grit tanks over that entire period, with annual average doses ranging from 10.6 to 14.4 milligrams per liter (mg/L) as ferric chloride (FeCl₃). The FeCl₃ is not flow paced. The primary purpose of dosing ferric chloride at this location is sulfide control in the digesters. This is a typical dosing scheme used at municipal wastewater treatment plants because the ferric chloride binds with sulfides and other compounds and then settles in the primary clarifiers before getting pumped into the digesters. The bound sulfide will not be converted to hydrogen sulfide (H₂S) in the digesters.

SAM staff started dosing polymer in the primary influent channel to try and achieve chemically enhanced primary treatment (CEPT) reactions. CEPT is typically characterized as dosing a coagulant (in this case ferric chloride) at least 3 to 5 minutes upstream of dosing a flocculant (i.e., polymer). The goal of CEPT dosing is to achieve higher TSS and BOD removal by creating larger particles and/or flocs that are more likely to settle in the primary clarifiers.

Table 2-4 shows a summary of primary clarifier performance over several time periods, with and without polymer addition. In general, the SAM WWTP achieves good TSS and BOD removal. Typical municipal WWTP primary clarifiers achieve 60 percent to 65 percent TSS removal, while SAM achieves 70 percent TSS removal on average. The data suggest that the addition of polymer did not improve primary clarifier performance.

Figure 2-3 shows time series plots of TSS and BOD removal as a means to visually display the primary clarifier performance over the period summarized in Table 2-4.

Table 2-4. Summary of Primary Clarifier Performance

Date and Condition	SOR, gpd/sqft	TSS Removal, percent	BOD Removal, percent	Ferric as FeCl ₃ , mg/L	Polymer, mg/L
2018 (no polymer)	650	70%	40%	10.6	0
2019 (no polymer)	736	71%	41%	11.8	0
Jan. 1, 2020 to Nov. 30, 2020 (no polymer)	408	70%	38%	14.4	0
Dec. 1, 2020 to March 24, 2021 (with polymer addition)	406	66%	36%	13.6	2.2

gpd/sqft = gallons per day per square foot

SOR = surface overflow rate





Figure 2-3. Primary clarifier BOD removal (top) and TSS removal (bottom)

2.3.1.1 Primary Clarifier Recommendations

If SAM wants to continue with CEPT, it is recommended to have a chemical vendor conduct jar tests to determine the most appropriate polymer chemical selection, along with the optimal chemical doses. It is also recommended that the chemical feed systems be improved to improve mixing where it is being added. Finally, it is recommended to include flow pacing to the influent flow rate; the facility currently uses constant chemical flow rates for ferric chloride and polymer.

2.4 Secondary System Performance

There are a total of four rectangular aeration basins at the WWTP. Aeration Basins 1 and 2 were constructed originally in the 1950s, while Aeration Basins 3 and 4 were constructed in 1999. Primary effluent flow from primary clarifiers is sent to a common channel, which then mixes with return activated sludge (RAS) and is fed to all basins. SAM staff have been using Aeration Basin 3 as the primary form of secondary treatment. Table 2-5 shows a summary of aeration basin dimensions.

Table 2-5. Summary of Aeration Basin Data		
Parameter	Reference: As-built Drawing Notes (Drawing No. G-2)	
	Aeration Basins 1 and 2	Aeration Basins 3 and 4
Length, ft	88.5	88.5
Width, ft	24	30
Depth, ft	16.3	16.3
Volume, cubic feet million gallons	34,620 (0.259)	43,280 (0.323)

There are four 125-horsepower centrifugal blowers (3 duty plus 1 standby) at the WWTP at a capacity of 2,275 standard cubic feet per minute (scfm) at 8.5 pounds of force per square inch gauge (psig). The total capacity of the blowers is 6,825 scfm at 8.5 psig with three of the four blowers online. Aeration Basins 1 and 2 have coarse-bubble diffusers, while Aeration Basin 3 has 9-inch Environmental Dynamics International (EDI) disc membrane diffusers (920 diffusers each tank), which were last replaced in May 2021. These diffusers have ethylene propylene diene monomer (EPDM) fine-bubble membranes, which are more efficient at transferring oxygen into the wastewater than the coarse-bubble diffusers. Aeration Basin 4 is not equipped with diffusers.

The solids residence time at SAM is typically around 2 days on average when accounting for only the inventory in the aeration basins. This has resulted in a typical mixed liquor suspended solids (MLSS) concentration around 1,500 mg/L. Figure 2-4 presents a time series plot of MLSS and waste activated sludge (WAS) TSS concentrations.




Figure 2-4. Aeration basin historical MLSS and WAS profile

The sludge volume index (SVI) data at SAM is shown on Figure 2-5 with RAS chlorination dosing. In general, the RAS chlorination dose has been very high at times and may have contributed to very high SVI values in late Fall 2020. If the RAS chlorination dose is too high, bacteria responsible for treatment may be impacted, which would limit their ability to treat the incoming wastewater. BC has provided operational guidance on RAS chlorination, which is documented separately in the Operations Assistance TM (Attachment E). The SVI statistics are summarized in Table 2-6. For the planning purposes of this TM, the design value 90th percentile SVI of 200 milliliters per gram (mL/g) was assumed. The high SVI associated with the upset was not used in this analysis.

After the period of data that this analysis was based on, there have been significantly high SVI excursions well past SVI values of 1,000 mL/g. The analysis here was not updated to accommodate such a high SVI but it should be mentioned for context.




Figure 2-5. Historical RAS chlorination impact on SVI

Table 2-6. Summary of SVI Statistics		
Timeframe	Average SVI, mL/g	90 th Percentile SVI, mL/g
2018	135	192
2019	134	187
2020	229	438
January 2021 - March 2021	204	248
January 2018 - July 2020 (prior to upset and used for planning purposes)	139	197

There are a total of two circular secondary clarifiers at the WWTP. These tanks were constructed in 1999 at the time of the regional facility expansion. Table 2-7 shows a summary of secondary clarifier dimensions. Figure 2-6 presents a time series plot of SOR and solids loading rate (SLR).

Table 2-7. Secondary Clarifier Information	
	Secondary Clarifiers 1 and 2
Diameter, ft	85
Side Water Depth, ft	14
Total Effective Area, ft ² , each	5,670
Design Peak Hour Overflow Rate, gpd/ft ²	1,401
RAS Pumping Capacity (1 pump offline), gallons per minute	3,600




Figure 2-6. Secondary clarifier historical performance based on SOR and SLR

2.5 BOD Spike and Process Upset

An influent BOD spike occurred on August 8, 2020, with BOD topping 1,000 mg/L. A second BOD spike occurred around October 1, 2020, with BOD increasing to 1,900 mg/L. The influent BOD spikes were not concurrent with influent TSS spikes, which would indicate that most of the BOD spike was soluble. However, primary effluent BOD data suggested that much of the BOD in the raw influent was removed through the primary clarification process, suggesting that the BOD was not soluble, as primary clarifiers do not remove soluble BOD. The raw influent and primary effluent data are not consistent during this period.

SAM staff provided direction that the capacity and alternatives analysis should not be based on this very high BOD spike and should instead be based on typical influent flow and loading values before the spike. Subsequent investigations into the collection system will work to prevent such BOD spikes in the future.

Attachment D provides a series of water quality plots to document the BOD spikes that occurred in 2020.

Section 3: Process Model Development

This section documents the development of the plantwide process model using BioWin Version 6.2. A screenshot of the BioWin model is provided in Figure 3-1.




Figure 3-1. SAM WWTP plantwide BioWin Model schematics

The aeration tanks were modeled as two zones to represent the two aeration drop legs along the length of the rectangular each tank. The model was calibrated first using actual plant data, and then validated using two validation periods. Once the model was validated, it was used to estimate capacity of the current system (see Section 4) and then was used to simulate future optimization scenarios (see Section 5).

A Level 2 calibration was performed based on historical data (Melcer et al., 2003). Model calibration and validation were performed to develop a model that could predict performance of the aeration basins relatively well, and then be used for capacity and plant performance evaluations.

3.1.1 Calibration and Validation Results

A detailed summary of the calibration and validation effort are tabulated in Attachment B. The following provides a summary of the conclusions and findings from the steady-state and dynamic model validations:

- Overall, the model predicts most parameters within 10 percent of historical data, which is suitable for a Level 2 calibration.
- The model provided a good match for MLSS and mixed liquor volatile suspended solids (MLVSS) inventory (within 10 percent for calibration and both validation periods).
- The model provided a good match for SRT (<5 percent for calibration and <15 percent for both validation periods) based on TSS:VSS ratio of 0.85.
- The model underpredicts aeration demand by <20 percent. However, SAM staff indicated that air is regularly wasted and/or blown off, so airflow values measured at SAM are not indicative of process air requirements.

Section 4: Capacity Assessment

BC assessed the WWTP's secondary treatment capacity to understand the maximum loading that can be treated. In addition, at the request of SAM staff, BC evaluated ways to operate the primary clarifiers at various flow rates.

4.1 Primary Clarifier Operating Guidance

SAM staff requested that BC provide guidance on how to operate the primary clarifiers at various influent flow conditions. A comprehensive evaluation of the existing primary clarifier capacity was not evaluated, but instead a focus on providing operational guidance was provided. Figure 4-1 shows the SOR values for various conditions plotted against influent flow rates. Operating only one of the small primary clarifiers is not a feasible option. In general, it is recommended to operate the two smaller primary clarifiers during dry weather conditions. Although the hydraulic design capacity (per original design drawings) shows that the two smaller clarifiers are sufficient to treat flows up to 9 mgd, it is recommended to switch to three primary clarifiers online when peak hourly flows are anticipated to exceed 5 mgd. This will optimize treatment performance by minimizing the SOR during peak flow events. Table 4-1 summarizes the primary clarifier operating recommendations.




Figure 4-1. SOR Versus Influent Flow at Various Conditions

Table 4-1. Summary of Recommended Primary Clarifier Operating Conditions	
Flow Condition	Primary Clarifier Condition
Influent flows up to 5 mgd hourly flows	Operate both small clarifiers
Influent flows exceeding 5 mgd hourly flow	Operate all 3 clarifiers

4.2 Secondary System

A secondary system capacity assessment was conducted to determine the capacity of the secondary system. Capacity of the secondary system could be limited by several factors, including:

- **Solids loading rate to the secondary clarifiers** –governed by a combination of MLSS concentrations, influent flow rate, and RAS flow rate.
- **Blower aeration capacity** –governed by how much air the blowers can output under certain conditions
- **Diffuser flux capacity** –governed by how much air can be conveyed through each diffuser without exceeding design limitations

The approach to evaluating the secondary system was to estimate the capacity for each of the three items described above, understanding that the actual secondary treatment capacity is limited by whichever item had the lowest treatment capacity.

The secondary treatment capacity was evaluated using current wastewater conditions and influent concentrations, which are significantly higher than when the original facility was designed. This is due to significant levels of water conservation, which have decreased flows significantly. The facility is designed for an ADWF of 3.69 mgd, but currently treats approximately 1.3 mgd, which is 35 percent of the design value. Due to the variability observed over the last 20 years and the chance for additional changes in the future, the secondary treatment capacity is shown in terms of BOD loading. The BOD loading is driven mostly by population changes in SAM's collection system but may also be changed if significant industrial/commercial sources move into the area. The loading will go up if the population goes up, regardless of whether the flow

per capita goes up or down. This method of quantifying capacity provides better information compared to evaluating capacity as a flow basis.

4.2.1 Solids Loading Rate Capacity

The solids loading rate capacity is governed by MLSS concentration, influent flow rate, settleability (i.e., SVI measurement), and RAS flow rate. The MLSS concentration was estimated using the BioWin model based on the primary effluent loadings and the aeration basin operating assumptions.

The solids loading rate capacity is determined by putting various combinations of these parameters into a state point analysis tool. The state point analysis tool evaluates various solids flux conditions and compares them to the solids flux curve, which is developed based on clarifier geometry and settleability assumptions. Information on each of these parameters is described in the following subsections.

4.2.1.1 Flow Assumptions

The SAM WWTP is rated for a peak design flow of 9 mgd and a peak hourly wet weather flow of 15 mgd. Over the historical period evaluated, the maximum peak day was 5.6 mgd. The peak day flow was used for estimating capacity, because the clarifiers appear well designed and are relatively deep, which yields some sludge storage capacity to address peak hourly flow rates. It may be unlikely that SAM observes a peak day flow of 9 mgd in the near future, but the capacity is rated based on this previously rated peak day capacity to avoid any attempt to re-rate the hydraulics at the SAM WWTP.

4.2.1.2 Settleability Assumptions

An SVI value of 200 mL/g was used (the 90th percentile over the period before the process upset was 197 mL/g), per Section 2.4.

4.2.2 Capacity Results

The BioWin modeling and subsequent airflow calculations suggested that there is sufficient aeration capacity for both the blower system and for diffuser flux, and that the solids loading rate was always the limiting factor when evaluating capacity at SAM. As such, the capacity results are shown in terms of solids loading rate. Capacities are based on recent BOD loading data from January 2018 through July 2020. The BOD loading associated with the BOD spikes (described in Section 2.5) are not included in this analysis.

Table 4-2 summarizes the capacity findings. Figure 4-2 presents the results for the capacity analysis graphically. The capacity is shown two ways:

- To treat a peak day flow of 9 mgd (to match rated design capacity)
- To treat a peak day flow of 6 mgd (rounded up from recent maximum peak day flow of 5.6 mgd)

The rated capacity is based on the rated design capacity of 9 mgd; however, SAM may not observe a peak day flow of 9 mgd in the short term. To provide context as to what the capacity may be in the short term, the same capacity calculations were performed at a peak day flow of 6 mgd, which is close to the recent maximum of 5.6 mgd.

Table 4-2. Summary of Existing Capacity

Condition	Units	Aeration Basin 3 Only	Aeration Basins 1 and 2 Only	All Three Aeration Basins Online
PDWWF of 9 mgd	ADW BOD load, lb/d	2,600	3,600	5,400
PDWWF of 6 mgd	ADW BOD load, lb/d	3,400	4,600	7,300

Note: The current ADW BOD load is approximately 3,700 lb/d

ADW = average dry weather

PDWWF = peak day wet weather flow





Figure 4-2. Capacity estimate based on design PDWWF of 9 mgd (top) and 6 mgd (bottom)

Section 5: Plant Optimization and Operational Improvements

BC evaluated several alternatives to upgrade the existing secondary process to provide more treatment capacity. Details of the scope of what is included in each alternative is provided in each subsection. A summary of the process capacities is provided in Section 5.6.

The process capacity was determined for each alternative using the following assumptions:

- Design PDWWF of 9 mgd
- A 90th percentile SVI of 200 mL/g
- Average BOD concentration of 340 mg/L
- Alternatives did not evaluate the ability to treat extreme BOD spikes, as it is anticipated that the pre-treatment analysis will return the BOD loading to normal conditions (i.e., January 2018 to June 2020)

5.1 Cost Estimating Assumptions

Conceptual-level opinion of probable construction costs (OPCC) prepared for this TM represent order-of-magnitude estimates as defined by the Association for the Advancement of Cost Engineering International criteria for a Class 5 estimate (-50 percent to +100 percent accuracy). The OPCCs are based on a recommended project's scopes of work and material quantity and represent costs that would be incurred if the project were bid in 2021 under current market conditions. The estimates provided include costs for demolition, mechanical equipment and piping, and structural and electrical improvements. The OPCC includes contractor overhead, profit, mobilization, bonds, insurance, and contingency markups.

All of the costs presented in this TM are construction cost estimates to be compared to a contractor's bid. To derive total project costs (i.e., capital costs), SAM staff would need to apply the appropriate factors for items such as administration, planning/environmental, design, and construction management. Typically, these costs may add an additional 30 percent to 45 percent markup on top of construction costs presented in this TM, but the amount of markup is specific to each agency.

Annual operating costs were not included as part of the alternatives evaluations because the costs would be similar between the alternatives and would not impact process selection.

Attachment A contains detailed descriptions of each cost estimate as well as detailed markups and assumptions.

5.2 Alternative 1

Alternative 1 consisted of installing new equipment in Aeration Basin 4 such that it matches the equipment in Aeration Basin 3. This included the following scope:

- Install fine-bubble diffusers in Aeration Basin 4 to match Aeration Basin 3
- Replace weir gates in Aeration Basins 1 and 2 so that Aeration Basins 1 and 2 can be used in parallel with either Aeration Basin 3 or 4 during maintenance events
- Install aeration piping with valving for two drop legs in Aeration Basin 4
- Install spray header with spray nozzles in Aeration Basin 4
- Install new dissolved oxygen instruments in Aeration Basin 4

Figure 5-1 presents a schematic of Alternative 1. Aeration Basins 3 and 4 are assumed to be used for the main form of treatment, with Aeration Basins 1 and 2 used only as needed during maintenance events. This alternative provides the highest level of redundancy, because all four tanks would be equipped. The Aeration

Basins 1 and 2 would still have coarse-bubble diffusers, providing less efficient treatment and recommended only for limited use.




Figure 5-1. Schematic of Alternative 1

5.2.1 Hydraulic Considerations

The flow routing will be the same as the current operation. The only hydraulic modifications are to replace the gates at the inlet of Aeration Basins 1 and 2 with weir gates sized to provide the appropriate flow split between Aeration Basins 1 and 2 and Aeration Basins 3 and 4. Hydraulic modeling during pre-design should be performed to determine the weir length and weir height to be used to obtain a volume-proportional flow split (i.e., more flow should go to Aeration Basins 3 and 4 than to Aeration Basins 1 and 2 because Aeration Basins 3 and 4 have a higher volume than Aeration Basins 1 and 2).

Attachment C contains schematics depicting the hydraulic upgrades required.

5.2.2 Cost Breakdown

The OPCC for Alternative 1 was \$565,000, which represents a range of \$283,000 to \$1,130,000. Figure 5-2 presents an approximate cost breakdown. Refer to the detailed cost estimate in Attachment A for further details.




Figure 5-2. Alternative 1 cost breakdown

Note that this cost breakdown has costs rounded for clarity and the sum may not exactly match the cost estimate.

5.3 Alternative 2

Alternative 2 consisted of retrofitting Aeration Basins 1 and 2 with fine-bubble diffusers to operate continuously in parallel with Aeration Basin 3. Aeration Basin 4 is not used in this Alternative. This included the following scope:

- Remove the existing coarse-bubble diffuser system in Aeration Basins 1 and 2
- Install new fine-bubble diffusers in Aeration Basins 1 and 2 using the same diffuser density as Aeration Basin 3
- Replace weir gates to Aeration Basins 1 and 2 (similar to Alternative 1)
- Construct new baffle walls in Aeration Basins 1 and 2 to address perceived short-circuiting issues

Figure 5-3 presents a schematic of Alternative 2. This alternative assumes that Aeration Basins 1, 2, and 3 would operate in parallel to perform secondary treatment. Replacing the weir gates provides more redundancy than SAM currently has because any combination of basins could operate in parallel. However, this alternative does not have the same level of redundancy and resiliency as Alternative 1.

The baffle walls may or may not be needed. It is recommended to perform testing to determine if short-circuiting is occurring or not prior to installing any baffling for this alternative. In addition, the cost estimate assumed concrete baffle walls, which was assumed to provide a conservative cost estimate. If baffle walls are installed, the design engineer should consider other materials that may be less costly.




Figure 5-3. Schematic of Alternative 2

5.3.1 Hydraulic Considerations

The flow routing will be the same as the current operation. The only hydraulic modifications are to replace the gates at the inlet of Aeration Basins 1 and 2 with weir gates. Hydraulic modeling during pre-design should be performed to determine the weir length and weir height to be used to obtain a volume-proportional flow split. These considerations are the same as Alternative 1.

Attachment C contains schematics depicting the hydraulic upgrades required.

5.3.2 Cost Breakdown

The OPCC for Alternative 2 was \$658,000, which represents a range of \$329,000 to \$1,316,000. Figure 5-4 presents an approximate cost breakdown. Refer to the detailed cost estimate in Attachment A for further details.




Figure 5-4. Alternative 1 Cost Breakdown

Note that this cost breakdown has costs rounded for clarity and the sum may not exactly match the cost estimate.

5.4 Alternative 3

Alternatives 1 and 2 presented options to upgrade the infrastructure at the SAM WWTP while following the same treatment philosophy currently employed. Alternative 3 represents a significant change from the secondary treatment philosophy and implements an anaerobic selector within the aeration basins. The purpose of the anaerobic selector is to reduce the readily biodegradable BOD before it reaches the aerobic zones, which would significantly improve settleability (i.e., decrease the design SVI). This has a great benefit to capacity because the existing capacity limitations at the WWTP are related to poor settleability (i.e., high SVI), which limits the solids loading rate that clarifiers can treat. This alternative provides the most treatment capacity per available basin volume.

One drawback of implementing an anaerobic selector at SAM would be the high probability of struvite precipitation in the anaerobic digesters and associated downstream equipment. Struvite would have a high probability of precipitating because the sludge being sent to the digester would have significantly higher concentrations of phosphorus, which is a key element in struvite. The new treatment process would have an anaerobic zone that would encourage biological phosphorus removal, which would encourage biomass to grow that may have four to six times more phosphorus than the biomass currently present in the WWTP's aeration basins.

Alternative 3 requires significant modifications to implement. It would require Aeration Basin 2 to flow in series with Aeration Basin 3, whereas they currently operate in parallel. Aeration Basin 2 would require approximately 60 percent of the volume to be unaerated and instead mixed with mechanical mixers. The remaining 40 percent of the volume would be replaced with fine-bubble diffusers at high density. Aeration Basin 4 would be configured to match Aeration Basin 3.

This alternative includes the following scope:

- Perform the scope of work for Alternative 1 as described above
- Remove the existing coarse-bubble diffusers in Aeration Basins 1 and 2
- Install new fine-bubble diffusers in the last 40 percent of volume in Aeration Basin 2
- Replace weir gates in Aeration Basins 1 and 2
- Construct a new baffle walls in Aeration Basin 2
- Install two submersible mixers in Aeration Basin 2
- Install coarse-bubble diffusers in the Aeration Basin 1 channel
- Infill openings in the concrete divider wall in the Aeration Basin 1 channel
- Install stainless steel stop plates in the basin channels

Figure 5-5 presents a schematic of Alternative 3. This alternative assumes that Aeration Basin 2 flows in series into Aeration Basin 3. This alternative does not have a high level of redundancy for the anaerobic selector. If Aeration Basin 2 had to come offline, SAM could operate with Aeration Basins 3 and 4 in parallel in a fully aerobic mode of operation. This alternative has the highest capacity per online basin volume, and if all basins are retrofitted would have the highest capacity rating. In addition, due to achieving significantly better settleability (i.e., lower SVI), the facility would have better process resiliency from upset periods.




Figure 5-5. Schematic of Alternative 3

5.4.1 Hydraulic Considerations

Alternative 3 requires the most hydraulic upgrades. It requires reversing flow in the primary effluent channel such that primary effluent and RAS flow into the front of Aeration Basin 2, with flow from Aeration Basin 2 flowing into the Aeration Basin 3 influent channel and through Aeration Basin 3 and/or Aeration Basin 4. Flow from Aeration Basins 3 and 4 would still go to the secondary clarifiers.

Attachment C contains schematics depicting the hydraulic upgrades required.

5.4.2 Cost Breakdown

The OPCC for Alternative 3 was \$1,051,000, which represents a range of \$526,000 to \$2,106,000. Figure 5-6 presents an approximate cost breakdown. Refer to the detailed cost estimate in Attachment A for further details.




Figure 5-6. Alternative 1 Cost Breakdown

Note that this cost breakdown has costs rounded for clarity and the sum may not exactly match the cost estimate.

5.5 Equalization Opportunity

Operations staff asked BC to evaluate what it would take to repurpose Aeration Basin 1 as an equalization basin. Although physical modifications were identified and costed out to do this, this mode of operation is not recommended at this time. Using Aeration Basin 1 for equalization does not increase capacity. The driver for using Aeration Basin 1 as an equalization basin would be operational flexibility. Since this work focused on identifying ways to increase capacity, and given re-purposing Aeration Basin 1 as an equalization basin does not increase capacity, repurposing Aeration Basin 1 is not recommended at this time.

The scope of this work includes:

- Installing an 8-inch influent pipe with a magnetic flow meter in Aeration Basin 1
- Installing a submersible pump with a variable-frequency drive in Aeration Basin 1

The OPCC for these upgrades was \$244,000, with a range of \$122,000 to \$488,000.

5.6 Capacity Comparison of Alternatives

The capacity of each alternative was evaluated based on the assumptions listed at the beginning of Section 5. Figure 5-7 presents capacities identified for each alternative. All three alternatives provided capacity at a BOD loading that is at least 20 percent greater than the current average dry weather BOD loading of 3,700 lb/d.




Figure 5-7. Capacity of each alternative with planned mode of operation (red) and with all equipped basins operating (blue)

The OPCC estimates are shown as green text under each alternative.

5.7 Alternative Analysis Summary

Table 5-1 compares each alternative based on several criteria, including operational flexibility, cost, risk of violations, cost certainty, and redundancy. For comparison purposes, each alternative is compared to the current plant configuration.

Condition	Current Configuration	Alternative 1	Alternative 2	Alternative 3
Treatment Capacity to meet current loading	No	Yes	Yes	Yes
Redundancy	No	Yes	No	No
Cost	N/A	Low	Medium	High
Risk of construction cost increase	N/A	Low	High	High

Table 5-1. Alternatives Analysis Summary

Condition	Current Configuration	Alternative 1	Alternative 2	Alternative 3
Probability risk of violation	High	Low	Medium	Low
Construction Risk	N/A	Low	High	High
Operational complexity and risk	Low	Low	Low	High
Maintenance risk	High	Low	High	High

Note: The current configuration is assumed to be either Aeration Basin 3 in service or Aeration Basins 1 and 2 in service

There are also some process improvements which are recommended which are common to all alternatives. These include flow pacing ferric and polymer at the WWTP. This is important because over dosing ferric may result in a phosphorus deficiency and underdosing may result in higher BOD loading to the activated sludge system. A planning level cost for making the physical upgrades to flow pace chemicals is \$70,000.

All costs presented in this section can be refined during pre-design. Selection of materials and type of bidding process impact costs and assumptions were made to develop planning level costs for the purposes of making decisions. It is likely that costs can be optimized during pre-design.

Recommendations

Alternative 1 provides the most redundancy and does so at the lowest estimated cost. It provides a simple construction and implementation schedule because the construction is in an empty basin, and the construction period would have minimal impacts on the existing treatment process. It would provide four available aeration basins to SAM staff, thus providing more flexibility in treatment.

It is recommended to implement Alternative 1. If loading significantly increases due to population growth or new industrial contributions, then Aeration Basins 1 and 2 can be retrofitted with fine-bubble diffusers to provide additional, high-efficiency treatment. Until Aeration Basins 1 and 2 are needed for normal treatment, they can be used as emergency/standby aeration basins to be used during maintenance events when Aeration Basins 3 or 4 are not available.

It is recommended to adjust chemicals onsite to be flow paced, specifically the ferric chloride and polymer, which are used for CEPT. The data review suggests that the polymer did not help increase settling in the primary clarifiers, but optimizing the dose and flow-pacing the chemical may result in better treatment. Costs for flow pacing chemicals are estimated to be \$70,000.

Section 6: References

H. Melcer, P.L. Dold, R.M. Jones, C.M. Bye, T. I., H.D. Stensel, A.W. Wilson, P. Sun, S. Bury. Methods for Wastewater Characterization in Activated Sludge Modelling Water Environment Research Foundation, IWA Publishing and Water Environment Federation, Alexandria, VA, USA and London, UK (2003)

Attachment A: Cost Estimate



Memorandum

Date: July 21, 2021
To: Mike Harrison, Sacramento
From: Steve Payne, Atlanta
Reviewed by: Bill Agster, Atlanta
Project No.: 156642.300.302
Subject: WWTP Capacity Study
Planning Level
Basis of Estimate of Probable Construction Cost

The Basis of Estimate Report and supporting estimate reports for the subject project are attached. Please call me if you have questions or need additional information.

Enclosures (3):

1. Basis of Estimate Report
2. Summary Estimate
3. Detailed Estimate

Basis of Estimate Report

Project Title

Introduction

Brown and Caldwell (BC) is pleased to present this opinion of probable construction cost (estimate) prepared for the Sewer Authority Mid-Coastside's WWTP Capacity Study, Half Moon Bay, California.

Estimated Project Costs

Based on the typical accuracy of a Class 5 estimate, the expected ranges of costs are:

	Upper Range	Estimated Cost	Lower Range
	+ 100 %		- 50 %
Alt 1	\$1,130,000	\$565,000	\$283,000
Alt 2	\$1,316,000	\$658,000	\$329,000
Alt 3	\$2,106,000	\$1,051,000	\$526,000
Alt 4	\$488,000	\$244,000	\$122,000

Summary

This Basis of Estimate contains the following information:

- Scope of work
- Background of this estimate
- Class of estimate
- Estimating methodology
- Direct cost development
- Indirect cost development
- Bidding assumptions
- Estimating assumptions
- Estimating exclusions
- Allowances for known but undefined work
- Contractor and other estimate markups

Scope of Work

The project consists of four alternatives, the scopes of which are described below:

Alternative 1

- Install fine bubble diffusers in Basin 4
- Replace weir gates in Basins 1 and 2
- Install aeration piping with valving for two drop legs in Basin 4

- Install spray header with spray nozzles in Basin 4
- Install two DO probes in Basin 4

Alternative 2

- Remove the existing coarse bubble diffusers in Basin 1 and 2
- Install new fine bubble diffusers in Basins 1 and 2
- Replace weir gates in Basins 1 and 2
- Construct new baffle walls in Basins 1 and 2

Alternative 3

- Perform the scope of work for Alternate 1 as described above
- Remove the existing coarse bubble diffusers in Basin 1 and 2
- Install new fine bubble diffusers in Basin 2
- Replace weir gates in Basins 1 and 2
- Construct a new baffle walls in Basin 2
- Install two submersible mixers in Basin 2
- Install coarse bubble diffusers in the Basin 1 Channel
- Infill openings in the concrete divider wall in the Basin 1 Channel
- Install stainless steel stop plates in the basin channels

Alternative 4

- Install an 8" influent pipe with magnetic flow meter in Basin 1
- Install a submersible pump with VFD in Basin 1. The 8" pump discharge pipe will include a magnetic flow meter.

Background of this Estimate

No previous estimates have been prepared for this project by BC's Estimating and Scheduling Group (ESG).

The attached estimate of probable construction cost is based on documents dated June 2021, received by the Estimating and Scheduling Group (ESG). These documents are described as planning level based on the current project progression, additional or updated scope and/or quantities, and ongoing discussions with the project team. Further information can be found in the detailed estimate reports.

Class of Estimate

Class 5: 0 to 2 Percent Conceptual Design Completion

In accordance with the Association for the Advancement of Cost Engineering International (AACE) criteria, this is a Class 5 estimate. A Class 5 estimate is defined as a Conceptual Level or Project Viability Estimate. Typically, engineering is from 0 to 2 percent complete. Class 5 estimates are used to prepare planning level cost scopes or evaluation of alternative schemes, long range capital outlay planning and can also form the base work for the Class 4 Planning Level or Design Technical Feasibility Estimate.

Expected accuracy for Class 5 estimates typically ranges from -50 to +100 percent, depending on the technological complexity of the project, appropriate reference information and the inclusion of an appropriate contingency determination. In unusual circumstances, ranges could exceed those shown.

Estimating Methodology

This estimate was prepared using quantity take-offs, vendor quotes and equipment pricing furnished either by the project team or by the estimator. The estimate includes direct labor costs and anticipated productivity adjustments to labor and equipment. Where possible, estimates for work anticipated to be performed by specialty subcontractors have been identified.

Construction labor crew and equipment hours were calculated from production rates contained in documents and electronic databases published by R.S. Means, Mechanical Contractors Association (MCA), National Electrical Contractors Association (NECA), and Rental Rate Blue Book for Construction Equipment (Blue Book).

This estimate was prepared using BC's estimating system, which consists of Sage Construction and Real Estate 300 estimating software engine (formerly Timberline) using RS Means database, historical project data, the latest vendor and material cost information, and other costs specific to the project location.

Direct Cost Development

Costs associated with the General Provisions and the Special Provisions of the construction documents, which are collectively referred to as Contractor General Conditions (CGC), were based on the estimator's interpretation of the contract documents. The estimates for CGCs are divided into two groups: a time-related group (e.g., field personnel) and non-time-related group (e.g., bonds and insurance). Labor burdens such as health and welfare, vacation, union benefits, payroll taxes, and worker's compensation insurance are included in the labor rates. No trade discounts were considered.

Indirect Cost Development

Local sales tax has been applied to material and equipment rentals. A percentage allowance for contractor's home office expense has been included in the overall rate markups. The rate is standard for this type of heavy construction and is based on typical percentages outlined in Means Heavy Construction Cost Data.

The contractor's cost for builder's risk, general liability and vehicle insurance has been included in this estimate. Based on historical data, this is typically two to four percent of the overall construction contract amount. These indirect costs have been included in this estimate as a percentage of the gross cost and are added after the net markups have been applied to the appropriate items.

Bidding Assumptions

The following bidding assumptions were considered in the development of this estimate.

1. Bidders must hold a valid, current Contractor's credentials, applicable to the type of project.
2. Bidders will develop estimates with a competitive approach to material pricing and labor productivity, and will not include allowances for changes, extra work, unforeseen conditions or any other unplanned costs.
3. Estimated costs are based on a minimum of four bidders. Actual bid prices may increase for fewer bidders or decrease for a greater number of bidders.
4. Bidders will account for General Provisions and Special Provisions of the contract documents and will perform all work except electrical which will be performed by a specialty subcontractor.

Estimating Assumptions

As the design progresses through different completion stages, it is customary for the estimator to make assumptions to account for details that may not be evident from the documents. The following assumptions were used in the development of this estimate.

1. The fine bubble diffuser system in Basin 4 is based on 1,564 diffuser heads.
2. The fine bubble diffuser systems for Basins 1 and 2 are based on 660 diffuser heads per basin.
3. The coarse bubble diffuser system in the Basin 1 Channel is based on 28 diffuser heads.
4. All piping is based on 316 stainless steel, schedule 10.
5. Contractor will be pressure wash the basins prior to beginning demolition and/or installation activities.
6. Contractor performs the work during normal daylight hours, nominally 7 a.m. to 5 p.m., Monday through Friday, in an 8-hour shift. No allowance has been made for additional shift work or weekend work.
7. Contractor has complete access for lay-down areas and mobile equipment.
8. Equipment rental rates are based on verifiable pricing from the local project area rental yards, Blue Book rates, and/or rates contained in the estimating database.
9. Contractor markup is based on conventionally accepted values that have been adjusted for project-area economic factors.
10. Major equipment costs are based on vendor supplied price quotes obtained by the project design team and/or estimators and on historical pricing of like equipment.
11. Process equipment vendor training using vendors' standard Operations and Maintenance (O&M) material is included in the purchase price of major equipment items where so stated in that quotation.
12. Bulk material quantities are based on manual quantity take-offs.
13. There is enough electrical power to feed the specified equipment. The local power company will supply power and transformers suitable for this facility.

Estimating Exclusions

The following estimating exclusions were assumed in the development of this estimate.

1. Hazardous materials remediation and/or disposal.
2. O&M costs for the project except for the vendor supplied O&M manuals.
3. Utility agency costs for incoming power modifications.
4. Permits beyond those normally needed for the type of project and project conditions.
5. Impacts from COVID-19 including additional labor and management hours required to meet social distancing, personal protection, and cleaning routines, additional costs of protective equipment, supply chain impacts, and material shortages.

Allowances for Known but Undefined Work

The following allowances were made in the development of this estimate.

1. \$24,000 each for the submersible mixers.
2. \$50,000 for the submersible pump and VFD.
3. \$45 per coarse bubble diffuser head.

Contractor and Other Estimate Markups

Contractor markup is based on conventionally accepted values which have been adjusted for project-area economic factors. Estimate markups are shown in Table 1.

Table 1. Estimate Markups	
Item	Rate (%)
Net Cost Markups	
Labor (employer payroll burden)	15
Materials and process equipment	10
Equipment (construction-related)	10
Subcontractor	10
Other - Process Equipment	8
Sales Tax (State and local for materials, process equipment and construction equipment rentals, etc.)	8.75
Sales Tax (Excise-Gross Receipts-Contract Value)	0
Material Shipping and Handling	2
Gross Cost Markups	
Contractor General Conditions	15
Start-up, Training and O&M	2
Construction Contingency	30
Builders Risk, Liability and Auto Insurance	2
Performance and Payment Bonds	1.5

Labor Markup

The labor rates used in the estimate were derived from RS Means latest national average wage rate tables and city cost indexes. These include base rate paid to the laborer plus fringes. A labor burden factor is applied to these such that the final rates include all employer paid taxes. These taxes are FICA (which covers social security plus Medicare), Workers Comp (which varies based on state, employer experience and history) and unemployment insurance. The result is fully loaded labor rates. In addition to the fully loaded labor rate, an overhead and profit markup is applied at the back end of the estimate. This covers payroll and accounting, estimator's wages, home office rent, advertising and owner profit.

Materials and Process Equipment Markup

This markup consists of the additional cost to the contractor beyond the raw dollar amount for material and process equipment. This includes shop drawing preparation, submittal and/or re-submittal cost, purchasing and scheduling materials and equipment, accounting charges including invoicing and payment, inspection of received goods, receiving, storage, overhead and profit.

Equipment (Construction) Markup

This markup consists of the costs associated with operating the construction equipment used in the project. Most GCs will rent rather than own the equipment and then charge each project for its equipment cost. The equipment rental cost does not include fuel, delivery and pick-up charges, additional insurance requirements on rental equipment, accounting costs related to home office receiving invoices and payment. However, the crew rates used in the estimate do account for the equipment rental cost. Occasionally, larger contractors will have some or all the equipment needed for the job, but to recoup their initial purchasing cost they will charge the project an internal rate for equipment use which is like the rental cost of equipment. The GC will apply an overhead and profit percentage to each individual piece of equipment whether rented or owned.

Subcontractor Markup

This markup consists of the GC's costs for subcontractors who perform work on the site. This includes costs associated with shop drawings, review of subcontractor's submittals, scheduling of subcontractor work, inspections, processing of payment requests, home office accounting, and overhead and profit on subcontracts.

Sales Tax (Materials, Process Equipment and Construction Equipment)

This is the tax that the contractor must pay according to state and local tax laws. The percentage is applied to both the material and equipment the GC purchases as well as the cost for rental equipment. The percentage is based on the local rates in place at the time the estimate was prepared.

Contractor Startup, Training, and O&M Manuals

This cost markup is often confused with either vendor startup or owner startup. It is the cost the GC incurs on the project beyond the vendor startup and owner startup costs. The GC generally will have project personnel assigned to facilitate the installation, testing, startup and O&M manual preparation for equipment that is put into operation by either the vendor or owner. These project personnel often include an electrician, pipe fitter or millwright, and/or I&E technician. These personnel are not included in the basic crew makeup to install the equipment but are there to assist and troubleshoot the startup and proper running of the equipment. The GC also incurs a cost for startup for such things as consumables (oil, fuel, filters, etc.), startup drawings and schedules, startup meetings and coordination with the plant personnel in other areas of the plant operation.

Builders Risk, Liability, and Vehicle Insurance

This percentage comprises all three items. There are many factors which make up this percentage, including the contractor's track record for claims in each of the categories. Another factor affecting insurance rates has been a dramatic price increase across the country over the past several years due to domestic and foreign influences. Consequently, in the construction industry we have observed a range of 0.5 to 1 percent for Builders Risk Insurance, 1 to 1.25 percent for General Liability Insurance, and 0.85 to 1 percent for Vehicle Insurance. Many factors affect each area of insurance, including project complexity and contractor's requirements and history. Instead of using numbers from a select few contractors, we believe it is more prudent to use a combined 2 percent to better reflect the general costs across the country. Consequently, the actual cost could be higher or lower based on the bidder, region, insurance climate, and the contractor's insurability at the time the project is bid.

Material Shipping and Handling

This can range from 2 to 6 percent, and is based on the type of project, material makeup of the project, and the region and location of the project. Material shipping and handling covers delivery costs from vendors, unloading costs (and in some instances loading and shipment back to vendors for rebuilt equipment), site paperwork, and inspection of materials prior to unloading at the project site. BC typically adjusts this percentage by the amount of materials and whether vendors have included shipping costs in the quotes that were used to prepare the estimate. This cost also includes the GC's cost to obtain local supplies, e.g., oil, gaskets and bolts that may be missing from the equipment or materials shipped.

Escalation to Midpoint for Labor, Materials and Subcontractors

In addition to contingency, it is customary for projects that will be built over several years to include an escalation to midpoint of anticipated construction to account for the future escalation of labor, material and equipment costs beyond values at the time the estimate is prepared. For this project, the anticipated rate of escalation is four percent per annum.

The estimated construction time for this project has not been determined. Four percent escalation has been included in the estimate

Undesigned/Undeveloped Contingency

The contingency factor covers unforeseen conditions, area economic factors, and general project complexity. This contingency is used to account for those factors that cannot be addressed in each of the labor and/or material installation costs. Based on industry standards, completeness of the project documents, project complexity, the current design stage and area factors, construction contingency can range from 10 to 50 percent.

Performance and Payment Bonds

Based on historical and industry data, this can range from 0.75 to 3 percent of the project total. There are several contributing factors including such items as size of the project, regional costs, contractor's historical record on similar projects, complexity and current bonding limits. BC uses 1.5 percent for bonds, which we have determined to be reasonable for most heavy construction projects.



Estimate Summary Report

7/20/2021 8:12 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

SEWER AUTHORITY MID-COASTSIDE WWTP CAPACITY STUDY - ALTERNATIVE 1 CLASS 5 ESTIMATE - PLANNING LEVEL

Estimator	Steve Payne
BC Project Manager	Mike Harrison
BC Office	Sacramento
Est Version Number	1
QA/QC Reviewer	Bill Agster
QA/QC Review Date	06/29/21
BC Project Number	156642



Estimate Summary Report

7/20/2021 8:12 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

Phase	Description	Gross Total Cost with Markups
01 TOTALS		
01 Alternative 1		
01 Demolition		16,340
04 Process Mechanical		461,135
05 Electrical and Instrumentation		87,884
01 Alternative 1		565,360
01 TOTALS		565,360



Estimate Detail Report


7/20/2021 8:09 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

SEWER AUTHORITY MID-COASTSIDE WWTP CAPACITY STUDY - ALTERNATIVE 1 CLASS 5 ESTIMATE - PLANNING LEVEL

Estimator	Steve Payne
BC Project Manager	Mike Harrison
BC Office	Sacramento
Est Version Number	1
QA/QC Reviewer	Bill Agster
QA/QC Review Date	06/29/21
BC Project Number	156642




Estimate Detail Report

7/20/2021 8:09 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
01 TOTALS										
01 Alternative 1										
01 Demolition										
02999 Demo Weir Gates										
02-22-04.	Site demolition, 48" weir gate	BC-0056	4.00 ea	1,016.51	-	-	-	-	1,016.51	4,066
50										
	Demo Weir Gates		0.00							4,066
02999 Pressure Wash Basin 4										
04-01-30.	Cleaning masonry, high pressure wash, average soil,	0420	2,700.00 sf	1.54	0.26	-	-	-	1.80	4,873
20	biological staining, water only, excludes scaffolding									
	Pressure Wash Basin 4		0.00							4,873
01 Demolition										8,939
04 Process Mechanical										
22112 4" Spray Piping A53 Threaded Field Run w/ 60 Nozzles										
22-11-13.	Pipe, steel, black, threaded, 4" diameter, schedule 40,	0650	248.00 lf	41.63	-	28.00	-	-	69.63	17,267
44	Spec. A-53, includes coupling and clevis hanger assembly sized for covering, 10' OC									
22-11-13.	Elbow, 90 Deg., steel, cast iron, black, straight, threaded,	0180	4.00 ea	249.76	-	221.00	-	-	470.76	1,883
45	standard weight, 4"									
22-11-13.	Tee, steel, cast iron, black, straight, threaded, standard	0620	61.00 ea	374.64	-	335.00	-	-	709.64	43,288
45	weight, 4"									
22-11-19.	Sleeve, pipe, steel with water stop, 12" long, 6" diam. for	0200	1.00 ea	169.42	-	142.00	-	-	311.42	311
34	4" carrier pipe, includes link seal									
22-20-02.	High impact, flat spray nozzle, 2 gpm@40 psi, 35 deg spray	BC-0001	60.00 ea	103.02	-	28.39	-	-	131.41	7,885
95	angle, ball jt									
40-05-05.	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L139048000	248.00 lf	2.72	-	-	-	-	2.72	675
00		000								
09-91-06.	Coatings & paints, B & C coating system E-1 (Epoxy,	BC-0001	260.00 sqft	0.96	-	0.89	-	-	1.84	480
41	metal pipe)									
	4" Spray Piping A53 Threaded Field Run w/ 60 Nozzles		248.00 lf	167.13		122.34			289.47	71,789
40360 16" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.	Pipe Plain End-Stainless 316/316L-Seamless-Sch 10S	A201005160	33.00 lf	-	-	85.23	-	-	85.23	2,813
20	16 Inch (400mm)	0S								




Estimate Detail Report

7/20/2021 8:09 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 16" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.	Fitting Butt Weld-Stainless 316/316L-ElI90-Sch 10S 16 20	A20211216000	4.00 ea	-	-	356.78	-	-	356.78	1,427
40-05-23.	Fitting Butt Weld-Stainless 316/316L-Tee-Sch 10S 16 20	A20211416000	1.00 ea	-	-	1,322.76	-	-	1,322.76	1,323
40-05-23.	Fitting Flanged & Bolted-Stainless 316/316L-Flange 20	A202421176200	13.00 ea	-	-	471.75	-	-	471.75	6,133
40-05-23.	Fitting Flanged & Bolted-Stainless 316/316L-Flange 20	A202424006200	1.00 ea	-	-	588.85	-	-	588.85	589
40-05-23.	Shop Butt Weld-Stainless 316/316L-Sch 10S 16 20	L20310216000	24.00 ea	-	-	24.39	-	-	24.39	585
40-05-23.	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 16 20	L2040021600P2	33.00 lf	42.63	-	-	-	-	42.63	1,407
40-05-23.	Field Butt Weld-Stainless 316/316L-Sch 10S 16 20	L20510216000	2.00 ea	309.52	60.42	1.16	-	-	371.10	742
40-05-05.	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 16 Inch (400mm)	A203400006200	8.00 ea	97.16	-	248.14	-	-	345.30	2,762
40-05-07.	Hilti-Chemical Anchor - Pipe Support Size 16 Inch (400mm)	A206043000000	1.00 ea	48.58	-	49.56	-	-	98.14	98
40-05-05.	Field Testing-Hydrotest-Non-Specific 16 Inch (400mm)	L209048000000	33.00 lf	23.32	-	-	-	-	23.32	769
40-05-05.	Pipe Erection-Handle Pipe-Construction Equipment 00	XL609064009000	12.00 mh	82.48	44.17	-	-	-	126.65	1,520
	16" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves		33.00 lf	139.72	19.72	451.71	-	-	611.15	20,168
40360 14" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.	Pipe Plain End-Stainless 316/316L-Seamless-Sch 10S 20	A1910051600S	20.00 lf	-	-	66.19	-	-	66.19	1,324
40-05-23.	Fitting Butt Weld-Stainless 316/316L-ElI45-Sch 10S 14 20	A19211116000	2.00 ea	-	-	184.67	-	-	184.67	369
40-05-23.	Fitting Butt Weld-Stainless 316/316L-Reducer 1 Dia-Sch 10S 14 20	A19211616000	1.00 ea	-	-	288.55	-	-	288.55	289
40-05-23.	Fitting Butt Weld-Stainless 316/316L-Tee-Sch 10S 14 20	A19211416000	1.00 ea	-	-	892.10	-	-	892.10	892
40-05-23.	Fitting Flanged & Bolted-Stainless 316/316L-Flange 20	A192421176200	14.00 ea	-	-	330.06	-	-	330.06	4,621
40-05-23.	Shop Butt Weld-Stainless 316/316L-Sch 10S 14 20	L19310216000	22.00 ea	-	-	21.71	-	-	21.71	478



Estimate Detail Report


7/20/2021 8:09 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 14" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-64.00	Valve Flanged & Bolted-Stainless Steel-Butterfly-Cls 150 (PN20) 14 Inch (350mm)	A196434206200	1.00 ea	-	-	1,502.24	-	-	1,502.24	1,502
40-05-51.00	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 14 Inch (350mm)	L194062006200	1.00 ea	320.04	-	-	-	-	320.04	320
40-05-23.20	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 14 Inch (350mm)	L1940021600P2	20.00 lf	37.16	-	-	-	-	37.16	743
40-05-23.20	Field Butt Weld-Stainless 316/316L-Sch 10S 14 Inch (350mm)	L195102160000	1.00 ea	275.51	53.78	1.02	-	-	330.31	330
40-05-05.00	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 14 Inch (350mm)	A193400006200	9.00 ea	97.16	-	186.95	-	-	284.11	2,557
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size 14 Inch (350mm)	A196043000000	1.00 ea	29.15	-	38.55	-	-	67.70	68
40-05-05.00	Field Testing-Hydrotest-Non-Specific 14 Inch (350mm)	L199048000000	20.00 lf	18.07	-	-	-	-	18.07	361
40-05-57.23	Valves-Accessories-Motor Operator-14 Inch (350mm)	A196046000000	1.00 ea	-	-	13,562.83	-	-	13,562.83	13,563
27-20-52.00	FE - Flow Meter - Install, Calibrate, Test, Loop Check	BC-0010	1.00 ea	635.01	-	250.00	-	-	885.01	885
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	10.00 mh	82.48	44.17	-	-	-	126.65	1,267
	14" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves		20.00 lf	203.18	24.78	1,250.46	-	-	1,478.42	29,568

40360 8" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.20	Pipe Plain End-Stainless 316/316L-Seamless-Sch 10S 8 Inch (200mm)	A1610051600S	80.00 lf	-	-	26.65	-	-	26.65	2,132
40-05-23.20	Fitting Butt Weld-Stainless 316/316L-ElI90-Sch 10S 8 Inch (200mm)	A162112160000	3.00 ea	-	-	55.70	-	-	55.70	167
40-05-23.20	Fitting Flanged & Bolted-Stainless 316/316L-Flange WN-Cls 150-Sch 40S/Std 8 Inch (200mm)	A162421176200	5.00 ea	-	-	99.12	-	-	99.12	496
40-05-23.20	Shop Butt Weld-Stainless 316/316L-Sch 10S 8 Inch (200mm)	L163102160000	11.00 ea	-	-	12.20	-	-	12.20	134
40-05-64.00	Valve Flanged & Bolted-Stainless Steel-Butterfly-Cls 150 (PN20) 8 Inch (200mm)	A166434206200	2.00 ea	-	-	595.95	-	-	595.95	1,192
40-05-51.00	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 8 Inch (200mm)	L164062006200	2.00 ea	180.72	-	-	-	-	180.72	361
40-05-23.20	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 8 Inch (200mm)	L1640021600P2	80.00 lf	17.49	-	-	-	-	17.49	1,399




Estimate Detail Report

7/20/2021 8:09 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 8" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.	Field Butt Weld-Stainless 316/316L-Sch 10S 8 Inch (200mm)	L165102160000	4.00 ea	154.76	30.21	0.47	-	-	185.44	742
40-05-05.	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 8 Inch (200mm)	A163400006200	5.00 ea	48.58	-	57.60	-	-	106.18	531
40-05-07.	Pipe Support 8 Inch (200mm)	A166044000000	4.00 ea	97.16	-	27.54	-	-	124.69	499
40-05-07.	Hilti-Chemical Anchor - Pipe Support Size 8 Inch (200mm)	A166043000000	8.00 ea	29.15	-	27.54	-	-	56.68	453
40-05-05.	Field Testing-Hydrotest-Non-Specific 8 Inch (200mm)	L169048000000	80.00 lf	7.48	-	-	-	-	7.48	598
22-20-03.	Pipe coupling, sleeve-type, Dresser style, 8"	BC-0216	2.00 ea	325.29	-	1,500.00	-	-	1,825.29	3,651
40-05-05.	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	16.00 mh	82.48	44.17	-	-	-	126.65	2,026
	8" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves		80.00 lf	72.66	10.34	96.76	-	-	179.77	14,381
40360 8" AA Manifold Piping SS316 Butt Welded - Install Only										
40-05-23.	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 8 Inch (200mm)	L1640021600P2	60.00 lf	17.49	-	-	-	-	17.49	1,049
40-05-23.	Field Butt Weld-Stainless 316/316L-Sch 10S 8 Inch (200mm)	L165102160000	3.00 ea	154.76	30.21	0.47	-	-	185.44	556
40-05-05.	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 8 Inch (200mm)	A163400006200	8.00 ea	48.58	-	57.60	-	-	106.18	849
40-05-07.	Pipe Support 8 Inch (200mm)	A166044000000	4.00 ea	97.16	-	27.54	-	-	124.69	499
40-05-07.	Hilti-Chemical Anchor - Pipe Support Size 8 Inch (200mm)	A166043000000	8.00 ea	29.15	-	27.54	-	-	56.68	453
40-05-05.	Field Testing-Hydrotest-Non-Specific 8 Inch (200mm)	L169048000000	60.00 lf	7.48	-	-	-	-	7.48	449
40-05-05.	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	8.00 mh	82.48	44.17	-	-	-	126.65	1,013
	8" AA Manifold Piping SS316 Butt Welded - Install Only		60.00 lf	60.55	7.40	13.21	-	-	81.16	4,869
40360 4" Purge Piping SS316 Butt Welded - Install Only										
40-05-23.	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L1340021600P2	46.00 lf	15.30	-	-	-	-	15.30	704



Estimate Detail Report

7/20/2021 8:09 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 4" Purge Piping SS316 Butt Welded - Install Only										
40-05-23.00	Field Butt Weld-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L135102160000	4.00 ea	106.18	20.73	0.19	-	-	127.10	508
40-05-07.00	Pipe Support 4 Inch (100mm)	A136044000000	8.00 ea	97.16	-	16.52	-	-	113.68	909
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size 4 Inch (100mm)	A136043000000	16.00 ea	19.43	-	22.03	-	-	41.46	663
40-05-05.00	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L139048000000	46.00 lf	2.72	-	-	-	-	2.72	125
	4" Purge Piping SS316 Butt Welded - Install Only		46.00 lf	50.91	1.80	10.55			63.27	2,910
46999 Fine Bubble Diffusers - 924 ea.										
46-06-00.00	Diffusers, fine bubble, includes 4" PVC laterals	BC-0046	924.00 ea	17.45	-	65.20	-	-	82.65	76,372
	Fine Bubble Diffusers - 924 ea.		924.00 ea	17.45		65.20			82.65	76,372
46999 Install Weir Gates - 4 ea.										
46-06-08.00	Hydraulic structures, weir gate, 24"x36" aluminum frame and slide, stainless fasteners, self contained, geared handwheel lift	BC-0146	4.00 ea	1,622.63	589.05	4,500.00	-	-	6,711.68	26,847
	Install Weir Gates - 4 ea.		0.00							26,847
04 Process Mechanical										246,905
05 Electrical and Instrumentation										
26999 Connect Valve Motor Operator										
26-99-99.99	Connect valve motor operator	MISC	1.00 ea	2,405.33	-	4,500.00	-	-	6,905.33	6,905
	Connect Valve Motor Operator		0.00							6,905
26999 New Wiring in Tank 4										
26-99-99.99	Misc. Electrical Work - new wiring to Tank 4	MISC	1.00 LS	-	-	-	25,000.00	-	25,000.00	25,000
	New Wiring in Tank 4		0.00							25,000
27999 DO Probes										



Estimate Detail Report

7/20/2021 8:09 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
27999 DO Probes										
27-20-57.00	DO - Dissolved Oxygen - Install, Calibrate, Test, Loop Check	BC-0006	2.00 ea	769.71	-	3,800.00	-	-	4,569.71	9,139
26-99-99.99	Conduit and wire for DO probes	MISC	2.00 ea	5.35	-	3,500.00	-	-	3,505.35	7,011
	DO Probes		0.00							16,150
05 Electrical and Instrumentation										48,055
01 Alternative 1										303,899
01 TOTALS										303,899



Estimate Detail Report

7/20/2021 8:09 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 1

Estimate Totals

Description	Rate	Hours	Amount	Totals
Labor		1,022 hrs	96,708	
Material			176,618	
Subcontract			25,000	
Equipment		177 hrs	5,572	
Other				
			303,898	303,898
Labor Mark-up	15.00 %		14,506	
Material Mark-up	10.00 %		17,662	
Subcontractor Mark-up	10.00 %		2,500	
Construction Equipment Mark-up	10.00 %		557	
Other - Process Equip Mark-up	8.00 %			
			35,225	339,123
Material Shipping & Handling	2.00 %		3,532	
Material Sales Tax	8.75 %		15,454	
Other - Process Eqp Sales Tax	8.75 %			
Net Markups			18,986	358,109
Contractor General Conditions	15.00 %		53,717	
			53,717	411,826
Start-Up, Training, O&M	2.00 %		8,237	
			8,237	420,063
Undesign/Undevelop Contingency	30.00 %		126,019	
			126,019	546,082
Bldg Risk, Liability Auto Ins	2.00 %		10,922	
			10,922	557,004
Payment and Performance Bonds	1.50 %		8,355	
			8,355	565,359
Escalation to Midpoint (ALL)				
Gross Markups				565,359
Total				565,359



Estimate Summary Report

7/20/2021 8:15 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

SEWER AUTHORITY MID-COASTSIDE WWTP CAPACITY STUDY - ALTERNATE 2 CLASS 5 ESTIMATE - PLANNING LEVEL

Estimator	Steve Payne
BC Project Manager	Mike Harrison
BC Office	Sacramento
Est Version Number	1
QA/QC Reviewer	Bill Agster
QA/QC Review Date	06/29/21
BC Project Number	156642



Estimate Summary Report

7/20/2021 8:15 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

Phase	Description	Gross Total Cost with Markups
01 ALTERNATE 2		
02 Basins 1 & 2		
01 Demolition		102,237
03 Structural		139,952
04 Process Mechanical		360,517
05 Electrical and Instrumentation		55,512
02 Basins 1 & 2		658,218
<hr/>		
01 ALTERNATE 2		658,218



Estimate Detail Report


7/20/2021 8:16 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

SEWER AUTHORITY MID-COASTSIDE WWTP CAPACITY STUDY - ALTERNATE 2 CLASS 5 ESTIMATE - PLANNING LEVEL

Estimator	Steve Payne
BC Project Manager	Mike Harrison
BC Office	Sacramento
Est Version Number	1
QA/QC Reviewer	Bill Agster
QA/QC Review Date	06/29/21
BC Project Number	156642




Estimate Detail Report

7/20/2021 8:16 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
01 ALTERNATE 2										
02 Basins 1 & 2										
01 Demolition										
02301 Pipe Demolition - 4" Drop Legs and Headers										
22-05-05.	Pipe, metal pipe, 4" to 6" diam., selective demolition	2100	156.00 lf	21.22	-	-	-	-	21.22	3,311
10										
40-05-05.	Pipe Erection-Handle Pipe-Construction Equipment	XL60906400 9000	25.00 mh	109.78	58.79	-	-	-	168.58	4,214
00										
02-41-19.	Selective demolition, rubbish handling, dumpster, 20 c.y., 5 ton capacity, weekly rental, includes one dump per week, cost be added to demolition cost	0725	1.00 week	-	-	562.74	-	-	562.74	563
19										
	Pipe Demolition - 4" Drop Legs and Headers		156.00 ft	38.82	9.42	3.61			51.85	8,088
02301 _Pipe Demolition for New Motorized BFV										
22-05-05.	Pipe, metal pipe, 8" to 14" diam., selective demolition	2150	4.00 lf	35.38	-	-	-	-	35.38	142
10										
	_Pipe Demolition for New Motorized BFV		4.00 ft	35.38					35.38	142
02999 Demo Weir Gates										
02-22-04.	Site demolition, 48" weir gate	BC-0056	4.00 ea	1,352.98	-	-	-	-	1,352.98	5,412
50										
	Demo Weir Gates		0.00							5,412
02999 Pressure Wash Basins 1 & 2										
04-01-30.	High pressure wash, average soil, biological staining, water only, excludes scaffolding	0420	4,520.00 sf	1.54	0.26	-	-	-	1.80	8,157
20										
	Pressure Wash Basins 1 & 2		0.00							8,157
02999 Demo Diffusers										
02-22-04.	Equipment dismantling/demolition, aeration diffusers, complete, Includes laterals	BC-0231	1,300.00 ea	14.63	-	-	-	-	14.63	19,015
52										
02-41-19.	Selective demolition, rubbish handling, dumpster, 20 c.y., 5 ton capacity, weekly rental, includes one dump per week, cost be added to demolition cost	0725	3.00 week	-	-	562.74	-	-	562.74	1,688
19										
40-05-05.	Pipe Erection-Handle Pipe-Construction Equipment	XL60906400 9000	80.00 mh	109.78	58.79	-	-	-	168.58	13,486
00										



Estimate Detail Report

7/20/2021 8:16 PM


BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
Demo Diffusers			0.00							34,189
01 Demolition										55,988
03 Structural										
03345 _Concrete Baffle Walls										
03-11-13.	C.I.P. concrete forms, wall, job built, plywood, over 16' high, 1 use, includes erecting, bracing, stripping and cleaning	2700	1,479.00 sfca	26.60	-	4.22	-	-	30.82	45,577
03-11-13.	C.I.P. concrete forms, wall, box out for opening, to 16" thick, over 10 S.F. (use perimeter), includes erecting, bracing, stripping and cleaning	0150	64.00 lf	22.32	-	3.73	-	-	26.05	1,667
03-15-05.	Form oil, up to 800 S.F. per gallon, coverage, includes material only	3050	3.94 gal	-	-	21.91	-	-	21.91	86
03-21-10.	Reinforcing steel, in place, walls, #3 to #7, A615, grade 60, incl labor for accessories, excl material for accessories	0700	2.95 ton	1,453.35	-	1,041.25	-	-	2,494.60	7,354
03-21-10.	Reinforcing in place, unloading & sorting, add - walls, cols, beams	2010	2.95 ton	73.05	8.01	-	-	-	81.06	239
03-21-10.	Reinforcing, crane cost for handling, add to above, walls, cols, beams	2225	2.95 ton	79.40	8.70	-	-	-	88.10	260
03-31-05.	Structural concrete,ready mix,normal weight,4500 psi,includes local aggregate,sand,portland cement and water,excludes all additives and treatments	0350	41.27 cy	-	-	118.24	-	-	118.24	4,880
03-31-05.	Structural concrete, placing, walls, pumped, 15" thick, includes vibrating, excludes material	5350	41.27 cy	53.78	5.41	-	-	-	59.19	2,443
03-35-29.	Finishing: break ties & patch voids (walls, cols or beams)	0010	1,415.00 sf	1.60	-	0.04	-	-	1.64	2,320
03-82-16.	Concrete impact drilling, for anchors, 8" d, 3/4" dia, in concrete or brick walls and floors, includes bit cost, layout and set up time, excl anchor	0500	112.00 ea	42.71	-	0.22	-	-	42.93	4,808
03-63-05.	Chemical anchoring, for rebar dowel, #5 in 3/4" diam hole, 8" embed, incl epoxy cartridge, excl layout, drilling & rebar	BC-0111	112.00 ea	27.45	-	10.82	-	-	38.27	4,286
03-21-11.	Reinforcing steel, in place, dowels, deformed, 2' long, #5, A615, grade 60	2420	112.00 ea	5.01	-	1.18	-	-	6.19	694
03-35-29.	Concrete finishing, walls, bush hammer, cured concrete	0350	168.00 sf	7.34	0.74	-	-	-	8.09	1,359
_Concrete Baffle Walls			39.31 cy	1,517.34	10.11	405.40			1,932.86	75,973

03 Structural

75,973




Estimate Detail Report

7/20/2021 8:16 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
04 Process Mechanical										
40360 4" AA Drop Leg Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.00	Pipe Plain End-Stainless 316/316L-Seamless-Sch 10S 20 Inch (100mm)	A1310051600S	80.00 lf	-	-	11.28	-	-	11.28	902
40-05-23.00	Fitting Butt Weld-Stainless 316/316L-ElI90-Sch 10S 20 Inch (100mm)	A13211216000	4.00 ea	-	-	46.18	-	-	46.18	185
40-05-23.00	Fitting Flanged & Bolted-Stainless 316/316L-Flange WN-Cls 150-Sch 40S/Std 4 Inch (100mm)	A13242117600	8.00 ea	-	-	40.04	-	-	40.04	320
40-05-23.00	Shop Butt Weld-Stainless 316/316L-Sch 10S 20 (100mm)	L13310216000	16.00 ea	-	-	8.45	-	-	8.45	135
40-05-64.00	Valve Flanged & Bolted-Stainless Steel-Butterfly-Cls 150 (PN20) 4 Inch (100mm)	A13643420600	4.00 ea	-	-	227.14	-	-	227.14	909
40-05-51.00	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 4 Inch (100mm)	L13406200600	4.00 ea	139.66	-	-	-	-	139.66	559
40-05-23.00	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 20 Inch (100mm)	L1340021600P2	80.00 lf	20.37	-	-	-	-	20.37	1,629
40-05-23.00	Field Butt Weld-Stainless 316/316L-Sch 10S 20 (100mm)	L13510216000	4.00 ea	141.33	27.59	0.20	-	-	169.11	676
40-05-05.00	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 4 Inch (100mm)	A13340000600	8.00 ea	51.73	-	29.59	-	-	81.31	651
40-05-07.00	Pipe Support 4 Inch (100mm)	A13604400000	8.00 ea	129.32	-	16.69	-	-	146.00	1,168
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size 4 Inch (100mm)	A13604300000	16.00 ea	25.86	-	22.25	-	-	48.11	770
40-05-05.00	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L13904800000	80.00 lf	3.62	-	-	-	-	3.62	290
22-20-03.00	Pipe coupling, sleeve-type, Dresser style, 4"	BC-0211	4.00 ea	193.14	-	494.11	-	-	687.25	2,749
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	16.00 mh	109.78	58.79	-	-	-	168.58	2,697
	4" AA Drop Leg Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves		80.00 lf	92.93	13.14	64.43			170.49	13,639
40360 4" AA Manifold Piping SS316 Butt Welded - Install Only										
40-05-23.00	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 20 Inch (100mm)	L1340021600P2	76.00 lf	20.37	-	-	-	-	20.37	1,548
40-05-23.00	Field Butt Weld-Stainless 316/316L-Sch 10S 20 (100mm)	L13510216000	4.00 ea	141.33	27.59	0.20	-	-	169.11	676



Estimate Detail Report

7/20/2021 8:16 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 4" AA Manifold Piping SS316 Butt Welded - Install Only										
40-05-07.00	Pipe Support 4 Inch (100mm)	A136044000000	16.00 ea	129.32	-	16.69	-	-	146.00	2,336
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size (100mm) 4 Inch	A136043000000	32.00 ea	25.86	-	22.25	-	-	48.11	1,540
40-05-05.00	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L139048000000	76.00 lf	3.62	-	-	-	-	3.62	275
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	12.00 mh	109.78	58.79	-	-	-	168.58	2,023
	4" AA Manifold Piping SS316 Butt Welded - Install Only		76.00 lf	86.88	10.74	12.89			110.50	8,398
40360 4" Purge Piping SS316 Butt Welded - Install Only										
40-05-23.20	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L1340021600P2	46.00 lf	20.37	-	-	-	-	20.37	937
40-05-23.20	Field Butt Weld-Stainless 316/316L-Sch 10S (100mm) 4 Inch	L135102160000	4.00 ea	141.33	27.59	0.20	-	-	169.11	676
40-05-07.00	Pipe Support 4 Inch (100mm)	A136044000000	8.00 ea	129.32	-	16.69	-	-	146.00	1,168
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size (100mm) 4 Inch	A136043000000	16.00 ea	25.86	-	22.25	-	-	48.11	770
40-05-05.00	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L139048000000	46.00 lf	3.62	-	-	-	-	3.62	167
	4" Purge Piping SS316 Butt Welded - Install Only		46.00 lf	67.76	2.40	10.66			80.82	3,718
40360 8" AA Piping SS316 - Motor Operated BFV anf Air Flow Meter - 2 ea.										
40-05-23.20	Fitting Flanged & Bolted-Stainless 316/316L-Flange WN-Cls 150-Sch 40S/Std 8 Inch (200mm)	A162421176200	4.00 ea	-	-	99.12	-	-	99.12	396
40-05-64.00	Valve Flanged & Bolted-Stainless Steel-Butterfly-Cls (PN20) 8 Inch (200mm)	A166434206200	2.00 ea	-	-	595.95	-	-	595.95	1,192
40-05-51.00	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 8 Inch (200mm)	L164062006200	2.00 ea	180.72	-	-	-	-	180.72	361
40-05-23.20	Field Butt Weld-Stainless 316/316L-Sch 10S (200mm) 8 Inch	L165102160000	4.00 ea	154.76	30.21	0.47	-	-	185.44	742
40-05-05.00	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 8 Inch (200mm)	A163400006200	4.00 ea	48.58	-	57.61	-	-	106.19	425
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	8.00 mh	82.48	44.17	-	-	-	126.65	1,013



Estimate Detail Report

7/20/2021 8:16 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 8" AA Piping SS316 - Motor Operated BFV anf Air Flow Meter - 2 ea.										
27-20-52.00	FE - (Pilot Tube) Flow Element - Install, Calibrate, Test, Loop Check	BC-0010	2.00 ea	772.17	-	238.25	-	-	1,010.42	2,021
40-05-57.23	Valves-Accessories-Motor Operator-8 Inch (200mm)	A166046000	2.00 ea	-	-	8,137.70	-	-	8,137.70	16,275
	8" AA Piping SS316 - Motor Operated BFV anf Air Flow Meter - 2 ea.		80.00 lf	42.24	5.93	232.16	-	-	280.32	22,426
46999 Fine Bubble Diffusers - 1,300 ea.										
46-06-00.00	Diffusers, fine bubble, complete, includes PVC laterals	BC-0046	1,300.00 ea	23.23	-	65.20	-	-	88.43	114,960
	Fine Bubble Diffusers - 1,300 ea.		1,564.00 ea	19.31	-	54.19	-	-	73.50	114,960
46999 Install Weir Gates - 4 ea.										
46-06-08.00	Hydraulic structures, weir gate, 24"x36" aluminum frame and slide, stainless fasteners, self contained, geared handwheel lift	BC-0146	4.00 ea	2,159.71	784.03	4,545.00	-	-	7,488.74	29,955
	Install Weir Gates - 4 ea.		0.00	-	-	-	-	-	-	29,955
04 Process Mechanical										193,096
05 Electrical and Instrumentation										
26999 Connect Valve Motor Operator										
26-99-99.99	Connect valve motor operator	MISC	2.00 ea	2,405.33	-	4,500.00	-	-	6,905.33	13,811
	Connect Valve Motor Operator		0.00	-	-	-	-	-	-	13,811
27999 DO Probes										
27-20-57.00	DO - Dissolved Oxygen - Install, Calibrate, Test, Loop Check	BC-0006	2.00 ea	935.96	-	3,621.40	-	-	4,557.36	9,115
26-99-99.99	Conduit and wire for DO probes	MISC	2.00 ea	6.50	-	3,335.50	-	-	3,342.00	6,684
	DO Probes		0.00	-	-	-	-	-	-	15,799
05 Electrical and Instrumentation										29,609
02 Basins 1 & 2										354,666



Estimate Detail Report

7/20/2021 8:16 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
<hr/>										
01	ALTERNATE 2									354,666



Estimate Detail Report

7/20/2021 8:16 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATE 2

Estimate Totals

Description	Rate	Hours	Amount	Totals
Labor		1,405 hrs	172,075	
Material			169,236	
Subcontract				
Equipment		292 hrs	13,355	
Other				
			354,666	354,666
Labor Mark-up	15.00 %		25,811	
Material Mark-up	10.00 %		16,924	
Subcontractor Mark-up	10.00 %			
Construction Equipment Mark-up	10.00 %		1,336	
Other - Process Equip Mark-up	8.00 %			
			44,071	398,737
Material Shipping & Handling	2.00 %		3,385	
Material Sales Tax	8.75 %		14,808	
Other - Process Eqp Sales Tax	8.75 %			
Net Markups			18,193	416,930
Contractor General Conditions	15.00 %		62,539	
			62,539	479,469
Start-Up, Training, O&M	2.00 %		9,589	
			9,589	489,058
Undesign/Undevelop Contingency	30.00 %		146,717	
			146,717	635,775
Bldg Risk, Liability Auto Ins	2.00 %		12,716	
			12,716	648,491
Payment and Performance Bonds	1.50 %		9,727	
			9,727	658,218
Escalation to Midpoint (ALL)				
Gross Markups				658,218
Total				658,218



Estimate Summary Report

7/21/2021 9:07 AM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

SEWER AUTHORITY MID-COASTSIDE WWTP CAPACITY STUDY - ALTERNATIVE 3 CLASS 5 ESTIMATE - PLANNING LEVEL

Estimator	Steve Payne
BC Project Manager	Mike Harrison
BC Office	Sacramento
Est Version Number	1
QA/QC Reviewer	Bill Agster
QA/QC Review Date	06/29/21
BC Project Number	156642



Estimate Summary Report

7/21/2021 9:07 AM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Gross Total Cost with Markups
01 ALTERNATE 3		
01 Basin 4		
01 Demolition		8,883
04 Process Mechanical		410,730
05 Electrical and Instrumentation		87,807
01 Basin 4		507,421
02 Basins 1 & 2		
01 Demolition		116,541
03 Structural		89,892
04 Process Mechanical		277,709
05 Electrical and Instrumentation		59,620
02 Basins 1 & 2		543,762
01 ALTERNATE 3		1,051,183



Estimate Detail Report


7/21/2021 9:08 AM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

SEWER AUTHORITY MID-COASTSIDE WWTP CAPACITY STUDY - ALTERNATIVE 3 CLASS 5 ESTIMATE - PLANNING LEVEL

Estimator	Steve Payne
BC Project Manager	Mike Harrison
BC Office	Sacramento
Est Version Number	1
QA/QC Reviewer	Bill Agster
QA/QC Review Date	06/29/21
BC Project Number	156642




Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
01 ALTERNATE 3										
01 Basin 4										
01 Demolition										
02999 Pressure Wash Basin 4										
04-01-30.	Cleaning masonry, high pressure wash, average soil,	0420	2,700.00 sf	1.54	0.26	-	-	-	1.80	4,873
20	biological staining, water only, excludes scaffolding									
	Pressure Wash Basin 4		0.00							4,873
	01 Demolition									4,873
04 Process Mechanical										
22112 4" Spray Piping A53 Threaded Field Run w/ 60 Nozzles										
22-11-13.	Pipe, steel, black, threaded, 4" diameter, schedule 40,	0650	248.00 lf	41.63	-	28.00	-	-	69.63	17,267
44	Spec. A-53, includes coupling and clevis hanger assembly sized for covering, 10' OC									
22-11-13.	Elbow, 90 Deg., steel, cast iron, black, straight, threaded,	0180	4.00 ea	249.76	-	221.00	-	-	470.76	1,883
45	standard weight, 4"									
22-11-13.	Tee, steel, cast iron, black, straight, threaded, standard	0620	61.00 ea	374.64	-	335.00	-	-	709.64	43,288
45	weight, 4"									
22-11-19.	Sleeve, pipe, steel with water stop, 12" long, 6" diam. for	0200	1.00 ea	169.42	-	142.00	-	-	311.42	311
34	4" carrier pipe, includes link seal									
22-20-02.	High impact, flat spray nozzle, 2 gpm@40 psi, 35 deg spray	BC-0001	60.00 ea	103.02	-	28.39	-	-	131.41	7,885
95	angle, ball jt									
40-05-05.	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L139048000	248.00 lf	2.72	-	-	-	-	2.72	675
00		000								
09-91-06.	Coatings & paints, B & C coating system E-1 (Epoxy,	BC-0001	260.00 sqft	0.96	-	0.89	-	-	1.84	480
41	metal pipe)									
	4" Spray Piping A53 Threaded Field Run w/ 60 Nozzles		248.00 lf	167.13		122.34			289.47	71,789
40360 16" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.	Pipe Plain End-Stainless 316/316L-Seamless-Sch 10S	A201005160	33.00 lf	-	-	85.23	-	-	85.23	2,813
20	16 Inch (400mm)	0S								
40-05-23.	Fitting Butt Weld-Stainless 316/316L-El90-Sch 10S	A202112160	4.00 ea	-	-	356.78	-	-	356.78	1,427
20	16 Inch (400mm)	000								
40-05-23.	Fitting Butt Weld-Stainless 316/316L-Tee-Sch 10S	A202114160	1.00 ea	-	-	1,322.76	-	-	1,322.76	1,323
20	16 Inch (400mm)	000								




Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 16" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.	Fitting Flanged & Bolted-Stainless 316/316L-Flange	A202421176	13.00 ea	-	-	471.75	-	-	471.75	6,133
20	WN-Cls 150-Sch 40S 16 Inch (400mm)	200								
40-05-23.	Fitting Flanged & Bolted-Stainless 316/316L-Flange	A202424006	1.00 ea	-	-	588.85	-	-	588.85	589
20	Blind-Cls 150 16 Inch (400mm)	200								
40-05-23.	Shop Butt Weld-Stainless 316/316L-Sch 10S 16 Inch	L203102160	24.00 ea	-	-	24.39	-	-	24.39	585
20	(400mm)	000								
40-05-23.	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 16	L204002160	33.00 lf	42.63	-	-	-	-	42.63	1,407
20	Inch (400mm)	0P2								
40-05-23.	Field Butt Weld-Stainless 316/316L-Sch 10S 16 Inch	L205102160	2.00 ea	309.52	60.42	1.16	-	-	371.10	742
20	(400mm)	000								
40-05-05.	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch	A203400006	8.00 ea	97.16	-	248.14	-	-	345.30	2,762
00	Rubber Gasket-Cls 150 (PN20) 16 Inch (400mm)	200								
40-05-07.	Hilti-Chemical Anchor - Pipe Support Size 16 Inch	A206043000	1.00 ea	48.58	-	49.56	-	-	98.14	98
00	(400mm)	000								
40-05-05.	Field Testing-Hydrotest-Non-Specific 16 Inch (400mm)	L209048000	33.00 lf	23.32	-	-	-	-	23.32	769
00		000								
40-05-05.	Pipe Erection-Handle Pipe-Construction Equipment	XL60906400	12.00 mh	82.48	44.17	-	-	-	126.65	1,520
00		9000								
	16" AA Piping SS316 Butt Welded Shop		33.00 lf	139.72	19.72	451.71			611.15	20,168
	Fab Piping w/ Flanges & Valves									
40360 14" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.	Pipe Plain End-Stainless 316/316L-Seamless-Sch 10S	A191005160	20.00 lf	-	-	66.19	-	-	66.19	1,324
20	14 Inch (350mm)	0S								
40-05-23.	Fitting Butt Weld-Stainless 316/316L-ElI45-Sch 10S 14	A192111160	2.00 ea	-	-	184.67	-	-	184.67	369
20	Inch (350mm)	000								
40-05-23.	Fitting Butt Weld-Stainless 316/316L-Reducer 1 Dia-Sch	A192116160	1.00 ea	-	-	288.55	-	-	288.55	289
20	10S 14 Inch (350mm)	000								
40-05-23.	Fitting Butt Weld-Stainless 316/316L-Tee-Sch 10S 14	A192114160	1.00 ea	-	-	892.10	-	-	892.10	892
20	Inch (350mm)	000								
40-05-23.	Fitting Flanged & Bolted-Stainless 316/316L-Flange	A192421176	14.00 ea	-	-	330.06	-	-	330.06	4,621
20	WN-Cls 150-Sch 40S 14 Inch (350mm)	200								
40-05-23.	Shop Butt Weld-Stainless 316/316L-Sch 10S 14 Inch	L193102160	22.00 ea	-	-	21.71	-	-	21.71	478
20	(350mm)	000								
40-05-64.	Valve Flanged & Bolted-Stainless Steel-Butterfly-Cls 150	A196434206	1.00 ea	-	-	1,502.24	-	-	1,502.24	1,502
00	(PN20) 14 Inch (350mm)	200								
40-05-51.	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 14	L194062006	1.00 ea	320.04	-	-	-	-	320.04	320
00	Inch (350mm)	200								



Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 14" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 14	L194002160	20.00 lf	37.16	-	-	-	-	37.16	743
20	Inch (350mm)	OP2								
40-05-23.	Field Butt Weld-Stainless 316/316L-Sch 10S 14 Inch	L195102160	1.00 ea	275.51	53.78	1.02	-	-	330.31	330
20	(350mm)	000								
40-05-05.	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch	A193400006	9.00 ea	97.16	-	186.95	-	-	284.11	2,557
00	Rubber Gasket-Cls 150 (PN20) 14 Inch (350mm)	200								
40-05-07.	Hilti-Chemical Anchor - Pipe Support Size 14 Inch	A196043000	1.00 ea	29.15	-	38.55	-	-	67.70	68
00	(350mm)	000								
40-05-05.	Field Testing-Hydrotest-Non-Specific 14 Inch (350mm)	L199048000	20.00 lf	18.07	-	-	-	-	18.07	361
00		000								
40-05-57.	Valves-Accessories-Motor Operator-14 Inch (350mm)	A196046000	1.00 ea	-	-	13,562.83	-	-	13,562.83	13,563
23		000								
27-20-52.	FE - (Pilot Tube) Flow Element - Install, Calibrate, Test,	BC-0010	1.00 ea	635.01	-	250.00	-	-	885.01	885
00	Loop Check									
40-05-05.	Pipe Erection-Handle Pipe-Construction Equipment	XL60906400	10.00 mh	82.48	44.17	-	-	-	126.65	1,267
00		9000								
	14" AA Piping SS316 Butt Welded Shop		20.00 lf	203.18	24.78	1,250.46			1,478.42	29,568
	Fab Piping w/ Flanges & Valves									
40360 8" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-23.	Pipe Plain End-Stainless 316/316L-Seamless-Sch 10S 8	A161005160	80.00 lf	-	-	26.65	-	-	26.65	2,132
20	Inch (200mm)	OS								
40-05-23.	Fitting Butt Weld-Stainless 316/316L-ElI90-Sch 10S 8	A162112160	3.00 ea	-	-	55.70	-	-	55.70	167
20	Inch (200mm)	000								
40-05-23.	Fitting Flanged & Bolted-Stainless 316/316L-Flange	A162421176	5.00 ea	-	-	99.12	-	-	99.12	496
20	WN-Cls 150-Sch 40S/Std 8 Inch (200mm)	200								
40-05-23.	Shop Butt Weld-Stainless 316/316L-Sch 10S 8 Inch	L163102160	11.00 ea	-	-	12.20	-	-	12.20	134
20	(200mm)	000								
40-05-64.	Valve Flanged & Bolted-Stainless Steel-Butterfly-Cls 150	A166434206	2.00 ea	-	-	595.95	-	-	595.95	1,192
00	(PN20) 8 Inch (200mm)	200								
40-05-51.	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 8	L164062006	2.00 ea	180.72	-	-	-	-	180.72	361
00	Inch (200mm)	200								
40-05-23.	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 8	L164002160	80.00 lf	17.49	-	-	-	-	17.49	1,399
20	Inch (200mm)	OP2								
40-05-23.	Field Butt Weld-Stainless 316/316L-Sch 10S 8 Inch	L165102160	4.00 ea	154.76	30.21	0.47	-	-	185.44	742
20	(200mm)	000								
40-05-05.	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch	A163400006	5.00 ea	48.58	-	57.60	-	-	106.18	531
00	Rubber Gasket-Cls 150 (PN20) 8 Inch (200mm)	200								



Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 8" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves										
40-05-07.00	Pipe Support 8 Inch (200mm)	A166044000000	4.00 ea	97.16	-	27.54	-	-	124.69	499
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size (200mm) 8 Inch	A166043000000	8.00 ea	29.15	-	27.54	-	-	56.68	453
40-05-05.00	Field Testing-Hydrotest-Non-Specific 8 Inch (200mm)	L169048000000	80.00 lf	7.48	-	-	-	-	7.48	598
22-20-03.00	Pipe coupling, sleeve-type, Dresser style, 8"	BC-0216	2.00 ea	325.29	-	1,500.00	-	-	1,825.29	3,651
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	16.00 mh	82.48	44.17	-	-	-	126.65	2,026
	8" AA Piping SS316 Butt Welded Shop Fab Piping w/ Flanges & Valves		80.00 lf	72.66	10.34	96.76			179.77	14,381
40360 8" AA Manifold Piping SS316 Butt Welded - Install Only										
40-05-23.20	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 8 Inch (200mm)	L1640021600P2	60.00 lf	17.49	-	-	-	-	17.49	1,049
40-05-23.20	Field Butt Weld-Stainless 316/316L-Sch 10S (200mm) 8 Inch	L165102160000	3.00 ea	154.76	30.21	0.47	-	-	185.44	556
40-05-05.00	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 8 Inch (200mm)	A163400006200	8.00 ea	48.58	-	57.60	-	-	106.18	849
40-05-07.00	Pipe Support 8 Inch (200mm)	A166044000000	4.00 ea	97.16	-	27.54	-	-	124.69	499
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size (200mm) 8 Inch	A166043000000	8.00 ea	29.15	-	27.54	-	-	56.68	453
40-05-05.00	Field Testing-Hydrotest-Non-Specific 8 Inch (200mm)	L169048000000	60.00 lf	7.48	-	-	-	-	7.48	449
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	8.00 mh	82.48	44.17	-	-	-	126.65	1,013
	8" AA Manifold Piping SS316 Butt Welded - Install Only		60.00 lf	60.55	7.40	13.21			81.16	4,869
40360 4" Purge Piping SS316 Butt Welded - Install Only										
40-05-23.20	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L1340021600P2	46.00 lf	15.30	-	-	-	-	15.30	704
40-05-23.20	Field Butt Weld-Stainless 316/316L-Sch 10S (100mm) 4 Inch	L135102160000	4.00 ea	106.18	20.73	0.19	-	-	127.10	508
40-05-07.00	Pipe Support 4 Inch (100mm)	A136044000000	8.00 ea	97.16	-	16.52	-	-	113.68	909




Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 4" Purge Piping SS316 Butt Welded - Install Only										
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size 4 Inch (100mm)	A136043000000	16.00 ea	19.43	-	22.03	-	-	41.46	663
40-05-05.00	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L139048000000	46.00 lf	2.72	-	-	-	-	2.72	125
	4" Purge Piping SS316 Butt Welded - Install Only		46.00 lf	50.91	1.80	10.55			63.27	2,910
46999 Fine Bubble Diffusers - 924 ea.										
46-06-00.00	Diffusers, fine bubble, includes 4" PVC laterals	BC-0046	924.00 ea	17.45	-	65.23	-	-	82.68	76,397
	Fine Bubble Diffusers - 924 ea.		924.00 ea	17.45		65.23			82.68	76,397
04 Process Mechanical										220,083
05 Electrical and Instrumentation										
26999 Connect Valve Motor Operator										
26-99-99.99	Connect valve motor operator	MISC	1.00 ea	2,405.33	-	4,500.00	-	-	6,905.33	6,905
	Connect Valve Motor Operator		0.00							6,905
26999 New Wiring in Tank 4										
26-99-99.99	Misc. Electrical Work - new wiring to Tank 4	MISC	1.00 LS	-	-	-	25,000.00	-	25,000.00	25,000
	New Wiring in Tank 4		0.00							25,000
27999 DO Probes										
27-20-57.00	DO - Dissolved Oxygen - Install, Calibrate, Test, Loop Check	BC-0006	2.00 ea	769.71	-	3,800.00	-	-	4,569.71	9,139
26-99-99.99	Conduit and wire for DO probes	MISC	2.00 ea	5.35	-	3,500.00	-	-	3,505.35	7,011
	DO Probes		0.00							16,150
05 Electrical and Instrumentation										48,055
01 Basin 4										273,011



Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
02 Basins 1 & 2										
01 Demolition										
02225 Cut and Demo Channel Wall - 3'w x 5.5'h x 8" th										
02-41-19.	Selective demolition, cutout, concrete, walls, bar reinforced, 6-12 C.F., excludes loading and disposal	1450	11.00 cf	41.76	5.18	-	-	-	46.95	516
02-41-19.	Sawcutting, concrete walls, rod reinforcing, per inch of depth	0820	112.00 lf	8.26	10.62	0.05	-	-	18.92	2,119
902-41-19	Rubbish handling, loading & trucking, chute loaded, including 2 mile haul, cost to be added to demolition cost.	0600	0.41 cy	52.70	13.12	-	-	-	65.82	27
902-41-19	Rubbish handling, dumpster, 20 C.Y., 8 ton capacity, weekly rental, includes one dump per week, cost to be added to demolition cost.	2300	1.00 week	-	-	565.00	-	-	565.00	565
Cut and Demo Channel Wall - 3'w x 5.5'h x 8" th			0.00							3,227
02225 Cut Slide Channel for Stop Plates										
02-41-19.	Selective demolition, cutout, concrete, walls, bar reinforced, 6-12 C.F., excludes loading and disposal	1450	11.00 cf	41.76	5.18	-	-	-	46.95	516
02-41-19.	Sawcutting, concrete walls, rod reinforcing, per inch of depth	0820	773.36 lf	8.26	10.62	0.05	-	-	18.92	14,634
902-41-19	Rubbish handling, loading & trucking, chute loaded, including 2 mile haul, cost to be added to demolition cost.	0600	0.41 cy	52.70	13.12	-	-	-	65.82	27
902-41-19	Rubbish handling, dumpster, 20 C.Y., 8 ton capacity, weekly rental, includes one dump per week, cost to be added to demolition cost.	2300	1.00 week	-	-	565.00	-	-	565.00	565
Cut Slide Channel for Stop Plates			0.00							15,742
02301 Pipe Demolition - 4" Drop Legs and Headers										
22-05-05.	Pipe, metal pipe, 4" to 6" diam., selective demolition	2100	156.00 lf	21.22	-	-	-	-	21.22	3,311
40-05-05.	Pipe Erection-Handle Pipe-Construction Equipment	XL60906400 9000	25.00 mh	109.78	58.79	-	-	-	168.58	4,214
02-41-19.	Selective demolition, rubbish handling, dumpster, 20 c.y., 5 ton capacity, weekly rental, includes one dump per week, cost be added to demolition cost	0725	1.00 week	-	-	562.74	-	-	562.74	563
Pipe Demolition - 4" Drop Legs and Headers			156.00 ft	38.82	9.42	3.61			51.85	8,088



Estimate Detail Report


7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
02301 _Pipe Demolition for New Motorized BFV										
22-05-05.10	Pipe, metal pipe, 8" to 14" diam., selective demolition	2150	4.00 lf	35.38	-	-	-	-	35.38	142
	_Pipe Demolition for New Motorized BFV		4.00 ft	35.38					35.38	142
02999 Demo Weir Gates										
02-22-04.50	Site demolition, 48" weir gate	BC-0056	4.00 ea	1,352.98	-	-	-	-	1,352.98	5,412
	Demo Weir Gates		4.00 EA	1,352.98					1,352.98	5,412
02999 Pressure Wash Basin 2 & Channel										
04-01-30.20	High pressure wash, average soil, biological staining, water only, excludes scaffolding	0420	3,250.00 sf	1.54	0.26	-	-	-	1.80	5,865
	Pressure Wash Basin 2 & Channel		1.00 LS	5,004.82	860.56				5,865.38	5,865
02999 Demo Diffusers										
02-22-04.52	Equipment dismantling/demolition, aeration diffusers, complete, Includes laterals	BC-0231	650.00 ea	14.63	-	-	-	-	14.63	9,507
02-41-19.19	Selective demolition, rubbish handling, dumpster, 20 c.y., 5 ton capacity, weekly rental, includes one dump per week, cost be added to demolition cost	0725	3.00 week	-	-	562.74	-	-	562.74	1,688
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	80.00 mh	109.78	58.79	-	-	-	168.58	13,486
	Demo Diffusers		650.00 EA	28.14	7.24	2.60			37.97	24,682
02999 Plug 24" ML Pipe - 2 ea.										
03-31-13.35	Structural concrete, ready mix, flowable fill, structural, 140 psi, includes ash, Portland cement Type I, aggregate, sand and water, delivered, excludes all additives and treatments	4250	0.50 cy	-	-	78.00	-	-	78.00	39
03-92-06.00	Plug pipe, non-shrink grout, 24" hole	BC-0036	2.00 ea	162.54	-	238.74	-	-	401.28	803
	Plug 24" ML Pipe - 2 ea.		2.00 EA	162.54		258.24			420.78	842
01 Demolition										63,999

03 Structural




Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
03345 _Concrete Baffle Wall - Basin 2										
03-11-13.85	C.I.P. concrete forms, wall, job built, plywood, over 16' high, 1 use, includes erecting, bracing, stripping and cleaning	2700	739.50 sfca	26.60	-	4.22	-	-	30.82	22,789
03-11-13.85	C.I.P. concrete forms, wall, box out for opening, to 16" thick, over 10 S.F. (use perimeter), includes erecting, bracing, stripping and cleaning	0150	32.00 lf	22.32	-	3.73	-	-	26.05	834
03-15-05.95	Form oil, up to 800 S.F. per gallon, coverage, includes material only	3050	1.97 gal	-	-	21.91	-	-	21.91	43
03-21-10.60	Reinforcing steel, in place, walls, #3 to #7, A615, grade 60, incl labor for accessories, excl material for accessories	0700	1.47 ton	1,453.35	-	1,041.25	-	-	2,494.59	3,677
03-21-10.60	Reinforcing in place, unloading & sorting, add - walls, cols, beams	2010	1.47 ton	73.05	8.01	-	-	-	81.05	119
03-21-10.60	Reinforcing, crane cost for handling, add to above, walls, cols, beams	2225	1.47 ton	79.40	8.70	-	-	-	88.10	130
03-31-05.35	Structural concrete, ready mix, normal weight, 4500 psi, includes local aggregate, sand, portland cement and water, excludes all additives and treatments	0350	20.64 cy	-	-	118.24	-	-	118.24	2,440
03-31-05.70	Structural concrete, placing, walls, pumped, 15" thick, includes vibrating, excludes material	5350	20.64 cy	53.78	5.41	-	-	-	59.19	1,221
03-35-29.60	Finishing: break ties & patch voids (walls, cols or beams)	0010	707.50 sf	1.60	-	0.04	-	-	1.64	1,160
03-82-16.10	Concrete impact drilling, for anchors, 8" d, 3/4" dia, in concrete or brick walls and floors, includes bit cost, layout and set up time, excl anchor	0500	56.00 ea	42.71	-	0.22	-	-	42.93	2,404
03-63-05.10	Chemical anchoring, for rebar dowel, #5 in 3/4" diam hole, 8" embed, incl epoxy cartridge, excl layout, drilling & rebar	BC-0111	56.00 ea	27.45	-	10.82	-	-	38.27	2,143
03-21-11.60	Reinforcing steel, in place, dowels, deformed, 2' long, #5, A615, grade 60	2420	56.00 ea	5.01	-	1.18	-	-	6.19	347
03-35-29.60	Concrete finishing, walls, bush hammer, cured concrete	0350	84.00 sf	7.34	0.74	-	-	-	8.09	679
_Concrete Baffle Wall - Basin 2			19.65 cy	1,517.34	10.11	405.40	-	-	1,932.85	37,986
03345 _Plug Concrete Walls - 3 ea. @ 4'w x 5.5'h x 8" th										
03-11-13.85	C.I.P. concrete forms, wall, job built, plywood, over 8' to 16' high, 1 use, includes erecting, bracing, stripping and cleaning	2400	132.00 sfca	28.38	-	4.66	-	-	33.04	4,362
03-15-05.95	Form oil, up to 800 S.F. per gallon, coverage, includes material only	3050	0.35 gal	-	-	21.50	-	-	21.50	8



Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
03345 _Plug Concrete Walls - 3 ea. @ 4'w x 5.5'h x 8" th										
03-21-10.	Reinforcing steel, in place, walls, #3 to #7, A615, grade 60	0700	0.12 ton	2,172.40	-	1,250.00	-	-	3,422.40	418
03-21-10.	Reinforcing in place, unloading & sorting, add - walls, cols, beams	2010	0.12 ton	109.20	12.00	-	-	-	121.15	15
03-21-10.	Reinforcing, crane cost for handling, add to above, walls, cols, beams	2225	0.12 ton	118.70	13.00	-	-	-	131.70	16
03-31-05.	Structural concrete,ready mix,normal weight,4500 psi,includes local aggregate,sand,portland cement and water,excludes all additives and treatments	0350	1.71 cy	-	-	133.00	-	-	133.00	228
03-31-05.	Structural concrete, placing, walls, pumped, 15" thick, includes vibrating, excludes material	5350	1.71 cy	80.75	8.12	-	-	-	88.87	152
03-35-29.	Finishing: break ties & patch voids (walls, cols or beams)	0010	132.00 sf	2.41	-	0.04	-	-	2.45	323
03-82-16.	Concrete impact drilling, for anchors, 8" d, 3/4" dia, in concrete or brick walls and floors, includes bit cost, layout and set up time, excl anchor	0500	45.00 ea	59.73	-	0.22	-	-	59.95	2,698
03-63-05.	Chemical anchoring, for rebar dowel, #5 in 3/4" diam hole, 8" embed, incl epoxy cartridge, excl layout, drilling & rebar	BC-0111	45.00 ea	38.39	-	10.78	-	-	49.17	2,212
03-21-11.	Reinforcing steel, in place, dowels, deformed, 2' long, #5, A615, grade 60	2420	45.00 ea	7.49	-	1.42	-	-	8.91	401
	_Plug Concrete Walls - 3 ea. @ 4'w x 5.5'h x 8" th		0.00							10,832

03 Structural

48,818


04 Process Mechanical

05999 Stop Plates - 316 SS, 1/2" th

05-58-09.	Stainless steel plate, 1/2" thk.	BC-0041	84.50 sqft	8.93	-	7.70	-	-	16.63	1,405
	Stop Plates - 316 SS, 1/2" th		0.00							1,405

40360 4" AA Drop Leg Piping SS316 Butt Welded - Install Only

40-05-51.	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 4 Inch (100mm)	L134062006	4.00 ea	139.66	-	-	-	-	139.66	559
40-05-23.	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L134002160	80.00 lf	20.37	-	-	-	-	20.37	1,629
40-05-23.	Field Butt Weld-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L135102160	4.00 ea	141.33	27.59	0.20	-	-	169.11	676




Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 4" AA Drop Leg Piping SS316 Butt Welded - Install Only										
40-05-05.00	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 4 Inch (100mm)	A133400006 200	8.00 ea	51.73	-	29.59	-	-	81.31	651
40-05-07.00	Pipe Support 4 Inch (100mm)	A136044000 000	8.00 ea	129.32	-	16.69	-	-	146.00	1,168
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size (100mm) 4 Inch	A136043000 000	16.00 ea	25.86	-	22.25	-	-	48.11	770
40-05-05.00	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L139048000 000	80.00 lf	3.62	-	-	-	-	3.62	290
22-20-03.00	Pipe coupling, sleeve-type, Dresser style, 4"	BC-0211	4.00 ea	193.14	-	494.11	-	-	687.25	2,749
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL60906400 9000	16.00 mh	109.78	58.79	-	-	-	168.58	2,697
	4" AA Drop Leg Piping SS316 Butt Welded - Install Only		80.00 lf	92.93	13.14	33.79			139.86	11,189
40360 4" AA Manifold Piping SS316 Butt Welded - Install only										
40-05-23.20	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L134002160 OP2	38.00 lf	20.37	-	-	-	-	20.37	774
40-05-23.20	Field Butt Weld-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L135102160 000	2.00 ea	141.33	27.59	0.20	-	-	169.11	338
40-05-07.00	Pipe Support 4 Inch (100mm)	A136044000 000	8.00 ea	129.32	-	16.69	-	-	146.00	1,168
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size (100mm) 4 Inch	A136043000 000	16.00 ea	25.86	-	22.25	-	-	48.11	770
40-05-05.00	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L139048000 000	38.00 lf	3.62	-	-	-	-	3.62	138
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL60906400 9000	8.00 mh	109.78	58.79	-	-	-	168.58	1,349
	4" AA Manifold Piping SS316 Butt Welded - Install only		38.00 lf	92.65	13.83	12.89			119.37	4,536
40360 4" Purge Piping SS316 Butt Welded Shop Fab Piping										
40-05-23.20	Pipe Plain End-Stainless 316/316L-Seamless-Sch 10S 4 Inch (100mm)	A131005160 0S	44.33 lf	-	-	11.28	-	-	11.28	500
40-05-23.20	Fitting Butt Weld-Stainless 316/316L-ElI45-Sch 10S 4 Inch (100mm)	A132111160 000	4.00 ea	-	-	12.51	-	-	12.51	50
40-05-23.20	Shop Butt Weld-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L133102160 000	8.00 ea	-	-	8.45	-	-	8.45	68



Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 4" Purge Piping SS316 Butt Welded Shop Fab Piping										
40-05-23.00	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L134002160 0P2	46.00 lf	20.37	-	-	-	-	20.37	937
40-05-23.00	Field Butt Weld-Stainless 316/316L-Sch 10S 4 Inch (100mm)	L135102160 000	4.00 ea	141.33	27.59	0.20	-	-	169.11	676
40-05-07.00	Pipe Support 4 Inch (100mm)	A136044000 000	8.00 ea	129.32	-	16.69	-	-	146.00	1,168
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size 4 Inch (100mm)	A136043000 000	16.00 ea	25.86	-	22.25	-	-	48.11	770
40-05-05.00	Field Testing-Hydrotest-Non-Specific 4 Inch (100mm)	L139048000 000	46.00 lf	3.62	-	-	-	-	3.62	167
	4" Purge Piping SS316 Butt Welded Shop Fab Piping		46.00 lf	67.76	2.40	24.08	-	-	94.24	4,335
40360 8" AA Piping SS316 - Motor Operated BFV and Air Flow Meter - 1 ea.										
40-05-23.00	Fitting Flanged & Bolted-Stainless 316/316L-Flange WN-Cls 150-Sch 40S/Std 8 Inch (200mm)	A162421176 200	2.00 ea	-	-	99.12	-	-	99.12	198
40-05-64.00	Valve Flanged & Bolted-Stainless Steel-Butterfly-Cls 150 (PN20) 8 Inch (200mm)	A166434206 200	1.00 ea	-	-	595.95	-	-	595.95	596
40-05-51.00	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 8 Inch (200mm)	L164062006 200	1.00 ea	180.71	-	-	-	-	180.71	181
40-05-23.00	Field Butt Weld-Stainless 316/316L-Sch 10S 8 Inch (200mm)	L165102160 000	2.00 ea	154.76	30.21	0.47	-	-	185.44	371
40-05-05.00	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 8 Inch (200mm)	A163400006 200	2.00 ea	48.58	-	57.61	-	-	106.19	212
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL60906400 9000	4.00 mh	82.48	44.17	-	-	-	126.65	507
27-20-52.00	FE - (Pilot Tube) Flow Element - Install, Calibrate, Test, Loop Check	BC-0010	1.00 ea	772.17	-	238.25	-	-	1,010.42	1,010
40-05-57.23	Valves-Accessories-Motor Operator-8 Inch (200mm)	A166046000 000	1.00 ea	-	-	8,137.70	-	-	8,137.70	8,138
	8" AA Piping SS316 - Motor Operated BFV and Air Flow Meter - 1 ea.		0.00	-	-	-	-	-	11,213	
40360 4" CAA Piping at Channel - SS316 Butt Welded Shop Fab Piping										
40-05-23.00	Pipe Plain End-Stainless 316/316L-Seamless-Sch 10S 4 Inch (100mm)	A131005160 0S	95.20 lf	-	-	11.16	-	-	11.16	1,063
40-05-23.00	Fitting Butt Weld-Stainless 316/316L-ElI90-Sch 10S 4 Inch (100mm)	A132112160 000	4.00 ea	-	-	45.72	-	-	45.72	183



Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 4" CAA Piping at Channel - SS316 Butt Welded Shop Fab Piping										
40-05-23.00	Fitting Butt Weld-Stainless 316/316L-Tee-Sch 10S 20 Inch (100mm)	A132114160000	3.00 ea	-	-	82.31	-	-	82.31	247
40-05-23.00	Fitting Butt Weld-Stainless 316/316L-Cap-Sch 10S 20 Inch (100mm)	A132117160000	1.00 ea	-	-	5.50	-	-	5.50	6
40-05-23.00	Fitting Flanged & Bolted-Stainless 316/316L-Flange WN-Cls 150-Sch 40S/Std 4 Inch (100mm)	A132421176200	9.00 ea	-	-	39.65	-	-	39.65	357
40-05-23.00	Shop Butt Weld-Stainless 316/316L-Sch 10S 20 (100mm)	L133102160000	27.00 ea	-	-	8.37	-	-	8.37	226
40-05-64.00	Valve Flanged & Bolted-Stainless Steel-Butterfly-Cls 150 (PN20) 4 Inch (100mm)	A136434206200	4.00 ea	-	-	224.89	-	-	224.89	900
40-05-51.00	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 400 Inch (100mm)	L134062006200	4.00 ea	104.93	-	-	-	-	104.93	420
40-05-23.00	Pipe Erection-Spools-Stainless 316/316L-Sch 10S 20 Inch (100mm)	L1340021600P2	108.00 lf	15.30	-	-	-	-	15.30	1,653
40-05-23.00	Field Butt Weld-Stainless 316/316L-Sch 10S 20 (100mm)	L135102160000	9.00 ea	106.18	20.73	0.19	-	-	127.10	1,144
40-05-05.00	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 4 Inch (100mm)	A133400006200	9.00 ea	38.86	-	29.29	-	-	68.16	613
40-05-07.00	Pipe Support 4 Inch (100mm)	A136044000000	3.00 ea	97.16	-	16.52	-	-	113.68	341
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size 400 (100mm)	A136043000000	2.00 ea	19.43	-	22.03	-	-	41.46	83
40-05-07.00	Hanger Rod 4 Inch (100mm)	A136045000000	3.00 ea	29.15	-	27.54	-	-	56.68	170
40-05-05.00	Field Testing-Hydrotest-Non-Specific 400 Inch (100mm)	L139048000000	108.00 lf	2.72	-	-	-	-	2.72	294
22-20-03.00	Pipe coupling, sleeve-type, Dresser style, 4" 400	BC-0211	4.00 ea	193.14	-	494.11	-	-	687.25	2,749
4" CAA Piping at Channel - SS316 Butt Welded Shop Fab Piping			108.00 lf	45.02	1.73	49.98	-	-	96.73	10,447
46999 Fine Bubble Diffusers - 270 ea.										
46-06-00.00	Diffusers, fine bubble, complete, includes PVC laterals 400	BC-0046	270.00 ea	23.23	-	65.20	-	-	88.43	23,876
Fine Bubble Diffusers - 270 ea.			270.00 ea	23.23	-	65.20	-	-	88.43	23,876
46999 Submersible Mixers - 2 ea.										
46-06-00.00	Mixer, propellar type, 5 hp,lightnin, 900 rpm, tefc motor 400	BC-0616	2.00 ea	1,132.74	-	23,959.80	-	-	25,092.54	50,185



Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
	Submersible Mixers - 2 ea.		0.00							50,185
46999	Coarse Bubble Diffusers in Channel - 28 ea.									
46-06-00	Diffusers, coarse bubble, complete	BC-0041	28.00 ea	660.73	-	45.10	-	-	705.83	19,763
00										
	Coarse Bubble Diffusers in Channel - 28 ea.		0.00							19,763
46999	Slide Gate - 1 ea.									
35-22-73	Slide gates, hydraulic structures, steel, self contained, 36" x 66", incl. anchor bolts & grout	0160	1.00 ea	2,704.37	981.75	8,200.00	-	-	11,886.12	11,886
16										
	Slide Gate - 1 ea.		0.00							11,886
04 Process Mechanical										148,835
05 Electrical and Instrumentation										
26999	Connect Valve Motor Operator									
26-99-99	Connect valve motor operator	MISC	1.00 ea	2,405.33	-	4,500.00	-	-	6,905.33	6,905
99										
	Connect Valve Motor Operator		0.00							6,905
26999	Connect Mixers - 2 ea.									
26-99-99	Connect mixers in Basin 2	MISC	2.00 ea.	3.85	-	4,500.00	0.00	-	4,503.85	9,008
99										
	Connect Mixers - 2 ea.		0.00							9,008
27999	DO Probes									
27-20-57	DO - Dissolved Oxygen - Install, Calibrate, Test, Loop Check	BC-0006	2.00 ea	935.96	-	3,621.40	-	-	4,557.36	9,115
00										
26-99-99	Conduit and wire for DO probes	MISC	2.00 ea	6.50	-	3,335.50	-	-	3,342.00	6,684
99										
	DO Probes		0.00							15,799
05 Electrical and Instrumentation										31,712
02 Basins 1 & 2										293,364
01 ALTERNATE 3										566,375



Estimate Detail Report

7/21/2021 9:08 AM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 3

Estimate Totals

Description	Rate	Hours	Amount	Totals
Labor		2,201 hrs	224,138	
Material			294,156	
Subcontract			25,000	
Equipment		606 hrs	23,081	
Other				
			566,375	566,375
Labor Mark-up	15.00 %		33,621	
Material Mark-up	10.00 %		29,416	
Subcontractor Mark-up	10.00 %		2,500	
Construction Equipment Mark-up	10.00 %		2,308	
Other - Process Equip Mark-up	8.00 %			
			67,845	634,220
Material Shipping & Handling	2.00 %		5,883	
Material Sales Tax	8.75 %		25,739	
Other - Process Eqp Sales Tax	8.75 %			
Net Markups			31,622	665,842
Contractor General Conditions	15.00 %		99,876	
			99,876	765,718
Start-Up, Training, O&M	2.00 %		15,314	
			15,314	781,032
Undesign/Undevelop Contingency	30.00 %		234,310	
			234,310	1,015,342
Bldg Risk, Liability Auto Ins	2.00 %		20,307	
			20,307	1,035,649
Payment and Performance Bonds	1.50 %		15,535	
			15,535	1,051,184
Escalation to Midpoint (ALL)				
Gross Markups				1,051,184
Total				1,051,184



Estimate Summary Report


7/20/2021 8:05 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 4

SEWER AUTHORITY MID-COASTSIDE WWTP CAPACITY STUDY - ALTERNATIVE 4 CLASS 5 ESTIMATE - PLANNING LEVEL

Estimator	Steve Payne
BC Project Manager	Mike Harrison
BC Office	Sacramento
Est Version Number	1
QA/QC Reviewer	Bill Agster
QA/QC Review Date	06/29/21
BC Project Number	156642



Estimate Summary Report

7/20/2021 8:05 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 4

Phase	Description	Gross Total Cost with Markups
01 ALTERNATE 4		
03 Alternate 4 Additions		
01 Demolition		9,839
04 Process Mechanical		183,033
05 Electrical and Instrumentation		50,624
03 Alternate 4 Additions		243,496
<hr/>		
01 ALTERNATE 4		243,496



Estimate Detail Report


7/20/2021 8:08 PM

BC Project Number: 156642
Estimate Version Number: 1
Estimate Date: 06/30/21
Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 4

SEWER AUTHORITY MID-COASTSIDE WWTP CAPACITY STUDY - ALTERNATIVE 4 CLASS 5 ESTIMATE - PLANNING LEVEL

Estimator	Steve Payne
BC Project Manager	Mike Harrison
BC Office	Sacramento
Est Version Number	1
QA/QC Reviewer	Bill Agster
QA/QC Review Date	06/29/21
BC Project Number	156642




Estimate Detail Report

7/20/2021 8:08 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 4

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
01 ALTERNATE 4										
03 Alternate 4 Additions										
01 Demolition										
02999 Core Drill for 8" Basin Influent Pipe										
03-82-13.	Concrete core drilling, bits for core drill, diamond, premium, 12" diameter, included in drilling line items	3120	2.00 ea	-	-	655.00	-	-	655.00	1,310
10										
	Core Drill for 8" Basin Influent Pipe		0.00							1,310
02999 Pressure Wash Basin 1										
04-01-30.	High pressure wash, average soil, biological staining, water only, excludes scaffolding	0420	2,220.00 sf	1.54	0.26	-	-	-	1.80	4,007
20										
	Pressure Wash Basin 1		0.00							4,007
01 Demolition										5,317
04 Process Mechanical										
40360 Piping SS316 Butt Welded Shop Fab Piping w/Optional Flanges & Valves										
40-05-23.	Pipe Plain End-Stainless 316/316L-Seamless-Sch 40S/Std 8 Inch (200mm)	A161005170 0S	9.27 lf	-	-	56.78	-	-	56.78	526
20										
40-05-23.	Fitting Butt Weld-Stainless 316/316L-ElI45-Sch 40S/Std 8 Inch (200mm)	A162111170 000	2.00 ea	-	-	90.70	-	-	90.70	181
20										
40-05-23.	Fitting Butt Weld-Stainless 316/316L-ElI90-Sch 40S/Std 8 Inch (200mm)	A162112170 000	2.00 ea	-	-	118.91	-	-	118.91	238
20										
40-05-23.	Fitting Flanged & Bolted-Stainless 316/316L-Flange WN-Cls 150-Sch 40S/Std 8 Inch (200mm)	A162421176 200	5.00 ea	-	-	99.12	-	-	99.12	496
20										
40-05-23.	Shop Butt Weld-Stainless 316/316L-Sch 40S/Std 8 Inch (200mm)	L163102170 000	13.00 ea	-	-	14.22	-	-	14.22	185
20										
40-05-64.	Valve Flanged & Bolted-Stainless Steel-Butterfly-Cls 150 (PN20) 8 Inch (200mm)	A166434206 200	1.00 ea	-	-	595.95	-	-	595.95	596
00										
40-05-61.	Valve Flanged & Bolted-Stainless Steel-Gate-Cls 150 (PN20) 8 Inch (200mm)	A166431206 200	1.00 ea	-	-	5,049.84	-	-	5,049.84	5,050
00										
40-05-51.	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 8 Inch (200mm)	L164062006 200	2.00 ea	180.72	-	-	-	-	180.72	361
00										
40-05-23.	Pipe Erection-Spools-Stainless 316/316L-Sch 40S/Std 8 Inch (200mm)	L164002170 0P2	20.00 lf	37.16	-	-	-	-	37.16	743
20										
40-05-23.	Field Butt Weld-Stainless 316/316L-Sch 40S/Std 8 Inch (200mm)	L165102170 000	1.00 ea	340.75	66.52	1.30	-	-	408.57	409
20										



Estimate Detail Report

7/20/2021 8:08 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 4

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 Piping SS316 Butt Welded Shop Fab Piping w/Optional Flanges & Valves										
40-05-05.00	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 8 Inch (200mm)	A163400006 200	5.00 ea	48.58	-	57.60	-	-	106.18	531
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size 8 Inch (200mm)	A166043000 000	1.00 ea	29.15	-	27.54	-	-	56.69	57
40-05-05.00	Field Testing-Hydrotest-Non-Specific 8 Inch (200mm)	L169048000 000	20.00 lf	7.48	-	-	-	-	7.48	150
27-20-03.00	8" Magnetic flowmeters, 150# AWWA flanges	BC-0016	1.00 ea	406.60	-	8,000.00	-	-	8,406.60	8,407
40-05-57.23	Valves-Accessories-Motor Operator-8 Inch (200mm) for butterfly valve	A166046000 000	1.00 ea	-	-	8,057.12	-	-	8,057.12	8,057
22-11-19.34	Sleeve, pipe, steel with water stop, 12" long, 12" diam. for 8" carrier pipe, includes link seal	0220	2.00 ea	208.13	-	390.00	-	-	598.13	1,196
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL60906400 9000	8.00 mh	82.48	44.17	-	-	-	126.65	1,013
	Piping SS316 Butt Welded Shop Fab Piping w/Optional Flanges & Valves		20.00 lf	167.49	21.00	1,221.28			1,409.76	28,195
40360 8" Submersible Pump Discharge Piping SS316 Butt Welded Shop Fab Piping										
40-05-23.20	Pipe Plain End-Stainless 316/316L-Seamless-Sch 40S/Std 8 Inch (200mm)	A161005170 0S	14.83 lf	-	-	56.78	-	-	56.78	842
40-05-23.20	Fitting Butt Weld-Stainless 316/316L-ElI90-Sch 40S/Std 8 Inch (200mm)	A162112170 000	2.00 ea	-	-	118.91	-	-	118.91	238
40-05-23.20	Fitting Flanged & Bolted-Stainless 316/316L-Flange WN-Cls 150-Sch 40S/Std 8 Inch (200mm)	A162421176 200	3.00 ea	-	-	99.12	-	-	99.12	297
40-05-23.20	Shop Butt Weld-Stainless 316/316L-Sch 40S/Std 8 Inch (200mm)	L163102170 000	7.00 ea	-	-	14.22	-	-	14.22	100
40-05-23.20	Pipe Erection-Spools-Stainless 316/316L-Sch 40S/Std 8 Inch (200mm)	L164002170 0P2	20.00 lf	37.16	-	-	-	-	37.16	743
40-05-23.20	Field Butt Weld-Stainless 316/316L-Sch 40S/Std 8 Inch (200mm)	L165102170 000	1.00 ea	340.75	66.52	1.30	-	-	408.57	409
40-05-05.00	Make Up Bolted Joint incl B-7 Nuts, Bolts, 1/16 Inch Rubber Gasket-Cls 150 (PN20) 8 Inch (200mm)	A163400006 200	3.00 ea	48.58	-	57.60	-	-	106.18	319
40-05-07.00	Pipe Support 8 Inch (200mm)	A166044000 000	3.00 ea	97.16	-	27.54	-	-	124.69	374
40-05-07.00	Hilti-Chemical Anchor - Pipe Support Size 8 Inch (200mm)	A166043000 000	2.00 ea	29.15	-	27.54	-	-	56.68	113
40-05-05.00	Field Testing-Hydrotest-Non-Specific 8 Inch (200mm)	L169048000 000	20.00 lf	7.48	-	-	-	-	7.48	150



Estimate Detail Report

7/20/2021 8:08 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 4

Phase	Description	Item	Takeoff Quantity	Labor Cost/Unit	Equip Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
40360 8" Submersible Pump Discharge Piping SS316 Butt Welded Shop Fab Piping										
27-20-03.00	8" Magnetic flowmeters, 150# AWWA flanges	BC-0016	1.00 ea	406.60	-	8,000.00	-	-	8,406.60	8,407
40-05-05.00	Pipe Erection-Handle Pipe-Construction Equipment	XL609064009000	8.00 mh	82.48	44.17	-	-	-	126.65	1,013
	8" Submersible Pump Discharge Piping SS316 Butt Welded Shop Fab Piping		20.00 lf	139.78	21.00	489.41			650.19	13,004
46999 Submersible Pump - 1 ea. @ 300 GPM										
46-06-22.00	Submersible pump - 300 GPM 50 TDH, includes guide rail,base elbow, & VFD	BC-0086	1.00 ea	4,879.25	700.00	50,000.00	-	0.00	55,579.25	55,579
	Submersible Pump - 1 ea. @ 300 GPM		0.00							55,579
04 Process Mechanical										96,778
05 Electrical and Instrumentation										
26999 Connect Submersible Pump and VFD										
26-99-99.99	Connect submersible pump w/ VFD	MISC	1.00 ea	4,810.65	-	10,000.00	0.00	-	14,810.65	14,811
	Connect Submersible Pump and VFD		0.00							14,811
26999 Connect Flowmeters										
26-99-99.99	Connect 8" magnetic flow meters	MISC	2.00 ea	1,539.41	-	4,500.00	-	-	6,039.41	12,079
	Connect Flowmeters		0.00							12,079
05 Electrical and Instrumentation										26,889
03 Alternate 4 Additions										128,984
01 ALTERNATE 4										128,984



Estimate Detail Report

7/20/2021 8:08 PM

BC Project Number: 156642
 Estimate Version Number: 1
 Estimate Date: 06/30/21
 Lead Estimator: Steve Payne

WWTP CAPACITY STUDY - ALTERNATIVE 4

Estimate Totals

Description	Rate	Hours	Amount	Totals
Labor		243 hrs	22,333	
Material			104,524	
Subcontract				
Equipment		70 hrs	2,128	
Other				
			128,985	128,985
Labor Mark-up	15.00 %		3,350	
Material Mark-up	10.00 %		10,452	
Subcontractor Mark-up	10.00 %			
Construction Equipment Mark-up	10.00 %		213	
Other - Process Equip Mark-up	8.00 %			
			14,015	143,000
Material Shipping & Handling	2.00 %		2,090	
Material Sales Tax	8.75 %		9,146	
Other - Process Eqp Sales Tax	8.75 %			
Net Markups			11,236	154,236
Contractor General Conditions	15.00 %		23,135	
			23,135	177,371
Start-Up, Training, O&M	2.00 %		3,547	
			3,547	180,918
Undesign/Undevelop Contingency	30.00 %		54,276	
			54,276	235,194
Bldg Risk, Liability Auto Ins	2.00 %		4,704	
			4,704	239,898
Payment and Performance Bonds	1.50 %		3,598	
			3,598	243,496
Escalation to Midpoint (ALL)				
Gross Markups				243,496
Total				243,496

Attachment B: BioWin Calibration Summary

Table B-1. Summary of primary influent fractions

Fraction	Reference/Approach	Adjusted Value
Flow [mgd]	Avg of Historical data (daily)	1.296
Alkalinity [mgCaCO ₃ /L]	Avg of Historical data (10 data per month)	340.7
BOD - Total Carbonaceous [mg/L]	Avg of Historical data (10 data per month)	318.1
BOD - Filtered Carbonaceous [mg/L]	BioWin typical fraction	133.0
COD - Total [mg/L]	Assumed BOD:COD ratio of 2.2	700
COD - Filtered [mg/L]	Increased COD from 25 mg/L to 35 mg/L based on COD data:default ratio of 500:700	258.7
COD - FF [mg/L]	BioWin typical fraction	147.0
CODs - Acetate [mg/L]	BioWin typical fraction	16.8
Gas - Dissolved oxygen [mg/L]	Assumed	0.0
Metal soluble - Calcium [mg/L]	Assumed	80.0
Metal soluble - Magnesium [mg/L]	Assumed	15.0
N - Total Kjeldahl Nitrogen [mg/L]	Assumed TKN: Ammonia ratio of 0.66	8.4
N - Ammonia [mg/L]	Assumed BOD: Ammonia ratio of 10	31.81
N - Nitrate [mg/L]	Assumed	0
pH [mg/L]	Historical Data (effluent daily)	7.4
P - Total [mg/L]	Assumed BOD:TP ratio	8.4
P - Soluble phosphate [mg/L]	Assumed	4.2
TSS [mg/L]	Historical Data (10 data per month)	292.8
VSS [mg/L]	Assumed VSS:TSS ratio of 0.85	248.0
S - Total S [mg/L]	Assumed BOD:TS ratio	8.4
S - Soluble Sulfate [mg/L]	BioWin typical fraction	7.2
COD - Filtered [mg/L]	Increased the ratio based on influent COD to match FUS to default value	35

Table B-2 tabulates parameters evaluated during the calibration and validation periods (text in red and blue). In general, there is good agreement on solid balance. This is not the case for aeration, BOD, and nitrification prediction.













Table B-2. Summary of Calibration and Validation Results						
Parameter	BioWin	SAM Data	Delta	Approach/Comments	General Recommendation	
MLSS, mg/L	Calib	1,347	1,323 1,466	-8.2% -9.8%	 Overall Delta < 10% variance -> Acceptable	For planning-level a %10-%15 level of agreement is acceptable on a monthly average basis (US EPA, 2010) ⁽¹⁾
	Valid 1	1,592	1,570 1,456	9.3% 7.8%		
	Valid 2	1,302	1,277 1,394	-6.5% -8.4%		
MLVSS, mg/L	Calib	1,151	1,246	-7.7%	 MLVSS ratio expected to be close to MLSS since MLVSS is estimated based on VSS:TSS 0.85	Particulate BOD and VSS relationship can be adjusted. Match MLVSS before matching MLSS (US EPA, 2010) ⁽¹⁾
	Valid 1	1,363	1,238	10.1%		
	Valid 2	1,116	1,185	-5.8%		
WAS TSS, mg/L	Calib	3,721	4,044	-8.0%	 Overall Delta < 12% variance -> Acceptable	Less critical to match RAS and WAS TSS concentration, as this parameter varies depending on the time of grab sampling (US EPA, 2010) ⁽¹⁾
	Valid 1	4,524	4,370	3.5%		
	Valid 2	3,694	4,287	-13.8%		
SRT, d	Calib	2.17	2.10	3.2%	 Overall Delta < 14% variance -> Acceptable	-
	Valid 1	2.04	1.81	13.0%		
	Valid 2	2.11	1.88	12.0%		
AB3 Airflow, cfm	Calib	1,881	2,311	-18.6%	 BioWin estimates was consistently Less than historical data records (Hourly from Historian). The fouling factor was set at 0.5. This brought the BioWin calculated air much closer the plant records. One assumption is that the diffusers may be torn or aeration flowmeter data not reliable. In aeration capacity evaluation, consider adding a safety factor or clearly stating BioWin predictions were lower than actual plant data.	-
	Valid 1	2,277	2,381	-4.4%		
	Valid 2	1,868	2,230	-16.2%		
Primary TSS Removal, %	Calib	75.29%	77.48%	-2.83%	 Average value Inputted to BioWin based on historical data during the specific calib/valid period	-
	Valid 1	70.95%	73.54%	-3.5%		
	Valid 2	74.16%	76.46%	-3.0%		
Secondary TSS, mg/L	Calib	8.53	9.90	-14%	 Revised to match eff TSS (-/+ 2 mg/L)	-
	Valid 1	10.01	14.41	-31%		

Table B-2. Summary of Calibration and Validation Results

Parameter		BioWin	SAM Data	Delta	Approach/Comments	General Recommendation
	Valid 2	6.42	8.40	-24%		
Influent Flow, mgd	Calib	1.30	1.30	-0.21%	 Entered hourly data that were based on Daily data multiplied by diurnal profile multipliers achieved from actual hourly historian data	
	Valid 1	1.58	1.58	-0.2%		
	Valid 2	1.25	1.25	-0.2%		
Effluent Flow, mgd	Calib	1.30	1.32	-2.1%		
	Valid 1	1.58	1.54	2.7%		
	Valid 2	1.25	1.36	-8.1%		
Final Effluent BOD, mg/L	Calib	6.6	17.6	-63%	 BioWin estimates consistently better BOD removal than plant records	
	Valid 1	7.7	15.3	-49.3%		
	Valid 2	5.3	13.4	-60.6%		
Final Effluent Ammonia, mg N/L	Calib	39.5	42.9	-8.0%	 Note the extent of nitrification is minimal. The MLSS and temperature puts the plant at the tipping point for nitrification. Note: Since we are not certain about alkalinity data, that's why I compared alkalinity removal rather than absolute alkalinity values. The Effluent Nitrate data (not summarized here) are in very good agreement.	
	Valid 1	38.5	42.3	-8.8%		
	Valid 2	38.5	39.8	-3.3%		
Final Effluent Nitrite, mg N/L	Calib	0.078	0.144	-45%	 No effluent Nitrate data is available from SAM. In general the model predicts very low nitrification. We assumed the DO levels in the first zone is significantly lower than the second zone (avg 1 mg/L in first zone, compared to avg 3-4 mg/L in the second zone). If we assume high DO in the first zone, significant nitrification would occur.	
	Valid 1	0.012	0.099	-88%		
	Valid 2	0.498	0.213	134%		

Attachment C: Hydraulic Upgrade Schematics



**ALTERNATIVES 1 & 2 -
PROPORTIONAL FLOW SPLIT**


**To Splitter
Box**

**EXISTING WEIR GATE
(TYP)**


**Install new weir gates to fixed
height or width. Determine
heights or widths from modeling.**

**Alternatively, install cutthroat
flumes. Vary invert and throat
width to achieve flow split.**


B SECTIONAL PLAN
3/16" = 1'-0"



W SECTION
3/8" = 1'-0"



X SECTION
3/8" = 1'-0"



RECORD DRAWING
THESE RECORD DRAWINGS HAVE BEEN PREPARED BASED
ON INFORMATION PROVIDED BY OTHERS.

DESIGNED	RCM/NH/TOB
DRAWN	RWN
CHECKED	DMM/TPH
DATE	APRIL 1996
DISCIPLINE ENGINEER	STRUCTURAL
PROJECT ENGINEER	PROJECT ENGINEER
PARTNER	PARTNER

CAROLLO ENGINEERS

SEWER AUTHORITY OF SHERMAN COUNTY, OREGON

REGISTERED PROFESSIONAL ENGINEER
No. 27728
Exp. 12/31/98
CIVIL
STATE OF CALIFORNIA


**EXPANSION OF
REGIONAL WASTEWATER TREATMENT FACILITY**

AERATION BASINS

SECTIONAL PLAN AND SECTIONS - BASINS 1 AND 2

VERIFY SCALES
BAR IS ONE INCH ON ORIGINAL DRAWING
0 1" = 1'

JOB NO. 4249A.10
DRAWING NO. AB-2
SHEET NO. 37 OF 132



ALTERNATIVES 1 & 2 - PROPORTIONAL FLOW SPLIT


To Splitter Box

Adjust weir gates to fixed height. Determine heights from modeling.


Alternatively, use cutthroat flumes. Vary invert and throat width to achieve flow split.

To AB 1 and 2

B SECTIONAL PLAN
3/16" = 1'-0"



C PARTIAL PLAN
3/16" = 1'-0"




D DETAIL
3/8" = 1'-0"

- NOTE:**
1. PROVIDE ST. STL PIPE SLEEVES PER 424 OR 425 TYP.
 2. SEE SLUICE GATE AND SLIDE GATE SCHEDULES IN DIVISION 15 OF SPECIFICATIONS FOR EACH GATE DESIGNATED BY MARK NO'S
 3. FOR SIGN SCHEDULE, SEE SPECIFICATIONS SECTION 10-B

DESIGNED	RCM/NH
DRAWN	RWN
CHECKED	PMM/TOH
DATE	APRIL 1998
REV.	DATE
BY	DESCRIPTION
AB-6X	AB-6X
AB-6B	AB-6B
AB-6	AB-6
TBA	TBA


DISCIPLINE ENGINEER	
PROJECT ENGINEER	
PARTNER	




SEWER AUTHORITY OF MARYLAND
DASTSIDE

EXPANSION OF REGIONAL WASTEWATER TREATMENT FACILITY
AERATION BASINS
SECTIONAL PLANS, BASINS 3 AND 4


VERIFY SCALES	JOB NO. 4249A.10
BAR IS ONE INCH ON ORIGINAL DRAWING	DRAWING NO. AB-6
IF NOT ONE INCH ON THIS SHEET, ADJUST SCALES ACCORDINGLY	SHEET NO. 41 OF 132




B SECTIONAL PLAN
3/16" = 1'-0"



W SECTION
3/8" = 1'-0"



X SECTION
3/8" = 1'-0"



RECORD DRAWING
THESE RECORD DRAWINGS HAVE BEEN PREPARED BASED ON INFORMATION PROVIDED BY OTHERS.

REV.	DATE	BY	DESCRIPTION
AB-2X	AB-2X		
AB-2	AB-2	11/99	PG RECORD DRAWING
JBA	TB		

DESIGNED RCM/NH/TOB
DRAWN RWN
CHECKED DHM/TDH
DATE APRIL 1996

DISCIPLINE ENGINEER
STRUCTURAL

PROJECT ENGINEER
CIVIL

PARTNER
CIVIL

CAROLLO ENGINEERS

SEWER AUTHORITY MILWAUKEE COASTSIDE

EXPANSION OF
REGIONAL WASTEWATER TREATMENT FACILITY


AERATION BASINS

SECTIONAL PLAN AND SECTIONS - BASINS 1 AND 2

VERIFY SCALES
BAR IS ONE INCH ON ORIGINAL DRAWING
0 1" = 1'

IF NOT ONE INCH ON THIS SHEET, ADJUST SCALES ACCORDINGLY.

JOB NO. 4249A.10
DRAWING NO. **AB-2**
SHEET NO. 37 OF 132



**ALTERNATIVE 3 -
SERIES FLOW**

**Adjust weir gates to fixed height.
Determine height from
modeling.**


**To Splitter
Box**

**Install
stop
plate**

**Cut
channel,
plug pipe**

**To AB 1
and 2**

(B) SECTIONAL PLAN
3/16" = 1'-0"




(C) PARTIAL PLAN
3/16" = 1'-0"

(D) DETAIL
3/8" = 1'-0"

- NOTE:**
1. PROVIDE ST. STL PIPE SLEEVES PER 424 OR 425 TYP.
 2. SEE SLUICE GATE AND SLIDE GATE SCHEDULES IN DIVISION 15 OF SPECIFICATIONS FOR EACH GATE DESIGNATED BY MARK NO'S
 3. FOR SIGN SCHEDULE, SEE SPECIFICATIONS SECTION 10-B

DESIGNED	RCM/NH
DRAWN	RWN
CHECKED	PMM/TOH
DATE	APRIL 1998
REV.	DATE
BY	DESCRIPTION
AB-6X	AB-6X
AB-6B	AB-6B
AB-6	AB-6
TBA	TB

DISCIPLINE ENGINEER	PROJECT ENGINEER
DATE	DATE




SEWER AUTHORITY OF MARYLAND
DASTSIDE

**EXPANSION OF
REGIONAL WASTEWATER TREATMENT FACILITY
AERATION BASINS**

SECTIONAL PLANS, BASINS 3 AND 4

VERIFY SCALES	JOB NO.
BAR IS ONE INCH ON ORIGINAL DRAWING	4249A.10
0" = 1'	DRAWING NO.
IF NOT ONE INCH ON THIS SHEET, ADJUST SCALES ACCORDINGLY	AB-6
	SHEET NO.
	41 OF 132



Install level sensor

FEQ Influent Pipe

Pipe connecting PE channel to AB1. Move to east end if draining via existing 4" pipe.

pumped effluent

gravity flow effluent

To AB 3 and 4


Baffle wall

FEQ Influent Pipe

B SECTIONAL PLAN
3/16" = 1'-0"

W SECTION
3/8" = 1'-0"

X SECTION
3/8" = 1'-0"




RECORD DRAWING
THESE RECORD DRAWINGS HAVE BEEN PREPARED BASED ON INFORMATION PROVIDED BY OTHERS.

DESIGNED	RCM/NH/TOB
DRAWN	RWN
CHECKED	DMM/TPH
DATE	APRIL 1996
DISCIPLINE ENGINEER	
PROJECT ENGINEER	
PARTNER	

EXPANSION OF
 REGIONAL WASTEWATER TREATMENT FACILITY
 AERATION BASINS
SECTIONAL PLAN AND SECTIONS - BASINS 1 AND 2


VERIFY SCALES
 BAR IS ONE INCH ON ORIGINAL DRAWING
 0 1"

JOB NO. 4249A.10
 DRAWING NO. **AB-2**
 SHEET NO. 37 OF 132




**ALTERNATIVE 3 -
SERIES FLOW WITH EQ BASIN**

S DETAIL
AB-1 1/2" = 1'-0"




G SECTION
AB-1 3/8" = 1'-0"


Pumped flow




P SECTION
AB-1 3/8" = 1'-0"



R SECTION
3/8" = 1'-0"



Q DETAIL PLAN
AB-2 3/8" = 1'-0"






RECORD DRAWING
THESE RECORD DRAWINGS HAVE BEEN PREPARED BASED ON INFORMATION PROVIDED BY OTHERS.



<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td>DESIGNED</td><td>RCM/TGB</td></tr> <tr><td>DRAWN</td><td>RWN</td></tr> <tr><td>CHECKED</td><td>DMM/TDH</td></tr> <tr><td>DATE</td><td>APRIL 1998</td></tr> </table>	DESIGNED	RCM/TGB	DRAWN	RWN	CHECKED	DMM/TDH	DATE	APRIL 1998	<p>DISCIPLINE ENGINEER</p> <p>PROJECT ENGINEER</p> <p>PARTNER</p>	<p>DESIGNED PROFESSIONAL ENGINEER</p> <p>PROJECT ENGINEER</p> <p>PARTNER</p>	<p>DESIGNED PROFESSIONAL ENGINEER</p> <p>PROJECT ENGINEER</p> <p>PARTNER</p>	<p>CAROLLO ENGINEERS</p>	<p>SEWER AUTHORITY MIAMI COASTSIDE</p> <p style="font-size: 2em; font-weight: bold; text-align: center;">S A M</p>	<p style="text-align: center;">EXPANSION OF REGIONAL WASTEWATER TREATMENT FACILITY AERATION BASINS</p> <p style="text-align: center;">SECTIONS AND DETAILS - BASINS 1 AND 2</p>	<p>VERIFY SCALES BAR IS ONE INCH ON ORIGINAL DRAWING</p> <p>0 1" = 1'</p> <p>IF NOT ONE INCH ON THIS SHEET, ADJUST SCALES ACCORDINGLY.</p>	<p>JOB NO. 4249A.10 DRAWING NO. AB-4 SHEET NO. 39 OF 132</p>
DESIGNED	RCM/TGB															
DRAWN	RWN															
CHECKED	DMM/TDH															
DATE	APRIL 1998															


Attachment D: BOD Spike Period Plots

The following plots are provided to document the water quality data associated with the various BOD spikes that occurred in 2020.













● SVI



● Cl2 to RAS, lb







The above documented actual data from the BOD spike. The following describes a modeling effort to

Attachment E: Operations TM



18500 Von Karman Avenue, Suite 1100
Irvine, CA 92612

T: 714.730.7600

DRAFT Technical Memorandum

Subject: Operations Support for Recent Sludge Bulking Event
Date: June 24, 2021
To: Kishen Prathivadi, P.E., PMP
From: Lance P. Salerno, QEP, Senior Principal O&M Consulting
Copy to: Michael Harrison, P.E., Director

Section 1: Introduction

1.1 Purpose and Background

Purpose

The purpose of this memorandum is to summarize initial observations, findings, and recommendations implemented to evaluate the process upset situation over the period from June 09, 2021 to June 21, 2021.

While findings here may be incorporated or considered by the final long term process evaluation study, this TM is intended to be near term in response to the process upset.

Background

Brown and Caldwell has been conducting a treatment process and capacity evaluation for the Sewer Authority Mid-Coastside (SAM) to evaluate long term improvements to the process and supporting SAM through the recent rehabilitation of Aeration Tank 3 with fine bubble diffusers. The Aeration Tank 3 work was completed and brought on-line at the end of May 2021. There are several long-term alternatives currently under consideration by the SAM and BC Team to improve performance and increase capacity:

- Option 1- Use Aeration Tanks 3 and 4 – Add diffusers, piping, instrumentation, foam sprays and rehabilitate the weir gates in Basin 4.
- Option 2- Use Aeration Tanks 1,2, and 3 –Replace the coarse bubble diffusers with fine bubble diffuser in Tanks 1 and 2, add new weir gates, install new baffle walls in Tanks 1 and 2.
- Option 3- Operate tanks 2 and 3 in series, converting tank 2 into an anaerobic biological selector zone followed by an aerobic zone to help with filament control. Install fine bubble diffuser and mixer and baffle wall in Tank 2. Provide flow distribution modifications to the Tank 2 effluent side so that flow goes back into the mixed liquor channel and it flows to basin 3. Additionally, to add redundancy Basin 4 would also be outfitted.



- Option 4 – Operate Tanks 2 and 3 in series as in Option 3, and use tank 1 as an equalization basin. Provide modifications in primary effluent channel to allow higher flows to overflow into Basin 1 and install return pumps in basin 1 to pump out during low diurnal flow periods.

While undertaking this study the SAM wastewater treatment plant experienced a condition of poor settling in the secondary clarifiers and decreasing Mixed Liquor Suspended Solids (MLSS) in early June 2021.

SAM requested BC to assist in evaluating the immediate problem and to help identify mitigation measures. BC sent an operations subject matter expert (SME), Mr. Lance Salerno to the site June 09, 2021, June 16, and June 21, 2021 accordingly.

Section 2: Results

2.1 Aeration Basin MLSS and SVI (5/30-6/21)

After the changeover to fine bubble diffuser in aeration basin 3 was completed in May, the MLSS continued to increase to 2,320 mg/L as of June 4, 2021 with an associated SVI of 226 mL/gm. After this point the MLSS decreased daily, settleability decreased and the associated SVI increased rapidly for the next four days even though the plant was reducing wasting. Aeration basin MLSS reached a low of 1,228 mg/L on June 8th. A profile of MLSS and SVI are shown in Figure 1.




Figure 1. MLSS and SVI (May 30-June 21, 2021)

Field observations by plant staff and initial microscopic exam indicated high amounts of filamentous growth and bulking conditions causing the poor settling. The secondary sludge blanket readings indicated poor compaction with between zero and two feet of heavier good settling sludge and an increased dispersed layer that reached up to fourteen feet on June 15. During this period, a second final settling tank was brought online by plant operations to help with maintaining effluent quality, which helped for a few days. After that, the plant ended up with two clarifiers with dispersed and bulking blankets. This resulted in a low aeration



basin sludge retention time but a high mean cell retention time, with most of the sludge inventory in the secondary clarifiers. Wasting concentrations were very low as the sludge was not compacting sufficiently to waste sufficient mass out of the secondary clarifiers. The plant adjusted wasting from 8 hours during the day to a 14-hour cycle overnight, to increase the duration and volume of wasting. Waste sludge was pumped to an out of service aeration tank and fed to the rotary drum thickener during the day.

Normally the plant adds a maintenance dose of chlorine, however, the bulking event still occurred. Due to the dramatic decrease in MLSS and potential concerns about over chlorination, chlorine addition was stopped for a few days, without benefit to reducing the filaments. After that, the dose was increased to as high as 10 pounds of chlorine per 1,000 pounds of MLSS at the RAS for several straight days, again without benefit to reducing filaments. Once the MLSS began to increase after June 15, a chlorine dose was maintained at about the historical maintenance level of 3-4 pounds per 1,000 pounds of MLSS.

Due to suspected bio-inhibition or toxicity to the biomass, the plant began adding daily supplemental seed using a proprietary product called EBS Biostar™ on June 15, 2021 at a dose of five gallons per day. EBS Biostar™ is a dry concentrated form that contains a wide spectrum of both aerobic and facultative bacteria plus enzymes.

Since beginning addition of the product, the MLSS has continuously increased, SVI steadily decreased and wasting volumes are approaching normal, however, settling was still impaired. As of the June 21 time frame, plant operations microscopic examination reports the same O21N filament in abundance, with an increase amount of normal floc and an increase in the number of free swimmers.

2.2 Microscopic Examination of the Activated Sludge

Aeration basin mixed liquor samples were collected and sent to two separate Micro Labs for analysis to confirm the type of filament present and evaluate root cause. Results from both laboratories are provided in Appendix A. Both laboratories identified the predominant filament as type O21N. This type of filament can be caused or proliferate with conditions of septicity, nutrient imbalance and/or low D.O. Type O21N has been reported as sometimes being highly resistant to chlorination. Plant microscopic exams did not indicate any fracturing of the filaments when dosing went up to 10 pounds per 1,000 pounds of MLSS, which is on the high side of the range of what can be added to an aeration basin. Doses at these levels or higher are risky as it can potentially impact the good bacteria.

A higher extra polymeric substances (EPS) value of 23% was reported by the lab report, which may indicate nutrient deficiency. However, higher EPS can also result from toxicity such as over-chlorination. An initial soluble phosphorus analysis was conducted with the microorganism test and reported almost no available soluble ortho-phosphate indicating possible deficiency. However, a test on the cells estimated that sufficient phosphorus was present in the actual biomass; thus the results were not clear.

Ferric chloride which is known to precipitate phosphorus is dosed at the influent to the plant and is not flow paced at the headworks, so there is the potential to overdose or underdose at times of the day due to the diurnal variability in flow. Ammonia, organic nitrogen, total and ortho-phosphate are not tested by the plant in the process, thus there is insufficient information to comment on whether actual nutrient imbalance relates to the O21N observations. Testing of nutrients in the future for the primary effluent and secondary effluent has been identified and the plant will be implementing ammonia testing accordingly. It is recommended that the plant implement testing for primary effluent and secondary effluent filtered total phosphorus and ortho-phosphorus on a regular basis.



2.3 Polymer

Since the chlorination was not effective to control the filaments, use of polymer was implemented. The plant has not historically used polymer for settling, so the polymer product typically used to thicken the waste activated sludge in the rotary drum thickener was used as an immediate measure. Dosing was attempted at several locations, including the aeration influent and the secondary center ring; however, dosing and mixing was not optimal. A temporary addition location in the aeration tank effluent channel was selected for polymer addition as it has high turbulence and drops to a pipe and comes up through the bottom of the secondary clarifier providing an opportunity for increased contact time and flocculation.

A representative from the polymer provider, Polydyne came out to the site on June 16, 2021 to screen various wastewater polymer products to help with settling. A high charge high molecular weight polymer product was identified that provided clearer supernatant relative to the current polymer product at a dose as low as 2.5 ppm and seemed to be optimal at a jar test dose of 4 ppm. Figure 2, below, shows a picture from the polymer testing, after about 20 minutes of settling.




Figure 2. Polymer jar testing.

The doses identified in jar testing are relatively high for secondary polymer addition, without specialized mixing equipment, and the application dose should be verified based on full scale application. A recommendation is to initially target a lower dose of 1 to 2 ppm on full scale, and slowly increase based on observed performance as it benefits settling. Once excess polymer is observed on the surface and/or benefits to settling diminish, the application dose should be reduced.

A settleometer test was conducted using aeration sludge from before the polymer addition point and after polymer addition, and plant reported a 30-minute settleometer test that improved from about 950 mL/L settled in 30 minutes without polymer to 350 mL/L and an SVI of 119 mL/gm with the existing polymer. A target dose of about 2 ppm polymer from a 0.6 percent make-up solution in the day tank was in use at the time. These observations suggest that polymer addition results in a significant improvement in settling. It is recommended that the plant continue to conduct settleometer tests with and without polymer. This will help track if there is improvement in the settling without polymer and when it can be reduced or discontinued.

The new polymer product and a temporary blending unit to make up the polymer is expected the week of June 21, 2021. It will be dosed on an as-needed basis to help settling and discontinued once it is no longer needed.

2.4 Septicity Evaluation

Type O21N and various other filaments grow with conditions of septicity are present due largely to the associated sulfides and organic acids. There were several sources of septicity identified during conversations with plant staff and steps taken to address the area to the extent possible. These include:

- There is a rather large collection system with several pump stations. The distances and dry weather were identified as potential sources of septicity formation. The pump stations are known sources, and two of them have sodium hypochlorite that is added. We visited one pump station, Princeton Pump Station, and noticed an excess amount of grease buildup in the wet well. As grease and associated fatty acids can lead to filamentous growth, cleaning the pump stations regularly was identified as a step that can be taken towards mitigating septicity. The plant also identified that sampling was conducted recently to try and identify the potential source of the upset. While the data was not provided as part of this study, a particular sample was reported with a very high level of BOD. Since filaments grow very rapidly, it is recommended to repeat sample any locations above a normal level of constituents to assess whether there may be a source system in the system that needs to be addressed.
- Bubbles, which are characteristic of degassing, have been observed in the primary clarifiers early in the morning. Historically, it was reported that two primary clarifiers were used during dry weather and three during wet weather. Three primary clarifiers were in service at the time the event started. The process team reviewed model predictions and confirmed that under normal dry weather conditions only two primary clarifiers are needed. The plant removed one of the three primary clarifiers in service to decrease the hydraulic retention time and associated potential for septicity formation, particularly during low flow periods of the day.
- To evaluate septicity sources, a surrogate screening parameter was tested by measuring oxidation reduction potential (ORP) at several locations in the plant. ORP was tested at several locations in the plant using a pre-calibrated rental ORP probe and meter to help rapidly screen whether there are potential sources of septicity and whether there could be steps taken to control it. Table 1 summarizes the data from one snapshot in time collected on June 21, 2021 at about 11:00 AM, which is a time during relatively higher diurnal flows. The lowest measured ORP values were at the bottom of the aeration basin near the effluent weir. However, the dissolved oxygen (DO) in the tank was 3.4 mg/L at the deepest point to 4.3 mg/L closer to the surface that while reduced conditions may be present, there is still measurable dissolved oxygen (DO) throughout. This could indicate a heavier layer of organic material towards the bottom creating reduced conditions and should be checked. This could be evaluated using a portable TSS meter to check whether there is a layer of sludge near the bottom creating organic acids that could lead to filaments. There was at least one or two locations in the aeration basin where excessive bubbling was observed, which is indicative of a loose or broken diffuser.

Table 1. ORP and DO Data from 6/21/21				
Headworks	Primary Effluent	Aeration Effluent	Belt Filter Press Filtrate	Secondary Clarifier #1/ #2
ORP -90 mv	PST 3 ORP -83 mv PST 2 ORP -90 mv	ORP -58 mv (3 feet) ORP -150 mv (near bottom)	ORP -110 mv	Outer portion bottom: ORP -134/-148 mv Center Well: -134/-139 mv
DO 4.0 mg/L	PST 3 DO 2.7 mg/L PST 2 DO 2.6 mg/L	DO 4.3 mg/L (near surface) DO 3.8 mg/L (in-situ probe) DO 3.4 mg/L (near bottom)	D.O. 7.0 mg/L	Outer portion bottom: DO 2.0 /1.8 mg/L Center Well: 2.0 mg/L/ -

Section 3: Summary and Recommendations

Summary

The bulking event of early June 2021 was the result of poor settling caused by excessive growth of a filamentous bacteria identified as O21N. There are various causes of O21N that are commonly described as septicity, nutrient deficiency and/or low dissolved oxygen. Whether the root cause of the actual event was transient or persistent cannot be determined at this time based on the information available. This is based on the observation that the poor settling event was accompanied by a rapid decrease in aeration mixed liquor concentration, reduced good floc formation, decrease in free swimming micro-organisms and a reduction in BOD₅ removal performance, indicating that it may have been an inhibitory or transient event that caused the O21N to proliferate. However, even though growth has returned to normal and settling has improved, the filaments are still present indicating that the activated sludge treatment system is still vulnerable to a recurrence.

Septicity is one potential cause of O21N proliferation. Septicity is potentially generated in many areas of the collection system and the wastewater plant. The collection system was not evaluated, however, it is a known source of odors (and associated septicity), and any steps that can be taken to mitigate septicity are prudent.

The plant is considering adding a product to the headworks to help reduce septicity. While it has not been evaluated, a trial period with close observation is supported. Primary clarifiers operations were modified to reduce the number in service to reflect the dry weather operating conditions. The recently modified aeration basin should be checked to evaluate whether there is a layer of sludge beneath the diffuser, and if so, whether the upwelling observed is due to a broken diffuser(s).

A potential area for septicity and risk in the plant has been the sludge inventory in the secondary clarifiers associated with the very deep blankets, which far exceeded the mass in the aeration basin during the upset period. The plant should continue to use wasting and filament mitigation to reduce the amount of inventory in the secondary clarifiers, then return to only one in service.

As an addendum to the onsite study, as of June 22 and June 23, plant data indicate that settling has continued to improve and blankets have decreased to 0.5 feet in one clarifier and 2.5 feet in the second clarifier. While settling has improved it is suggested to continue to be proactive with wasting and polymer addition



until filaments are back to historical normal levels and observations confirmed by a laboratory that specializes in advance microscopic examinations and filament identification.

3.1 Recommendations

Since the root cause of the filaments has not yet been identified, the following recommendations are made holistically to continue proactive mitigation efforts to evaluate septicity, nutrients and process operations considerations. The numbering is for convenience only.

Septicity Related Recommendations

1. Reduce number of in-service primary settling tanks from three to two during dry weather flows. Complete.
2. Check the aeration basin total suspended solids concentration near the bottom of the tank using a handheld TSS meter.
3. Check the aeration basin for broken diffusers in locations of upwelling and replace/repair as necessary. Since the plant is on one aeration basin currently and DO is being maintained at or above set-point, this may not be a near term activity, but should be considered pending the outcome of the TSS evaluation.
4. Remove accumulated surface grease on the pump stations on a regular basis (e.g., annually).
5. Follow-up on elevated BOD observed in the collection system until a source is identified.
6. Continue to collect and evaluate ORP data, aqueous sulfides and organic acids (VOAs) periodically to assist in efforts to reduce septicity in the overall collection and treatment system.
7. Return secondary clarification to one secondary clarifier, after the process stabilizes, and minimize blanket levels to less than 2 feet at all times.
8. The plant has identified a product (from Aquafix) used with septic influent wastewater and filament problems to help freshen up the influent entering the plant and reduce septicity. The goal of the product is consistent with the current situation, however, this product was not and the plant will need to work out dosing and details with the provider directly.

Nutrient Related Recommendations

9. Flow pace the chemically enhanced primary treatment (CEPT) chemicals. Until this is complete, reduce the amount of ferric chloride, if possible, with close evaluation and monitoring of digester sulfides.
10. Test for filtered total phosphorus and ortho-phosphorus in the primary effluent and the secondary effluent on at least a weekly basis.
11. Begin testing primary effluent and secondary effluent for ammonia nitrogen when nitrite and nitrate samples are collected. Evaluate the RDT side stream and filter press side stream for nutrients and COD.
12. Avoid operating the RDT and Filter Press at the same times, and alternate days if possible, to help mitigate surges of nutrients back to the aeration tank.

Process Related Recommendations

13. Identify a polymer, addition and storage system that can be used to aid settling on an as necessary basis.



14. Conduct daily settleometer testing before and after polymer addition.
15. Establish a methodology for conducting jar testing to optimize the polymer dose, if necessary.
16. Continue to waste sludge over as long a period as possible to mitigate rapid swings in mixed liquor concentration during the day.
17. Maintain a lower chlorine addition rate to the RAS, and only add if necessary.
18. Continue to add a bio-augmentation product until the activated sludge process stabilizes. Maintain supplemental bio-augmentation product at the plant in the event a future recurrence happens involving reduced or no growth of aeration biomass. The EBS Biostar™ bio-augmentation product showed effective performance. Sources of seed sludge from nearby municipalities may also be considered but need to be vetted in advance for compatibility.
19. Conduct external micro-biology examination on a regular (e.g., weekly) basis until the activate sludge process fully stabilizes and filaments are reduced to normal levels.
20. Increase the DO setpoint from 3.2 mg/L to the extent possible, while the secondary blankets are deep (4' or greater) to reduce possibility of organic acid formation.





Microbiology Laboratory Reports





**Activated Sludge Microbiological and Chemical Evaluation
Sewer Authority Mid Coastline (SAM)
Half Moon Bay, CA
June 15, 2021**

Purpose:

The following report provides data, pictures, and comments regarding the analysis of two samples (MLSS and RAS) collected from the Sewer Authority Mid Coastline wastewater treatment plant (WWTP) in Half Moon Bay, CA. An EBS employee was contacted due to an issue surrounding solids carryover from the secondary clarifier. The samples were collected on June 15th, 2021 and received by the EBS laboratory in Mandeville, LA, the following day. The samples underwent microscopic examinations with filament identification, advanced microbiological analyses, and chemical analyses. Comments regarding sample analysis can be found below. Appendices A, B, and C containing tables, photos, and the EBS reference guide, are attached to this report.

Executive Summary:

- After a thirty-minute settling test, neither the MLSS or RAS sample settled.
- Filament abundance was observed in excessive amounts in both the MLSS and RAS samples. This level of filaments is likely creating the issues with settling and compaction.
- The filaments present showed no observable effects from recent chlorination efforts.
- Extracellular polymeric substances (EPS) made up 23% of the volatile suspended solids. Elevated EPS concentrations can also negatively impact sludge settleability.
- Our analysis determined the phosphorus percent in biomass to be 3.0%, indicating the biomass has sufficient phosphorus.
- While there was a sufficient percentage of phosphorus in the biomass, there was virtually no residual orthophosphate present.

Results and Discussion

- There are a few environmental conditions that can exist which prevent the bacterial solids from settling and compacting well in a secondary clarifier. First, a low concentration of solids could inhibit settling as there is not a critical mass. This is needed to form a proper sludge layer. Secondly, high levels of filamentous bacteria and/or polysaccharide production can physically inhibit the floc from forming larger, more dense pieces that would hopefully settle well leaving behind a low solids in the clarifier overflow. These samples exhibited all three traits: a low solids, elevated levels of EPS and an overgrowth filamentous bacteria.
- The sludge did not settle after the thirty-minute settling test but did eventually settle some after six hours. The supernatant collected after the extended settling was low in solids. The SVI values calculated for both the thirty-minute and extended settling were above the expected 75-150 mg/L range and indicate bulking conditions.
- When analyzing a sample for filamentous bacteria, filament abundance and effect on the floc are two important parameters that are taken into account. EBS employs a filamentous rating scale of 0 to 6. No filaments would be ranked at a 0 while an excessive amount will be rated a 6. Excessive filament proliferation can sometimes be attributed to several environmental conditions, such as nutrient conditions, retention time, and the constituents of the incoming BOD. Some species of filaments can be associated with specific environmental conditions. It is also important to keep in mind that it is not so much the abundance of filaments that can cause bulking issues, but it is their effect on the floc that can negatively impact sludge settleability. During our analysis of this sample, we observed the filaments at an excessive level (6 out of 6). Filaments were observed growing well beyond the floc pieces creating a bridging effect. This creates large open spaces between the floc and prevents it from being able to compact into larger, more dense pieces. The two identified filaments were *Type 021N* and *S. natans*. These filaments are typically both associated with low nutrient content, low DO, and septic conditions and soluble readily-metabolizable substrates (SRMS). SRMS are substrates that are easy for the bacteria to biodegrade such as fatty acids, simple sugars, and starches,.
- Extracellular polymeric substances (EPS) are high molecular weight compounds excreted by microorganisms and stored into their external cell walls. EPS is mostly composed of polysaccharides and proteins but also consists of DNA, lipids, humic substances, and cations. The EPS test is run to determine how much of these substances are present in the volatile solids and then normalized to the MLVSS and expressed as a percentage of the biomass. Zoogloea bacteria are a species of bacteria that tend to excrete high levels of these polysaccharides. Conditions such as low pH, low nutrients, and low oxygen availability or chlorination can stress the Zoogloea bacteria and cause them to produce excessive levels of polysaccharides as a defense mechanism. As with filaments, the level of production can affect the system's performance. A moderate amount can be beneficial as it encourages the floc to stick together. However, an overabundance can produce high levels of hydrophobic layers that prevent the floc from forming compact pieces and disrupt settling. EPS measured at 23% in the MLSS and 28% in the RAS sample. Although this value is higher than what we typically see in other systems, without historical data, it is difficult to say what is normal for this system.

- Total Phosphorus in the MLVSS was measured by subtracting the filtered nutrient value from the unfiltered nutrient value then normalized to the mixed liquor volatile suspended solids (MLVSS). Sufficient nutrients ensure the bacteria have the ability to perform important functions without leaving behind high levels of residual nutrients that may carry over into the final effluent. In most municipal wastes, nitrogen is often available while phosphorus can be the limiting factor. Based on our results, the Total Phosphorus was measured at 3.0% in the MLVSS which suggests the system is not phosphorus limited. One thing to point out is most of the phosphorus was measured in the unfiltered sample which includes the concentration that bacteria have taken up rather than in the soluble "bio-available" form in the bulk water.
- Microscopically, the floc appeared to be mostly pin to small with some medium size pieces having fairly compact centers with large open areas caused by the excessive filaments. Dispersed bacteria were observed in a low amount and often signal that BOD conversion is near complete. Once the food source has been depleted, the bacteria will floc together to conserve energy instead of staying active in the bulk water.
- The identification and enumeration of higher life forms can demonstrate the health and maturity of a wastewater treatment system. EBS employs a Maturity Index, which is a weighted average of the higher life form distribution with a target range of 1.5-2.5. Systems with a high microorganism abundance and diversity indicate that BOD conversion is likely to complete. The overall environmental conditions must be stable and non-toxic, as higher life forms are very susceptible to changes in the environment. There was a good diversity of higher life forms observed in this sample. A maturity index rating of 2.9 was assigned for the MLSS sample as there were many free-swimming and stalked ciliates observed. Their presence indicates a non-toxic environment existed during the time of sample collection. Consistent monitoring of these higher life forms is suggested as they can quickly help determine if any major shifts in the environment have occurred.
- Bioflocculation potential is a set of tests that measure the potential for good floc formation. Mixed Liquor Surface Charge (MLSC) and Hydrophobicity are two characteristics that can impact the density of the floc. Mixed Liquor Surface Charge (MLSC) is a test that measures the available charge on the bacteria. The reported range for good floc formation should fall between -0.150 to -0.600 meq/g. This indicates there is enough charge available to the floc to form larger pieces of floc. Hydrophobicity comes into play after surface charge forces have brought the floc together. It is a measure of the ability of the floc to force water out of the pore spaces. The higher the relative hydrophobicity, the more compact the floc should be. Typically, good floc has a hydrophobicity index of greater than 80%. The results for this sample indicate the floc has enough available charge to form a compact floc. However, the hydrophobicity measured 68% in the MLSS and 66% in the RAS sample.
- The pH is also a very important parameter in wastewater. The recommended range for optimal bacterial health is 6.5-8.5. Any fluctuations outside of this target can be detrimental to the bacterial population, resulting in a hindered rate of BOD remov-

al. This sample measured a pH of 7.2, which is in the middle of the suggested range.

Report prepared by:
Christina Dietzen
Environmental Specialist
dietzen@ebsbiowizard.com

Appendix A
Table 1: Analytical Data

Basic Chemistry	MLSS	RAS
pH	6.9	6.9
MLSS (mg/L)	1125	1575
MLVSS (mg/L)	1075	1450
MLVSS (%)	96%	92%
30 Minute Settling (mL/L)	1000	1000
30 Minute SVI (mL/g)	889	635
Six hour Settling (mL/L)	250	267
Six hour SVI (mL/g)	222	170
Turbidity (NTU) after six hours of settling.	5	5
Nutrient Content		
Total P Unfiltered (mg/L)	33	
Total P Filtered (mg/L)	0.2	
P in MLVSS (%)	3.0%	

Table 2: Basic Microscopic Evaluation

Basic Microscopy	MLSS	RAS
Floc Structure	Some pin, Small to Medium size floc. Fairly compact	Some pin, Small to Medium size floc. Fairly compact
Dispersed Bacteria (0-3)	0.5	0.5
Pin Floc (0-3)	1.0	1.0
Filament Rating (0-6)	6.0	6.0
Zoogloal Bacteria (0-3)	0.5	0.5
India Ink Stain (0-3)	1.5	1.5
* Floc Size (μm) - Pin (<75 μm), Small (75-150 μm), Medium (150-500 μm), Large (>500 μm)		

Table 3: Higher Life Form Distribution

Higher Life Forms	MLSS	RAS
Flagellates	2	1
Free-swimming/Crawling Ciliates	4	5
Stalked Ciliates/Suctorians	73	38
Rotifers/Chaetonotus	0	0
Nematodes/ Oligochaetes	0	1
Maturity Index	2.9	2.8

Table 4: Filamentous Bacteria Abundance and Causes

MLSS and RAS Filament Types & Causes	H ₂ S and/or septicity	Mature Biomass	Nutrient Deficiency	SRMS*	Low F:M	Low DO
1. <i>Type 021N</i>	X	X	Esp(N)	X		
2. <i>S. natans</i>			Esp (P)	X		X


*Soluble readily-metabolizable substrates (SRMS): substrates that are easy for the bacteria to biodegrade.

Table 5: Advanced Microbiology


Biofloculation potential	MLSS	RAS
EPS		
EPS (mg/L)	250	407
EPS in MLVSS (%)	23%	28%
Surface Charge		
Mixed Liquor Surface Charge (meq/g)	-0.651	-0.465
Hydrophobicity		
Relative Hydrophobicity (%)	68%	66%

Appendix B

MLSS Photos:




100X phase contrast, wet mount. Some pin, small to medium size floc.




400X phase contrast, wet mount. Closer look at the MLSS with excessive amounts of filaments.

RAS Photos:




100X phase contrast, wet mount. Note the bridging occurring between floc pieces.




400X phase contrast, wet mount. Closer look at the RAS sample.

India Ink Photos:




400X phase contrast, India Ink. A moderate level of polysaccharides were measured in the MLSS sample during the india ink stain.




400X phase contrast, India Ink. The RAS sample was also observed having a moderate amount of polysaccharides.

Higher Life Form Photos:




400X phase contrast, wet mount. Basin 2-3. Stalked ciliates.

Filamentous Bacteria Photos Continued:




1000X phase contrast, wet mount. *Type 021N* was the most common filament observed.




1000X phase contrast, wet mount. *S. natans* has sausage shaped cells.

Filamentous Bacteria Stain Photos:



1000X bright field, Gram stain. MLSS All filaments stained Gram negative.



1000X bright field, Neisser stain. All filaments stained Neisser negative.

Appendix C

EBS Reference Guide

Term	Description	Activated Sludge Target Range
30 Minute Settling Test	This test is used to determine the settled sludge volume of mixed liquor samples in activated sludge systems.	
Biochemical Oxygen Demand (BOD)	The quantity of oxygen required by bacteria to biologically oxidize organic material under aerobic conditions, usually expressed in mg/L. The organic matter serves as food for the bacteria and energy is released to the cell during its oxidation.	
Bioflocculation	The act of bacteria excreting exocellular polymeric substances that are sticky in nature that allow small floc to come together forming large floc.	
Chemical Oxygen Demand (COD)	The amount of oxygen required for the chemical oxidation of organic material using chemicals as oxidants, usually expressed in mg/L.	
Culturable Bacteria	Bacteria that are able to grow and reproduce using a basic plating technique.	
Culturable (Viable) Cell Count	Cell count based on the bacteria in the system that are capable of reproducing and BOD degradation.	10 ⁵ -10 ⁸ CFU/mL
Deflocculation	The physical or chemical act of breaking up larger floc into pin floc and dispersed bacteria.	
Dissolved Oxygen Uptake Rate (DOUR)	A test that measures the respiration rate of the biological organisms in a wastewater sample by measuring the rate at which oxygen is used in mg O ₂ /L/Hr.	
Exocellular Polymeric Substances	Substances that are “sticky” in nature produced by bacteria and aid in floc formation. The percentage of EPS in a system typically exceeds 12% outside of the pulp and paper industry and are typically run on activated sludge systems.	8-12%
Filamentous Bulking	Occurs when filamentous bacteria rapidly grow and hinder the settling of sludge or inhibit settling completely.	
Hydrophobicity	Used to determine the hydrophobicity of the biomass. A more hydrophobic biomass should form tighter floc and will not trap as much water in the pore space.	
India Ink	Used to determine the presence and abundance of polysaccharides. It is rated on a scale of 1(low), 2(abundant), and 3(excessive). Polysaccharides aid in floc formation.	
Live Cell Count	Cell count based on the bacteria in the system that are live/actively respiring and are capable of BOD degradation using flow cytometry.	Varies

EBS Reference Guide Continued:

Term	Description	Activated Sludge Target Range
Maturity Index	The maturity index is a numerical value derived to estimate the health and maturity of the sludge based upon the higher life form population. It is calculated by multiplying specific higher life forms by a designated number and dividing by the total number of higher life forms present.	1.5-2.5
Mixed Liquor Surface Charge	The surface charge of the biomass affects the flocculation process and floc stability, which can further affect the settleability and dewaterability. The surface charge is affected by C/N ratio, sludge age, ion balance, etc. The reported surface charge range is -0.15 to -0.60 meq/g MLSS, and a surface charge value closer to the middle of this range indicates optimal health of the sludge. However, this may be system-specific.	-0.15 to -0.60 meq/g
Mixed Liquor Suspended Solids (MLSS)	The concentration of insoluble materials suspended or dispersed in water or wastewater. Generally expressed in mg/L on a dry weight basis and determined by filtration methods.	Varies
Mixed Liquor Volatile Suspended Solids (MLVSS)	The quantity of organic or volatile solids that will burn off when heated to 550° C for 30 minutes.	
Nutrients	Substances that are required to support living plants and organisms, including carbon, hydrogen, oxygen, sulfur, nitrogen, and phosphorus. Nitrogen and phosphorus are commonly fed to wastewater to enhance its treatability. A theoretical nutrient balance of 100:5:1 (C:N:P) is required for efficient biological oxidation of BOD. Supplemental nutrients are sometimes required in nutrient poor waste streams.	
Sludge Volume Index (SVI)	A value used to determine the settling properties of the sludge based on the amount of MLSS in the sample. This number is derived using the 30 minute settling test and MLSS.	75-150 mL/g
Soluble Readily-Metabolizable Substrates (SRMS)	Soluble readily-metabolizable substances are simple sugars and starches that are easily processed as food by bacteria.	
Specific Oxygen Uptake Rate (SOUR)	Measures use of oxygen as a terminal electron acceptor. This value is derived by multiplying the DOUR value by the VSS in grams/L.	
Supernatant TSS	This test measures the total amount of suspended material, organic or inorganic matter, in the supernatant collected after 30 minute settling.	<50 mg/L
Total Cell Count	Cell count based on all the bacteria in the system, dead or alive, using flow cytometry.	Varies

EBS Reference Guide

Maturity Index Example:

Indicator Group	Point Value	Number Observed in 10 Fields	Group Points (Point Value x Number Observed)
Flagellate/Naked Amoeba	1	18	18
Crawling Ciliate/Free Swimming Ciliate	2	15	30
Stalked Ciliate/Suctorian	3	5	15
Rotifer/Chaetonotus	4	3	12
Nematode	5	4	20
Total for Maturity Index		45	95
Maturity Index		(Group Points) / (# Observed) (95) / (45) = 2.1	

References:

Daigger, G., Jenkins, D., & Richard, M. (2004). *Manual on the Causes and Control of Activated Sludge Bulking, Foaming, and Other Solids Separation Problems, 3rd Edition*. Boca Raton, FL: CRC Press LLC.

Eikelboom, D.H. (2000). *Process and Control of Activated Sludge Plants by Microscopic Investigation*. London: IWA Publishing.

Water Environment Federation (2001). *Wastewater Biology: The Microlife, 2nd Edition*. Alexandria, VA: Water Environment Federation.

For more information regarding laboratory analysis or testing, please contact:

Danielle Sharp
 Chemistry & Microbiology Lab Coordinator
 sharp@ebsbiowizard.com
 (985) 674-0660 ext. 130



AQUAFIX^{Inc.}

*Innovations in
wastewater treatment.*

1.888.757.9577 • www.teamaquafix.com • bugman@teamaquafix.com

1

TECHNICAL UPDATE

Date: 06/14/2021
To: Sewer Authority Mid-Coastside
Sample(s): Influent ML, Influent Foam, Effluent ML and Effluent Foam
Date Received: 06/10/2021
Date(s) Analyzed: 06/10/2021
Sample Analyzed By: Deborah Lee, Aquafix
Objective: Determine cause of poor settling and high TSS.

Microscopic Observations Influent ML




Figure 1. 100X magnification (m): The Influent ML sample contained low colonies of stalked ciliates and overall medium levels of stalked ciliates. There were also low to medium levels of swimming ciliates.




Figure 2. 100X (m): There were high levels of filaments outside of the floc in the Influent ML sample. These filaments are long and can promote inter-floc bridging, which will increase sludge volume and lead to sludge bulking.

Visit us on the web!

www.teamaquafix.com




Figure 3. 400X (m), Phase contrast: The flocs in the Influent ML sample were mostly small (<100um) and condensed. There were medium levels of very large floc (>500um). The average floc size was 119.14um and white in color indicating good oxygen penetration. This is expected with small flocs that are not very dense. There were also high levels of free bacteria in this sample.




Figure 4. 400X (m), India ink stain: The floc in the Influent ML sample overall had medium levels of extracellular polymeric substances (EPS) in the condensed areas. EPS is a glue-like substance that allows bacteria to stick together to produce floc. Medium levels of EPS are necessary to produce floc with a strong structure that can withstand shear force.




Figure 5. 1000X (m), Gram Stain: There were high levels of Type 021N present in the Influent ML sample. Type 021N grows in environments with septic compounds, low DO, and/or low levels of usable nitrogen.




Figure 6. 1000X (m), Gram Stain: The Influent ML sample contained medium levels of *S. natans*/Type 1701 (arrows). *S. natans*/Type 1701 is found in environments with septic compounds, low DO, and high BOD loading.

Visit us on the web!

www.teamquafix.com

Microscopic Observation Influent Foam




Figure 7. 100X (m): The Influent Foam sample was similar in composition to the Influent ML sample. this indicates that the foam is composed of small floc and other light particles being pushed to the water-air interface.




Figure 8. 400X (m), Phase contrast: There were also high levels of free bacteria in this sample (glowing spots) along with the mentioned small flocs and filaments of Type 021N growing free in the bulk liquid. Type 021N is known to sometimes form a slimy scum at the surface of aeration basins when this filament becomes abundant.




Figure 9. 1000X (m), Gram Stain: There were high levels of Type 021N (red filaments) in the Foam sample and medium levels of Nocardia-like filaments (arrow). Nocardioforms are known to cause foaming when present in high levels.




Figure 10. 1000X (m), Gram Stain: As with the Influent ML sample, the Influent Foam sample had low to medium levels of *S. natans*/Type 1701 (arrows).

Visit us on the web!

www.teamquafix.com

Microscopic Observation Effluent ML



Figure 11. 100X (m): The Effluent ML sample was similar to the Influent ML samples but have had more branched filaments free in the bulk liquid. There were also low levels of nematodes present (not shown).



Figure 12. 100X (m): The Effluent ML sample also contained floc that were mostly small in size with an average diameter of 114.96μm. There were also high levels of filaments mostly free in the bulk liquid.




Figure 13. 400X (m), Phase contrast: The small flocs in the Effluent ML were white in color indicating good oxygen penetration. This is expected with small flocs that are not very dense. There were also high levels of free bacteria and free small clusters of branched filaments in this sample.




Figure 14. 400X (m), India ink stain: The Effluent ML flocs had mostly areas of medium levels of EPS with a few condensed areas with high EPS. There was possibly oil in this sample since the bulk liquid excluded the stain in some areas and there may have been a few oil droplets observed.

Visit us on the web!

www.teamquafix.com




Figure 15. 1000X (m), Gram Stain: There were medium to high levels of Type 021N mostly observed outside of the floc structure in the Effluent ML sample.




Figure 16. 1000X (m), Gram Stain: There were high levels of *S. natans*/Type 1701 (arrows) observed extending from the flocs in the Effluent ML sample.

Microscopic Observation Effluent Foam




Figure 17. 100X (m): The Effluent Foam sample contained stringy solids of mostly small to medium sized flocs and high levels of filaments free in the bulk liquid.




Figure 18. 400X (m), Phase contrast: There were also high levels of free bacteria (bright dots) present in the Effluent Foam sample.

Visit us on the web!

www.teamquafix.com



Figure 19. 1000X (m), Gram Stain: The Effluent Foam was much like the Influent Foam with high levels of Type 021N and low to medium levels of *S. natans*/Type 1701.




Figure 20. 1000X (m), Gram Stain: The Effluent Foam sample had medium levels of Nocardia-like branched filaments. There may have been slightly more Nocardioforms in this sample than the Influent Foam sample.

Summary:

Overall the cause of bulking and high TSS is due to the excessive growth of filaments such as Type 021N that can form a scum in aeration basins. There were also filaments within the floc structure that may cause the floc to break apart into smaller units as the filaments grow outward. This will result in a high amount of small flocs that will not settle and also in high levels of free bacteria in the effluent. It is possible that low levels of useable nitrogen are the cause of excessive growth of Type 021N in this system.


There were medium levels of Nocardia-like filaments observed in the floc and a little free in the bulk liquor. These branched filaments are known to cause foaming, however in this system, the Nocardia-like filaments may be mostly contributing to floc breakup as the filaments extend and become more buoyant. The resulting smaller flocs will be too light to settle during normal settling times and will contribute to higher effluent TSS. There were low to medium levels overall of *S. natans*/Type 1701 extending from the medium sized flocs and may indicate septicity or periodic high BOD loading.

The sludge age of the Sewer Authority ML was on the older end in both the Influent and Effluent ML samples. There were colonies of stalked ciliates present, Nocardioforms which can grow in low to medium amounts with old sludge age, and low nematodes observed.

(The red shaded area in the diagram below represents the effective sludge age of the Sewer Authority ML samples)

Visit us on the web!

www.teamquafix.com



Influent ML

Rank	Filament	Relative Abundance	Cause
1	Type 021N	High	Septic compounds, low N, low DO
2	Nocardioforms	Medium in floc	FOG, long MCRT
3	<i>S. natans</i> /Type 1701	Medium	Low DO, septic compounds, high BOD load

Influent Foam

Rank	Filament	Relative Abundance	Cause
1	Type 021N	High	Septic compounds, low N, low DO
2	Nocardioforms	Medium in floc	FOG, long MCRT
3	<i>S. natans</i> /Type 1701	Low - Medium	Low DO, septic compounds, high BOD load

Effluent ML

Rank	Filament	Relative Abundance	Cause
1	<i>S. natans</i> /Type 1701	High	Low DO, septic compounds, high BOD load
2	Type 021N	Medium - High	Septic compounds, low N, low DO
3	Nocardioforms	Low	FOG, long MCRT

Effluent Foam

Rank	Filament	Relative Abundance	Cause
1	Type 021N	High	Septic compounds, low N, low DO
2	Nocardioforms	Medium in floc	FOG, long MCRT
3	<i>S. natans</i> /Type 1701	Low - Medium	Low DO, septic compounds, high BOD load
4	Type 0675/0041	Low	Low F:M

Visit us on the web!

www.teamquafix.com

Add for filaments:

<https://teamaquafix.com/common-wastewater-filaments/#021N>

<https://teamaquafix.com/common-wastewater-filaments/#1701>

<https://teamaquafix.com/common-wastewater-filaments/#nocardioforms>

Recommendations:

- If there are long sewer lines leading to the plant, it is recommended to meter in OxyFresh along the lines to decrease the amount of septicity coming into the plant. If septic is being accepted, OxyFresh could also be added directly into the influent at the same time. OxyFresh is an easy to apply liquid micronutrient that promotes metabolic activity of aerobic bacteria.
- If possible, waste out the small flocs and filaments. If wasting is not possible, add SmartBOD into the aeration basin. SmartBOD contains bioavailable sources of amino acids, complex proteins, carbohydrates, and micronutrients that bacteria in biological wastewater processes require in order to build floc and effectively remove nutrients.
- It is recommended to add Accelerator VII, a fast-acting source of amino acids and micronutrients, into the aeration basin to promote the growth of floc-forming bacteria over filaments such as Type 021N.

Visit us on the web!

www.teamaquafix.com



SEWER AUTHORITY MID-COASTSIDE

Staff Report

TO: Honorable Board of Directors

FROM: Kishen Prathivadi, General Manager

DATE: August 23, 2021

SUBJECT: **Authorize General Manager to Issue a Purchase Order to Environmental Dynamics International for the Design, Supply and Installation of Diffusers to Aeration Basin 4**

Executive Summary

The purpose of this report is for the Board of Directors to discuss and authorize the General Manager to issue a Purchase Order to Environmental Dynamics International for the design, supply, and installation of diffusers to Aeration Basin 4.

Fiscal Impact

The cost is \$219,400 and was included in the FY 21-22 budget.

Strategic Plan Compliance

The recommendation complies with the SAM Strategic Plan's Vision: "*Utilize state of the art technologies and management practices to advance public health and environmental protection.*" It also complies with the Strategic Plan's Goal 5: Infrastructure, Operations and Maintenance: "*The goals are no spills, safety, environmental protection, reliability, and long-term cost effectiveness.*"

Background and Discussion/Report

In late September and early October of 2020, SAM WWTP experienced abnormally high Biochemical Oxygen Demand (BOD) levels in its influent. These BOD levels stressed plant processes and resulted in the discharge of non-compliant effluent by the plant. SAM hired Brown and Caldwell (BC) in March 2021 to complete a wastewater treatment plant capacity assessment and operations evaluation. This request was in response to

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

high influent biochemical oxygen demand (BOD) loading events that occurred in October 2020 that may have contributed to process upsets at the SAM WWTP. BC initiated the work by conducting an on-site kickoff meeting on March 30, 2021 to discuss project objectives. Immediately after the kickoff meeting, BC conducted a visual assessment of the secondary treatment facilities. Over the next three weeks, BC reviewed the historical flow and loading data and past treatment performance as a basis for determining existing treatment capacity of the primary and secondary treatment processes. BC presented this information to SAM staff on May 17, 2021 and conducted a more detailed operations assessment to further confirm process capacity. BC concluded that, using industry-standard assumptions for estimating process capacity along with the information obtained during the operations assessment, that the WWTP did not have adequate capacity to treat current flow and loading with only Aeration Basin 3, and that additional modifications should be constructed to increase the capacity at the WWTP. Four Alternatives were presented to the Board on July 26, 2021, of which the recommended option was Alternative 1.

Alternative 1 is to Outfit Aeration Basin 4 with fine bubble diffusers to match Aeration Basin 3 and operate both aeration basins 3 and 4 in parallel. This was the recommended alternative. This was chosen as it provides most redundancy and does so at the lowest estimated cost. Additionally, the construction period would have minimal impacts on the existing treatment process and provides more flexibility in treatment.

Therefore, Staff obtained a proposal from Environmental Dynamics International for the design, supply, and installation of diffusers to Aeration Basin 4. Staff had earlier retrofitted Aeration Basin 3 with EDI diffusers and would like to retain the same manufacturer for Aeration Basin 4 for ease of availability of spare parts and servicing etc. The lead time for delivery of the diffusers is 12-14 weeks and it is important that we place the order as soon as we can.

Staff Recommendation

Staff recommends the Board authorize General Manager to issue a Purchase Order to Environmental Dynamics International for the design, supply, and installation of diffusers to Aeration Basin 4 in an amount not to exceed \$219,400.

Supporting Documents

Attachment A: Proposal from Environmental Dynamics International

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	



**Environmental
DYNAMICS INTERNATIONAL**
A *Nexom* BRAND



HALF MOON BAY, CA

Preliminary Proposal for
Design, Supply and Installation of
the Wastewater Treatment System
Upgraded with FlexAir™ Aeration

Proposal # cd9018.01

August 10, 2021

aeration for life™

5601 Paris Rd, Columbia, MO 65202
+1 573 474 9456 | www.wastewater.com

Table of Contents

Project Overview.....	2
System Design Parameters	3
Diffuser Selection.....	4
Budgetary Capital Cost.....	5
Questions or Comments?	8

Project Overview

Environmental Dynamics International (EDI) is pleased to offer the FlexAir Aeration-Mixing System for Aeration Basin #4 at the Half Moon Bay CA facility. EDI is offering the fine bubble aeration system including all in-basin aeration components with installation and start-up services by EDI SiteWorks, EDI's construction division. SiteWorks is a licensed contractor in the state of California (License # 9911995).

The following is the detailed scope of work to be supplied by EDI:


INCLUDED IN OVERALL SCOPE OF SUPPLY

- Aeration system design submittal and shop drawings
- Installation, start-up, commissioning, and initial training
- 1- year warranty from startup (or 18 months from shipment, whichever comes first)
- Operation & Maintenance Manuals
- Shipping to jobsite



HALF MOON BAY, CA
CD9018.01

2 of 10



System Design Parameters

EDI understands that the existing Aeration Basin #4 requires upgraded diffused aeration.

Basin sizes are presented in the following table:

	Basin #4
Basin Dimensions- each Basin (ft)	88.5 x 30
Side Water Depth (ft)	17


Quantity of diffusers for each option is presented in the following table:

	Basin #4
Diffuser	9" Standard Disc
# of Diffusers for each Basin	1,344



HALF MOON BAY, CA
CD9018.01

3 of 10



Diffuser Selection

FlexAir™ 9" ISM Disc Diffuser



The 9" disc diffuser has a glass-fiber reinforced SuperStrut body for maximum chemical, temperature, and UV resistance. This diffuser offers a triple check valve design which minimizes entry of liquid/solids into piping. Integral Saddle Mount provides ease of installation and maintenance with maximum mechanical strength. Patented EZ-Seal™ for quick membrane installation.



HALF MOON BAY, CA
CD9018.01



Budgetary Capital Cost

Design, Supply, Installation, and Start-up of all in-tank FlexAir™ aeration equipment required to make a fully functioning system (as per specifications and drawings) after the flange and including all in-water components as follows:

AERATION BASIN #4

Scope of supply listed for one basin (total of one basin included in proposal):

- 1 14" x 8" 304L Stainless Steel Yard Piping. Includes support system, flanged connections at all field joint, and stainless steel flange fasteners.
- 2 8" Lug Style Butterfly Valve for grid isolation.
- 2 8" 304L Stainless Steel Drop Pipe. Drop pipe provided with flanged top connection and plain end bottom. The drop pipe is to be supported by the contractor such that no downward force is transmitted to the aeration piping system.
- 2 8" 304 Stainless Steel Coupling. Coupling joins plain ends of SS drop and PVC manifold.
- 2 8" Schedule 40 PVC Air Distribution Manifold Assembly. Assembly provided factory assembled and shipped in sub-assemblies. Assembly includes flanged connections at all field joints, flanged header connections and stainless steel flange fasteners.
- 32 3" SDR 26 PVC Lateral Assembly. Assembly provided factory assembled and shipped in sub-assemblies. Assembly includes flanged connections at all field joints, diffuser outlet ports, end cap and stainless steel flange fasteners.
- Lot 304 Stainless Steel Pipe Support for air manifolds. Anchor bolts included.
- Lot SuperStrut Pipe Support for air laterals. Anchor bolts included.
- 1,344 FlexAir Disc Diffuser Assembly. Diffuser assembly provided factory assembled. Assembly includes disc holder, membrane, and retainer ring.
- 2 Purge system.

Note: Yard piping to be anchored atop concrete wall between basins 3 and 4 and will terminate and tie into the existing yard piping that feeds Basin #3. Please see preliminary



HALF MOON BAY, CA
CD9018.01

5 of 10

sketch for proposed layout. Header layout is preliminary and will need review and confirmation after clarification of scope.

MANUFACTURER SERVICES

- Lot Installation of aeration components listed above according to manufacturer specifications and directions.
- Lot Start-up, leak check, and commissioning of supplied equipment as per specifications as long as water and air are available to tanks. Owner to provide water and electrical energy for air.

PROPOSAL NOTES

1. Receiving/off-loading and secure on-site storage of all equipment is by others.
2. Proposal assumes one mobilization and demobilization to complete the work as defined above. Additional mobilizations can be purchased for an additional charge.
3. Proposal assumes that the basins are accessible to the crews upon arrival and will be de-watered, cleaned, and ready for equipment installation.
4. Proposal assumes access into the tank, either by hatchway and/or ladder(s) is provided by others.
5. Proposal assumes that the tanks are open-topped and the area around the tanks is open and free of powerlines, guide wires, etc. so that the tanks can be accessed by machinery during installation.
6. Proposal assumes that the tank floor is flat and constructed from concrete for support system anchorage.
7. The personnel that will be onsite have multiple training and safety certifications, including those in OSHA, Confined Space, and H2S. However, additional site-specific safety training or procedures have not been included. Please notify EDI if there are site-specific safety requirements.
8. Proposal includes California State Prevailing Wages for the project area in San Mateo County CA. Should these wages not be required, please return proposal for revised pricing.
9. Delays and downtime resulting from actions or occurrences beyond the control of SiteWorks may be subject to a change order.



HALF MOON BAY, CA
CD9018.01

6 of 10

BUDGETARY PRICING for the design and supply of the following as described in the scope of work above:

- 1 Aeration Basin (#4) Aeration Equipment
- Manufacturer installation of above items
- Manufacturer start-up of above items

\$ 219,400 USD taxes not included (FCA shipping allowed to jobsite)

NOTE: See EDI Standard Terms & Conditions attached to this proposal.

QUOTE VALIDITY

Note that the quote being provided will be in effect only for a period of 30 days. Should the company be awarded a purchase order during that 30-day period, it is understood that shipment of the product will be allowed within a period of 180 days from the date of the purchase order. Should the goods not be required to be delivered until after that time horizon, the company reserves the right to adjust pricing to reflect inflationary changes incurred and expected until the shipment date is reached.

PAYMENT TERMS

Requests for extended financing beyond the Net Terms indicated below will be quoted based upon the payment terms being requested at the time of order placement.

- TBD

TYPICAL EQUIPMENT LEAD TIME / DELIVERY

Shop drawings / submittals would be completed within 6-8 weeks after confirmation of order. Approximate delivery times of major components after submittal approval:

- Aeration Equipment 12-14 weeks
- Installation to be scheduled in conjunction with shipment of materials.


SHIPPING

Please note that a freight surcharge may be added based on any increases in freight charges or packing materials from the quoted value provided herein to the actual value at the time of shipment. Freight transit time is an estimation as per the information provided by carriers. Delays may happen that are beyond our control. We assure our customers that every effort will be done as to help the delivery of the cargo on time.



HALF MOON BAY, CA
CD9018.01

7 of 10



Questions or Comments?

Any questions or comments can be directed to:

Scott Hentges
Regional Aftermarket Account Manager

scott.hentges@wastewater.com
+1 573-507-5170

Greg Roppelt
Regional Sales Manager

greg.roppelt@wastewater.com
+1 573 507-5128



Environmental Dynamics International, A Nexom Brand

edi.marketing@wastewater.com
+1-573-474-9456

5601 Paris Rd. · Columbia MO · 65202
www.wastewater.com

This proposal has not been published and is the sole property of Environmental Dynamics International. It is lent to the borrower for his/her confidential use only. In consideration of this loan, the borrower promises to return it upon request and agrees that it shall not be reproduced, copied, shared, lent, or otherwise disposed of, directly or indirectly, nor used for any purpose other than that for which it is specifically furnished.



HALF MOON BAY, CA
CD9018.01

8 of 10

MANUFACTURERS LIMITED MECHANICAL WARRANTY STATEMENT

The warranty provided by Environmental Dynamics International Inc., (EDI) is limited to the terms set forth in this Warranty Statement. All other warranties, expressed or implied are excluded and disclaimed in their entirety. EDI gives no other warranty of any kind, nature or description, expressed or implied, other than the limited warranties set forth herein, and this warranty exclusion includes but is not limited to warranties of merchantability and warranties of fitness for a particular purpose, both of which are excluded and disclaimed in their entirety. Equipment manufactured by EDI is warranted to be free from defects in materials and workmanship as applicable;

- (a) Standard twelve (12) months from start-up of the equipment or eighteen (18) months from shipment, whichever occurs first

Defective part(s) shall be remedied by repair or replacement of the defective part(s) only shipped freight included, FOB original shipping point¹. Costs incurred by EDI (on or off site)² shall be reimbursed by the Purchaser / Owner³ should EDI find a deficiency to not be due to equipment covered by this warranty.

The following are excluded from this warranty, but shall not be considered to be limiting to other exclusions: cleaning and de-watering, labor⁴, equipment manufactured by others⁵, process and performance related to system design or biological process performance, decomposition, abnormal wear and/or damage caused by site conditions; chemical action, chemical precipitate, physical abrasion points or abrasive materials, water velocities greater than 2 ft/sec or as approved by EDI, blunt trauma forces, faulty or substandard structural components, faulty or inadequate maintenance/operation⁶, equipment and services provided under a contract which is in a current state of default due to non-payment.⁷ EDI exclusively assumes no responsibility of expense or liability for (a) equipment repairs made or contracted by Purchaser or Owner without EDI's written consent; (b) modifications to any of EDI's equipment made by others which are not approved in advance and in writing by EDI; (c) failure of the Owner to promptly notify EDI of observed defects and or deficiencies which occur during the warranty period (d) work by others⁸, (e) field modifications to allow for removal or replacement of EDI components

END OF PROPOSAL

¹ FOB original shipping point; indicates the point of which risk of loss passes

² Cost incurred include shall not be limited to; travel, housing, labor and materials; that have been expended to research and repair such deficiency.

³ Responsible party for the equipment at the time of the warranty claim; generally dictated by project status, pre (Purchaser) or post (Owner) project hand over.

⁴ Accessing/uninstalling/replacing/reinstalling any parts.

⁵ EDI does not warranty equipment manufactured by others. "By others" includes but is not limited to: blowers, DO probes, electrical panels, engines, motors, any electrical apparatus, etc. Such equipment bears warranties of the respective manufacturers. Labor costs associated with warranty repairs of equipment manufactured by others shall be borne by others.

⁶ Please refer to your EDI IO&M manual for maintenance and operation instructions.

⁷ Default due to non-payment shall not include EDI approved holdbacks.

⁸ Work by Others shall include but not be limited to; materials furnished, or labor provided by any contractor, subcontractor or material supplier not working directly for or directly under EDI.



HALF MOON BAY, CA
CD9018.01

9 of 10

EDI STANDARD CONDITIONS OF PROPOSAL AND SALE OF EQUIPMENT

Environmental Dynamics International, hereinafter also referred to as EDI or the Company, offers this proposal to supply equipment. Any resulting contract between EDI and the Purchaser shall be subject to the following terms and conditions.

Services - Environmental Dynamics International is a manufacturer of water and wastewater treatment equipment and systems. EDI is not a consulting engineering firm and does not provide Professional Engineering services as part of our contracts to supply equipment hardware.

Process and Performance Warranties - Contracts for purchase of equipment accepted by EDI exclude any process or performance warranties related to system design. Additionally, no biological or process performance warranties are expressed or may be implied by the participation of EDI in this contract. Any biological or process performance warranty for systems supplied by the Company shall be specifically and independently detailed and signed as a separate contract by an authorized Officer of the Company.

Governing Law - Any proposal for equipment supply made by the Company as well as any contract between the Company and the Purchaser are deemed to be executed at Columbia, Missouri, USA, subject to correction for typographical or mathematical errors and governed by Missouri law.

Credit Approval - Performance of any contract by the Company is contingent upon Purchaser credit approval. Credit may be waived in lieu of a project materials payment bond. A materials payment bond supplied to the project Owner or Engineer by the Purchaser is acceptable. EDI reserves the right to hold shipment on delinquent accounts.

Force Majeure - Strikes, fires, accidents, war, reduced supply of fuel or raw materials or excessive cost thereof, or other restraints affecting shipments or curtailments in manufacturing or due to delays unavoidable by or beyond the control of the Company shall be governed by *force majeure*.

Costs and Damages - The Company shall in no instance be liable for indirect or special costs, consequential or liquidated damages or any penalties outside the written contract.

Special Hazards - Unusual conditions such as rock, poor foundation soils, excess water or other unusual site or safety conditions are not covered by this standard Company proposal. Extra costs emanating from unusual site or safety conditions shall be negotiated with written agreements developed at or subsequent to the time of discovery and prior to further work being completed by EDI.

Shipment & Delivery Times - Statements as to expected date of hardware shipment represent the Company's best judgment, but shipment on those dates is not guaranteed. The Purchaser hereby waives all claims to damages caused by delay in shipment or delivery of hardware.

Insurance - The Purchaser agrees to provide and maintain for the benefit of the Company adequate insurance for the equipment herein specified from the time of its shipment from EDI until paid for in full and the Purchaser agrees to assume all loss over and above that compensated for by such insurance. The Purchaser shall procure and pay for all public liability insurance during the installation of any EDI provided equipment.

Title of Ownership - All equipment and/or services ordered by Purchaser from the Company shall remain the property of the Company until fully paid for in cash.

Cancellation or Suspension - of any order will be accepted only upon terms that will indemnify the Company against loss. Additionally, the Company may invoice the Purchaser 15% of the agreed upon contract price.

Back Charges - must be approved by EDI, in writing, before they will be accepted. EDI will make every effort to offer prompt consideration and approval of legitimate back charges.

Invoicing - The Company may make partial billings of the contract price as various components of the equipment are shipped. When equipment is manufactured by EDI, but shipment is delayed by the Customer, EDI shall be paid in accordance with contract terms as though delivery had been accomplished.

Storage Charges - When EDI manufactures equipment to meet schedules established by the Purchaser, the Company reserves the right to invoice the Purchaser for storage charges on items held at EDI at the rate of 1% per month of the sale price.

Default for Non-Payment - Contracts in default of the payment terms may be subject to any or all of the following; should the Purchaser fail to pay the purchase price as agreed the Company may, a) retain as liquidated damages all partial payments made on account thereof to date without prejudice to any other claim for damages suffered by the Company for any cause, b) be allowed site access to recover hardware, c) obtain other balances due from arbitration or d) an interest charge on outstanding invoices billed at the rate of 1.5% per month, 18% per annum.

Attorney Fees - For any suits brought or retainage paid to attorneys to collect any part of the purchase price or to enforce any provision herein, the Purchaser will pay EDI attorney fees and related expenses including an administrative fee equal to the attorney fees.

Bankruptcy, Receivership or Insolvency Proceedings - Should bankruptcy, receivership or insolvency proceedings be instituted by or against the Purchaser or should the Purchaser make an assignment in favor of creditors, the unpaid balance of the purchase price shall immediately become due and payable at the option of the Company. Notwithstanding other arrangements to the contrary, the Company shall be free to enter premises where equipment for which the Company has not been fully paid may be located and remove said equipment as its property without prejudice to any further claims on amounts of damage which the Company may suffer from any cause.

Promissory Note - Acceptance of a promissory note or other evidence of debt for any part of price shall not be construed as payment.

Patent infringement - Any interference with Purchaser's use of equipment supplied by the Company on the grounds that such use constitutes an infringement of any patent shall impose no liability on the Company.

Spare or Potential Warranty Parts - If spare parts or potential warranty parts are required immediately, EDI may ship those parts subject to the following limitations: a) Purchaser agrees to pay for additional components or spare components including special freight charges. Reimbursement will be issued as a credit to the Purchaser's account in the event potential warranty parts are verified as actual warranty defects and b) Contract price adjustments or price adjustments on additional or spare components are subject to EDI approval and original contact terms.

Defective, damaged, improper material or shortage - Claims will not be allowed unless written notice specifying the nature and extent of the defect, damage or shortage is received in the Company's office within fourteen (14) days from unloading - unless the defect, damage or shortage is of such a nature that it would not be reasonably discovered until the material is assembled and/or erected as a finished product, then the fourteen (14) days will begin from the date of commencement of assembly and/or erection.

Mechanical Warranty - As per Manufacturers Limited Mechanical Warranty Statement

Accepted by Buyer:

Date

Accepted by Seller / Environmental Dynamics International Inc.

Date



HALF MOON BAY, CA
CD9018.01

10 of 10



SEWER AUTHORITY MID-COASTSIDE

Staff Report

TO: Honorable Board of Directors
THROUGH: Kishen Prathivadi, General Manager
FROM: Tim Costello, Supervisor of Technical / Field Services
SUBJECT: **Monthly Manager’s Report – July 2021**

Executive Summary

The purpose of this report is to keep the Board and public informed of SAM’s day-to-day operations.

Fiscal Impact

There is no fiscal impact from this report.

Strategic Plan Compliance

The recommendation complies with the SAM Strategic Plan Goal 5.5: *“Operations and maintenance should be proactively planned, and the Board shall be kept up to date on progress on operations and maintenance issues.”*

Background and Discussion/Report

The following data is presented for the month of July 2021.

Key Indicators of Performance

NPDES Permit Violations:	10
Accidents, Injuries, etc.:	0
Reportable Spills Cat 1:	0
Reportable Spills Cat 2:	0
Reportable Spills Cat 3:	0

Flow Report (See Attachment A)

Half Moon Bay	0.910	66.2%
Granada CSD	0.243	17.7%
Montara W&SD	0.221	16.1%
Total	1.374	100%

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

Administration

There were two Board Meetings, and no public records requests in the month of July 2021. There was one article in the Half Moon Bay Review, “Districts spend combined \$700,000 on sewer dispute, July 7, 2021. There has been no lost time work accidents since September 10, 2019. There were no new hires, and two anniversaries in the month of July, Kishen Prathivadi, General Manager, and Felipe Preciado, Collections Worker I.

Operations & Maintenance

The following permanent flow storage installations are in place and functioning properly.

Montara Pump Station – Walker Tank, which has a capacity of 434,000 gallons.

The Portola Station – Wet Weather Facility, which has a capacity of 200,000 gallons. Phase two of this project is complete now giving us an additional 200,000 or a combined total available storage volume of 400,000 gallons at this location.

The Portola Pump Station has the ability to use the Wet Weather Facility as a modified equalization basin if needed, (without mixing it is not ideal for this use) or as wet weather flow storage as originally designed.

We thought we were doing better until July rolled around in regards to process issues, sampling continues to be accelerated as the issues are persistent.

Right at the beginning of the month things started going pear shaped again. The MLSS concentrate began to drop and would not recover, we went from a concentration in the 2200 mg/L range down below 500 mg/L. It was clear that we were not treating properly both by results and visual observations. To say everyone was tired and frustrated is an understatement. We are trying multi pronged approaches to correct what is going on but it seems we are mostly in a reactive state treating the symptoms and unable to pinpoint the cause.

We sent samples in to EBS on the 14th, 19th and 27th this month in a continued effort to try to figure what is going on with the process. Along with input from process specialist from B & C and product enhancements we are trying to get things functioning properly.

These are bullets from the reports; A significant decrease in solids was measured in comparison to the 6/30 analysis. This is likely due to the recent upset and confirms the low solids numbers observed on-site. A slight increase in filament abundance in both

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

the MLSS and RAS samples was observed since last analysis. This abundant level is likely hindering sludge compaction and settle ability. The high percent of EPS measured in the MLVSS can also attribute to a poor settling sludge. This value has steadily increased since the 6/15 sample.

Filament abundance remains consistent with last analysis at an abundant level in the MLSS sample. The types of filaments present remain unchanged.

Advanced analytical data measured a significant amount of dimethyl benzyl ammonium compounds in the influent which could cause inhibition when bio-accumulated. Despite the elevated levels of Quaternary Ammonium Compounds (QAC), a significant portion is removed in the primary clarifiers. QACs are often associated with solids so a high removal rate is expected in the clarifiers. If primary treatment were to fail, the system could run the risk of coming in contact with these QACS in the MLSS and becoming inhibited over time. However, this does not appear to be occurring at this time.

Our results show an increase in the MLSS concentration up to over 1400 mg/L. This represents a 140% increase in MLSS since the 7/14 sample. However, the MLVSS has only increased 100% during the same time period, so a large increase in solids is due to inert (non-biomass) solids.

Filament abundance slightly increased and is now rated at a 5.5 out of 6 level. This indicates there are more than 20 filaments per piece of floc.

Foaming issues were reported as being observed on-site prior to this sample collection. The abundance of Actinomycetes has not changed since last week.

Due to a shortage an industry shortage with Ferric chloride we needed to do some jar testing to find an alternative that will work for us. Aluminum Chloride appears to have good results so we will likely be switching early next month.

Due to the high sample numbers we did have NPDES exceedances for both TSS, EFF BOD and percent removal. The BOD and TSS sample points had weekly and monthly exceedances. The Percent removal is monthly average for both the BOD and TSS and we fell below on both this month.

I have been openly communicating with Mr. Burrell at the state to be sure he is kept in the loop of what we have going on and our continuing struggles. I also like to keep an open line of communication so that I don't miss anything on reporting.

In regards to exceedances this month it looks like I will be reporting a total of ten, four weekly EFF TSS, one monthly EFF TSS, and one for the percent removal. We had two weekly BOD's, one monthly BOD, and one for percent removal.

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

The goats were on property in July as part of the weed abatement program. Approximately 300 goats were used for grazing July 11 - July 15, 2020 (5 days). We will have the full SWCA report in the next meeting.

During the month of July 2021, rainfall was below normal for Half Moon Bay. The 10-year average for the area is 0.105 inches of rain in July, this web link has some very useful data for our area, <https://ggweather.com/hmb/> . We did get some rainfall to report for the month of July, but it was minimal at best. Rainfall totals were as follows: 0.11 inches at the treatment plant, 0.11 inches in the GCSD service are, and 0.31 inches at the MWSD weather station. Below the 10 year average still, much like the last few months. There were micro-climate variations verified by the data.

Below is a chronological summary of some of the occurrences during the month of July 2021.

- 7/1/2021 – Poly to MLSS eff, Adding Oxi fresh, work on portable poly unit, phone discussion with EBS environmental regarding most recent lab testing, different type of filament .
- 7/2/2021 – Adding poly to MLSS basin still to help with the settling problem, the filaments seem to be causing the problem and are not improving. Adding the Accelerator & product and the Smart BOD to help the process. Still experiencing bulking in the secondary's, adding chlorine directly to the foam to address the filaments. Started filling secondary number 2
- 7/3/2021 – Adding poly to MLSS still, add enhancements to MLSS basin to promote growth of biology, bulking continues to worsen.
- 7/4/2021 – Poly to MLSS still, adding enhancements to MLSS to promote biology growth, Bulking continues to worsen, shut down Portola to use as an EQ basin
- 7/5/2021 – SAM Holiday, adding Poly to MLSS still, adding enhancements to MLSS to promote biology growth, shut down Portola again to act like an EQ basin of sorts, still bulking
- 7/6/2021 – Poly to MLSS still, adding enhancements to MLSS to promote biology growth, bulking again, secondary # 2 online, working to balance flows through tanks to minimize lack of settling. Not good, we are doing what we can to minimize issues.

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

- 7/7/2021 – Poly to MLSS still, adding enhancements to MLSS to promote biology growth, bulking again, Process meeting with Lance (process specialist) Lance has been working with the new polymer we got to try to see if he can figure out the best dose rate, we are having not so good luck with this newer product.
- 7/8/2021 – Poly to MLSS still, we are not seeing the desired effect with this new polymer, we've been fighting it for a few days and the frustration level is very high, adding enhancements to MLSS to promote biology growth, filaments are continuing to still be an issue, bulking continuing.
- 7/9/2021 – Isolate secondary #2 try to waste out bad biology that is not settling and has filaments, adding enhancements to MLSS basin Smart BOD and Accelerator 7 products, also adding Bio star product as we had results with that product before. Blanket throughout water column in secondary.
- 7/10/2021 – Isolate other secondary (# 1), in attempt to remove filaments and bad biology, added enhancements to MLSS basin Smart BOD and Accelerator 7 products, also adding Bio star product, bulking still, tank isolation didn't work as we hoped it might. Using Portola as EQ to help stabilize what we have.
- 7/11/2021 – Poly doesn't seem to be working well, tried variations secondary still won't settle, no flock, added enhancements to MLSS basin Smart BOD and Accelerator 7 products, also adding Bio star product, blanket entire column in secondary, adjust hypo down to a minimal amount, it was up for the filaments, nothing seems to be working.
- 7/12/2021 – Added enhancements to MLSS basin Smart BOD and Accelerator 7 products, also adding Bio star product, still using Portola as EQ (a daily event), Call with EBS to discuss biology, bulking still, blanket throughout water column, very young biology in clarifier, primarily single cell and some free swimming ciliates.
- 7/13/2021 – Added enhancements to MLSS basin Smart BOD and Accelerator 7 products, also adding Bio star product twice a day now mixing it with water and aerating for up to 12 hours to get it even more active prior to adding to mlss, EBS says this should enhance use of product, Portola still used for EQ.
- 7/14/2021 – Added enhancements to MLSS basin Smart BOD and Accelerator 7 products, also adding Bio star product twice a day, Portola still used for EQ increasing dosage of poly to MLSS eff to secondary inf, secondary blanket throughout water column.

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

- 7/15/2021 – Added enhancements to MLSS basin Smart BOD and Accelerator 7 products, also adding Bio star product twice a day, Portola still used for EQ increasing dosage of poly to MLSS eff to secondary inf, blanket throughout water column. Adding 6 - 250 gallon totes of poly at about 0.4 % each day, that's a lot. Secondary blanket throughout water column, getting dark.
- 7/16/2021 – Adding Biostar product to MLSS basin, mixing on the front end now before applying as this is supposed to give a greater bang for the buck regarding application. Adding smart BOD and accelerator 7 to help with the whole enhancement of the MLSS basin. Have poly going to MLSS eff to assist with the settling in the secondary's, bulking is still an issue. Using Portola as a EQ basin still so we don't blow everything out the back end. Try Increasing RAS with Portola off to draw more from secondary, results questionable. Painter on site working on the #2 water building and keeping that project moving forward. Mass coordination effort ensued in order to get seed sludge delivery lined up from SVCW to our facilities, lot of people involved to make it happen I think we got the green light just before 5pm. We will be getting two loads a day of 3000 gallons each for the next five consecutive days, the concentration is about 2,700 mg/l.
- 7/17/2021 – Adding the Biostar product as well as the smart BOD and Accelerator 7. Poly going to MLSS eff for secondary bulking issue that is continuing. Received the first two loads of the seed sludge today, let's hope for the best. Still using Portola for EQ.
- 7/18/2021 – Adding the Biostar product as well as the smart BOD and Accelerator 7. Poly going to MLSS eff for secondary bulking issue that is continuing. Day two of the seed sludge today. Still using Portola for EQ.
- 7/19/2021 – Adding the Biostar product as well as the smart BOD and Accelerator 7. Poly going to MLSS eff for secondary bulking issue that is continuing. Day three of the seed sludge today. Still using Portola for EQ. Painters here working on #2 water building. Brandon on site prepping for the water pump project. Spoke with Lance ,(B &C), via phone. EBS got back to us, no significant inhibitory levels from the sample we sent from rocket farms, we will pull another and check for metals.
- 7/20/2021 – Adding the Biostar product as well as the smart BOD and Accelerator 7. Poly going to MLSS eff for secondary bulking issue that is continuing. Day four of the seed sludge today. Portola off again for EQ, Calcon working in MB2, painter here working #2 water project. Going to try stopping poly and just go with the ferric addition tonight, (consultant recommendation), started low dose CL2 to RAS, (consultant recommendation).

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

- 7/21/2021 – Adding the Biostar product as well as the smart BOD and Accelerator 7. Ferric to MLSS eff to help with bulking, did some more jar testing today going to try a ferric / poly combination to see if that helps with the settling. Meeting with the Brown and Caldwell folks about plant issues and basin evaluations. Still bulking in the clarifier, it appear to have some improvement with the poly / ferric combo.
- 7/22/2021 – Adding the Biostar product as well as the smart BOD and Accelerator 7. Lance onsite working with operator, set up both secondary's for the ferric poly combo. Still bulking but small signs of improvements.
- 7/23/2021 – Add biostar product, smart bod, accelerator 7, Jar testing alum product as we are going to run out of ferric due to supply issues on the west coast. Good results with 20 mg/L of the alum and poly combination. Application is going to be the key and decent mixing which is another hurdle we have to figure out. Floc Load was delivered today.
- 7/24/2021 – Added the Biostar product twice, once in the AM and once in the PM, added the smart BOD and the Accelerator 7 as well, blankets are 11 ft with fluff on top.
- 7/25/2021 – Added Floc Load to the MLSS basin this morning, we needed to shut off the poly addition since the combination of the floc load and the polymer can create little gelatinous gobs that can an issue. Added the Biostar product in the afternoon.
- 7/26/2021 – Came in in the morning to find Ferric line had broken at the fitting, got that repaired but not before it made a little mess and wasted Ferric that we are already short on. Added Biostar twice today morning and afternoon.
- 7/27/2021 – Lance from Brown and Caldwell in to work with the operators on process issues. Added Biostar product just once today. Sent off a sample to the lab for microscopic examination.
- 7/28/2021 – Lance here working with operators again, meeting with the operations team to discuss progress and where we are now. Still not in a great place but showing minimal signs of improvement.
- 7/29/2021 – Cleaned chlorine contact basin number one due to solids accumulation in the basin, sent the blanket portion to AB 1 & 2 for storage for now until we can dispose of it. Spoke with Lance via phone in the afternoon to discuss strategy for the weekend and pitfalls to avoid.
- 7/30/2021 – R & S Erection here to replace the back door by the lab, the transom window was rotting out and we don't want it falling on anyone. Add Bio

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

star product, Smart BOD and Accelerator 7, slight increase in the cl2 to RAS to beat down the filaments, ferric and poly to MLSS Eff, adjust ferric down at 11pm (overnight setting).

7/31/2021 – Calcon in investigating issues with W.A.S. flow metering not reading correctly, added bio star, smart BOD, Accelerator 7, 11 pm ferric adjustment for overnight.

Other activities are listed below;

There were 10 deliveries (approximately 6,300 gallons) of trucked waste discharged at the SAM Plant for a total revenue of \$ 630.00. There were no leachate deliveries to the SAM IPS line in the month of July 2021, for a total leachate volume of 0 gallons.

The NPDES data report for July 2021 is attached reference (Attachment B).

Contract Collection Services

The SAM crew cleaned 26,477 feet of sewer line and responded to eleven service calls in contract service areas. Seven were sewer line related and four were maintenance service calls. Six of the callouts were during regular business hours, and five were after hour calls. One call was in HMB, two calls were in the GCSD service area, and eight calls were in the MWSD service area.

HMB – The service call in HMB was on 7/10 for a clean out backup in the backyard. Crew arrived and flushed main finding no obstruction. Advised homeowner to contact a plumber to resolve issue.

There were no maintenance calls in HMB area during July.

GCSD – The service calls in the GCSD area were as follows; 7/8 – Call was for a slow toilet, Crew arrived and flushed main finding no obstructions. No property line cleanout to be found. Owner stated that a plumber was on the way to help resolve issue. 7/26 - Owner noticed backup at on property. Crew arrived and flushed main finding no obstruction. Unable to locate property line clean out, advised homeowner to contact plumber to resolve issue.

There were no maintenance calls in the GCSD area during the month of July.

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

MWSD – The service call in the MWSD area were as follows; 7/9 - Call for slow drains. Crew arrived and flushed main finding no obstructions. Lateral line goes through a bunch of cypress trees. Line was recently snaked out removing roots, owner said they would call out rooter company again. 7/11 - Flushed main, no obstruction. Contacted district to make sure it was not an issue with line replacements in the area. District engineer reached out to contractor to investigate. 7/19 - Call for Waterfall noise inside manhole. Crew arrived to find grease blocking the drop hole so the water was cascading from the top making the splashing noise. Removed grease and flushed main, better now. 7/21 - This is the last house on the, crew flushed the main and suggested to homeowner to periodically flush with water to make sure things are moving. Did find some construction debris in line, notify district of findings.

The maintenance service calls in the MWSD area this month were as follows; 7/7 - Airport lift station power glitch. Genny did not run, reset alarms and checked station for normal operation. 7/9 - Seal cove area, grinder pump response. Issue was on house side of grinder. Pump was replaced due to age and rotating shaft was loose from excess wear. Vault was vactored out and tested pump for proper operation. 7/20 - Date Harte lift station response. Pump #1 failed to start, motor starter tripped. Pulled pump, found shirt bound up in the volute / impeller. Removed shirt, reinstalled, checked for normal operation. 7/24 - Seal cove # 1 response. Alarm due to low battery voltage for keypad. Replace battery, cleared alarms, checked station for normal operation.

The July 2021 collection system data report is provided for the Board's information. There were no Category 1, no Category 2's, and no Category 3 SSO's during the month of July 2021.

Staff Recommendation

Staff recommends that the Board receive the Manager's Report for July 2021.

Supporting Documents

Attachment A: Monthly Flow Report July 2021

Attachment B: Monthly NPDES Report July 2021

Attachment C: Collection System Data July 2021

Attachment D: Contract Collection Service Report July 2021

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

Attachment A


Flow Distribution Report Summary for July 2021

The daily flow report figures for the month of July 2021 have been converted to an Average

Daily Flow (ADF) for each Member Agency.
The results are attached for your review.

The summary of the ADF information is as follows:

	<u>MGD</u>	<u>%</u>
The City of Half Moon Bay	0.910	66.2%
Granada Community Services District	0.243	17.7%
Montara Water and Sanitary District	<u>0.221</u>	<u>16.1%</u>
Total	1.374	100.0%



Sewer Authority Mid-Coastside


Monthly Flow Distribution Report for July 2021

<u>Date</u>	<u>HMB</u>	<u>GCSD</u>	<u>MWSD</u>	<u>Plant</u>	<u>Rain Plant</u>	<u>Rain Portola</u>	<u>Rain Montara</u>
7/1/2021	0.873	0.230	0.226	1.329	0.03	0.05	0.04
7/2/2021	0.865	0.245	0.216	1.326	0.00	0.00	0.01
7/3/2021	0.842	0.114	0.232	1.188	0.04	0.00	0.02
7/4/2021	0.906	0.281	0.217	1.404	0.01	0.01	0.02
7/5/2021	0.911	0.207	0.234	1.352	0.02	0.02	0.03
7/6/2021	1.019	0.411	0.216	1.646	0.00	0.00	0.03
7/7/2021	0.975	0.233	0.217	1.425	0.00	0.00	0.03
7/8/2021	0.878	0.233	0.220	1.331	0.00	0.00	0.00
7/9/2021	0.861	0.135	0.217	1.213	0.00	0.00	0.00
7/10/2021	0.973	0.259	0.228	1.460	0.00	0.00	0.00
7/11/2021	0.971	0.262	0.229	1.462	0.00	0.00	0.00
7/12/2021	0.865	0.204	0.223	1.292	0.00	0.00	0.03
7/13/2021	0.882	0.239	0.220	1.341	0.01	0.02	0.03
7/14/2021	0.916	0.249	0.217	1.382	0.00	0.01	0.02
7/15/2021	0.852	0.247	0.216	1.315	0.00	0.00	0.05
7/16/2021	0.882	0.187	0.216	1.285	0.00	0.00	0.00
7/17/2021	0.942	0.262	0.225	1.429	0.00	0.00	0.00
7/18/2021	0.931	0.273	0.233	1.437	0.00	0.00	0.00
7/19/2021	0.882	0.261	0.226	1.369	0.00	0.00	0.00
7/20/2021	0.878	0.235	0.221	1.334	0.00	0.00	0.00
7/21/2021	0.936	0.329	0.220	1.485	0.00	0.00	0.00
7/22/2021	0.890	0.234	0.220	1.344	0.00	0.00	0.00
7/23/2021	0.910	0.239	0.213	1.362	0.00	0.00	0.00
7/24/2021	0.945	0.264	0.221	1.430	0.00	0.00	0.00
7/25/2021	0.970	0.266	0.234	1.470	0.00	0.00	0.00
7/26/2021	0.960	0.241	0.214	1.415	0.00	0.00	0.00
7/27/2021	0.884	0.235	0.212	1.331	0.00	0.00	0.00
7/28/2021	0.902	0.231	0.220	1.353	0.00	0.00	0.00
7/29/2021	0.885	0.235	0.214	1.334	0.00	0.00	0.00
7/30/2021	0.932	0.238	0.217	1.387	0.00	0.00	0.00
7/31/2021	0.891	0.254	0.224	1.369	0.00	0.00	0.00
Totals	28.209	7.533	6.858	42.600	0.11	0.11	0.31


Summary

	<u>HMB</u>	<u>GCSD</u>	<u>MWSD</u>	<u>Plant</u>
Minimum	0.842	0.114	0.212	1.188
Average	0.910	0.243	0.221	1.374
Maximum	1.019	0.411	0.234	1.646
Distribution	66.2%	17.7%	16.1%	100.0%



Sewer Authority Mid-Coastside Monthly Flow Distribution Report, July 2021




Percent Distribution July 2021



Most recent flow calibration March 2021 PS, March 2021 Plant



Flow based percent distribution based for past year



SAM E-001 July 2021

Date	Inf TSS mg/l	Eff TSS mg/l	Eff TSS Weekly Avg	TSS % Removal	Inf BOD mg/l	I° Eff BOD mg/l	Eff BOD mg/l	Eff BOD Weekly Avg mg/l
7/1/2021	310	7.00		97.7%	390	290	7.0	
7/2/2021	220	7.50		96.6%	360	270	8.2	
7/3/2021			7.25					7.60
7/4/2021								
7/5/2021	270				360	220		
7/6/2021	290	270.00		6.9%	440	240	30.0	
7/7/2021	350	16.00		95.4%	310	260	14.0	
7/8/2021	260	34.00		86.9%	360	210	22.0	
7/9/2021	320	120.00		62.5%	360	270	83.0	
7/10/2021			110.00					37.25
7/11/2021	230	160.00		30.4%	260	220	45.0	
7/12/2021	260	270.00		-3.8%	280	270	59.0	
7/13/2021	320	280.00		12.5%	280	240	63.0	
7/14/2021	220	140.00		36.4%	350	260	73.0	
7/15/2021	270	62.00		77.0%	450	270	75.0	
7/16/2021	280	110.00		60.7%	440	260	100.0	
7/17/2021			170.33					69.17
7/18/2021	340	180.00		47.1%	290	220	50.0	
7/19/2021	270	220.00		18.5%	470	250	79.0	
7/20/2021	320	130.00		59.4%	220	210	18.0	
7/21/2021	290	330.00		-13.8%	370	240	180.0	
7/22/2021	310	280.00		9.7%	250	210	170.0	
7/23/2021	310	86.00		72.3%	300	250	50.0	
7/24/2021			204.33					91.16
7/25/2021	260	120.00		53.8%	520	360	76.0	
7/26/2021	300	55.00		81.7%	580	350	53.0	
7/27/2021	260	34.00		86.9%	400	300	25.0	
7/28/2021	260	25.00		90.4%	450	330	23.0	
7/29/2021	240	27.00		88.8%	300	260	23.0	
7/30/2021	280	25.00		91.1%	350	250	27.0	
7/31/2021			47.67					37.83
Count	25	24	5	24	25	25	24	5
Minimum	220	7.00	7.25	-13.8%	220	210	7.0	7.6
Average	282	124.52	107.92	56.0%	366	260	56.4	48.6
Maximum	350	330.00	204.33	97.7%	580	360	180.0	91.2
Percent Removal				85				
5 Sample Median								
High								
Low								
Daily Max								
Weekly Max			45					45
Monthly Average		30					30	

SAM E-001 July 2021

Date	BOD % Removal	Eff Settleeable Matter mg/l	Eff Settleeable Matter Weekly Avg mg/l	Eff Turbidity NTU	Eff Turbidity Weekly Avg NTU	Chlorine Residual Day Max
7/1/2021	98.2%					0.00
7/2/2021	97.7%					0.00
7/3/2021						0.00
7/4/2021						0.00
7/5/2021						0.00
7/6/2021	93.2%	160.0		110		0.00
7/7/2021	95.5%	ND		8.3		0.00
7/8/2021	93.9%					0.00
7/9/2021	76.9%					0.00
7/10/2021			80.00		59.15	0.00
7/11/2021	82.7%					0.00
7/12/2021	78.9%					0.00
7/13/2021	77.5%					0.00
7/14/2021	79.1%	ND		75.00		0.00
7/15/2021	83.3%	ND		40.00		0.00
7/16/2021	77.3%					0.00
7/17/2021			ND		57.50	0.00
7/18/2021	82.8%	180.00		90.00		0.00
7/19/2021	83.2%	140.00		110.00		0.00
7/20/2021	91.8%					0.00
7/21/2021	51.4%					0.00
7/22/2021	32.0%					0.00
7/23/2021	83.3%					0.00
7/24/2021			160.00		100.00	0.00
7/25/2021	85.4%					0.00
7/26/2021	90.9%	10		20.00		0.00
7/27/2021	93.8%	3.0		34.00		0.00
7/28/2021	94.9%					0.00
7/29/2021	92.3%					0.00
7/30/2021	92.3%					0.00
7/31/2021			6.50		27.00	0.00
Count	24	5	3	8	4	31
Minimum	32.0%	3.0	< 6.50	8.30	27.00	0.0
Average	83.7%	98.60	82.17	60.91	60.91	0.0
Maximum	98.2%	180.0	160.0	110.00	100.00	0.0
Percent Removal	85					
5 Sample Median						
High						
Low						
Daily Max				225		4.8
Weekly Max					100	
Monthly Average				75		

SAM E-001 July 2021

Date	Chlorine time Minutes	Ammonia Nitrogen Distilled mg/l	Eff pH	Eff Temp	Enterococci MPN	30 day geo mean	Eff DO mg/l	Eff DO % Saturation
7/1/2021	0.00		7.16	20.6			6.99	77.5
7/2/2021	0.00		7.24	20.6			6.60	73.5
7/3/2021	0.00		7.17	20.4			7.19	79.8
7/4/2021	0.00		6.94	21.0			6.90	77.3
7/5/2021	0.00		7.03	20.5			6.46	71.5
7/6/2021	0.00		7.12	20.4			6.58	72.8
7/7/2021	0.00	37.0	7.04	19.8	ND		6.98	76.3
7/8/2021	0.00		7.19	20.1			6.86	75.8
7/9/2021	0.00		7.16	20.0			7.14	78.7
7/10/2021	0.00		7.20	19.9		< 10.00	6.88	75.8
7/11/2021	0.00		7.19	20.4			6.15	68.0
7/12/2021	0.00		7.24	20.0			5.33	58.1
7/13/2021	0.00		7.20	20.2			5.38	59.0
7/14/2021	0.00		7.17	19.6			6.27	68.5
7/15/2021	0.00	35.0	6.99	20.0	20		5.83	64.0
7/16/2021	0.00		7.18	19.8			5.62	61.4
7/17/2021	0.00		7.17	19.8		< 10.00	5.89	64.4
7/18/2021	0.00		7.23	20.5			5.46	60.6
7/19/2021	0.00	36.0	7.35	20.3	ND		5.74	63.3
7/20/2021	0.00		7.21	20.2			6.04	66.5
7/21/2021	0.00		7.19	20.1			6.13	67.6
7/22/2021	0.00		7.07	20.2			5.95	65.6
7/23/2021	0.00		6.99	20.1			6.75	74.3
7/24/2021	0.00		6.97	20.1		< 10.00	7.13	78.7
7/25/2021	0.00		6.99	20.6			6.23	69.2
7/26/2021	0.00		6.80	20.4			6.48	71.7
7/27/2021	0.00	36.0	7.26	20.9	ND		6.49	72.6
7/28/2021	0.00		7.01	20.5			6.83	75.9
7/29/2021	0.00		6.97	20.8			7.17	80.3
7/30/2021	0.00		7.03	20.0			7.10	78.3
7/31/2021	0.00		7.02	20.7		< 10.00	6.90	76.8
Count	31	4	31	31	1	4	31	31
Minimum	0.00	35.0	6.80	19.6	< 20	< ND	5.33	58.1
Average	0.0	36.0	7.11	20.3	< 20	< 10	6.43	71.1
Maximum	0.00	37.0	7.35	21.0	20	< 10.0	7.19	80.3
Percent Removal								
5 Sample Median						2,800		
High			9					
Low			6					
Daily Max					8,300			
Weekly Max								
Monthly Average								

Sewer Authority Mid-Coastside

Monthly Collection System Activity/SSO Distribution Report, July 2021

July 2021

	Total	<i>Number of S.S.O's</i>			
		HMB	GCSD	MWSD	SAM
Roots	0	0	0	0	0
Grease	0	0	0	0	0
Mechanical	0	0	0	0	0
Wet Weather	0	0	0	0	0
Other	0	0	0	0	0
Total	0	0	0	0	0

12 Month Moving Total

	Total	<i>12 month rolling Number</i>			
		HMB	GCSD	MWSD	SAM
Roots	1	0	0	1	0
Grease	0	0	0	0	0
Mechanical	0	0	0	0	0
Wet Weather	0	0	0	0	0
Other	1	0	0	1	0
Total	2	0	0	2	0
		0%	0%	100%	0%

Reportable SSOs

	Total	<i>Reportable Number of S.S.O.'s</i>			
		HMB	GCSD	MWSD	SAM
July 2021	0	0	0	0	0
12 Month Moving Total	2	0	0	2	0

SSOs / Year / 100 Miles

	Total	<i>Number of S.S.O.'s /Year/100 Miles</i>			
		HMB	GCSD	MWSD	SAM
July 2021	0.0	0.0	0.0	0.0	0.0
12 Month Moving Total	1.9	0.0	0.0	7.4	0.0
Category 1	0.0	0.0	0.0	0.0	0.0
Category 2	0.0	0.0	0.0	0.0	0.0
Category 3	1.9	0.0	0.0	7.4	0.0
Miles of Sewers	104.5	37.0	33.2	27.0	7.3
		35.4%	31.8%	25.8%	7.0%


12 Month Rolling Total Sewer Cleaning Summary

Month	HMB	GCSD	MWSD	Total Feet	Total Miles
Aug - 20	15,475	20,299	7,883	43,657	8.3
Sept - 20	12,942	18,428	4,067	35,437	6.7
Oct - 20	11,459	14,887	8,999	35,345	6.7
Nov - 20	11,229	23,059	9,482	43,770	8.3
Dec - 20	17,235	16,367	4,540	38,142	7.2
Jan - 21	9,147	11,987	2,909	24,043	4.6
Feb - 21	8,887	7,652	5,483	22,022	4.2
Mar - 21	12,401	11,943	4,691	29,035	5.5
April - 21	10,839	2,172	6,565	19,576	3.7
May - 21	12,472	986	6,281	19,739	3.7
June - 21	10,450	3,278	4,743	18,471	3.5
July - 21	13,852	9,054	3,571	26,477	5.0

Annual ft	146,388	140,112	69,214	355,714	
-----------	---------	---------	--------	---------	--

Annual Mi.	27.7	26.5	13.1		67.4
------------	------	------	------	--	------

Attachment C



TASK SUMMARY- GCSD 2021-2022

Task	Target Total	Jul	Aug	Sept	Oct	Nov	Dec	Jan	Feb	March	April	May	June	Total to Date	% Complete
Sewer Line Cleaning	87,000	7,608												7,608	9%
Hot Spot Cleaning	5,400	1,587												1,587	29%
Lift Station Inspection - Daily	52	4												4	0%
Lift Station Inspection - Annually	3	-												-	0%
Maint. Work Orders - Completed	-	4												4	-
Maint. Work Orders - Incomplete	-													-	-
Manhole Inspection	879	44												44	5%
USA Markings	372	74												74	20%
F.O.G. Inspections Completed	10	-												-	0%
F.O.G. Inspections Passed	10	-												-	0%
F.O.G. Inspection Failed	-	-												-	-
Lateral Inspections	-	-												-	-
Customer Service Call - Reg	-	2												2	-
Customer Service Call - OT	-	-												-	-
SSO Response - Category 1	-	-												-	-
SSO Response - Category 2	-	-												-	-
SSO Response - Category 3	-	-												-	-
Insurance Claims Filed	-	0												-	-

TASK SUMMARY-HMB 2021-22

Task	Target Total	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	March	April	May	June	Total to Date	% Complete
Sewer Line Cleaning	81,457	9,827												9,827	12%
Hot Spot Cleaning	25,184	4,369												4,369	17%
Lift Station Inspection - Weekly	43	4												4	9%
Lift Station Inspection - Quarterly	4	-												-	0%
Lift Station Inspection - Annually	1	-												-	0%
Maint. Work Orders - Completed	-	-												-	
Maint. Work Orders - Incomplete	-	-												-	
Manhole Inspection	722	57												57	8%
USA Markings	703	46												46	7%
Customer Service Call - Reg	-	-												-	
Customer Service Call - OT	-	1												1	
SSO Response - Category 1	-	-												-	
SSO Response - Category 2	-	-												-	
SSO Response - Category 3	-	-												-	

TASK SUMMARY -MWSD 2021-2022

Task	Target Total	Units	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total to Date	% Complete
Sewer Line Cleaning	63,000	Linear feet	3,994												3,994	6%
Hot Spot Cleaning	16,500	Linear feet	200												200	1%
Lift Station Inspection - Daily	2,028	Each	156												156	8%
Lift Station Inspection - Annually	13	Each	-												-	0%
Maint. Work Orders - Completed	-	Each	156												156	-
Maint. Work Orders - Incomplete	-	Each	-												-	-
Manhole Inspection	572	Each	21												21	4%
USA Markings	252	Each	45												45	18%
F.O.G. Inspections Completed	6	Each	-												-	0%
F.O.G. Inspections Passed	6	Each	-												-	0%
F.O.G. Inspection Failed	-	Each	-												-	-
Customer Service Call - Reg	-	Each	4												4	-
Customer Service Call - OT	-	Each	4												4	-
SSO Response - Category 1	-	Each	-												-	-
SSO Response - Category 2	-	Each	-												-	-
SSO Response - Category 3	-	Each	-												-	-
Insurance Claims Filed	-	Each	-												-	-



SEWER AUTHORITY MID-COASTSIDE

Staff Report

TO: Honorable Board of Directors
FROM: Kishen Prathivadi, General Manager
SUBJECT: **Attorney's Report**

Executive Summary

The purpose of this report is for information purposes only.

Fiscal Impact

There is no fiscal impact from this report.

Strategic Plan Compliance

The recommendation complies with the SAM Strategic Plan Goal 4: *“A well-organized, motivated, and well-trained staff with an effective Board of Directors are the most important keys to success for SAM.”*

Background and Discussion/Report

This item is placed on the agenda to allow for any report from the Attorney.

Staff Recommendation

Staff recommends that the Board of Directors receive the report.

Supporting Documents

None

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

200



SEWER AUTHORITY MID-COASTSIDE

Staff Report

TO: Honorable Board of Directors
FROM: Kishen Prathivadi, General Manager
SUBJECT: **Directors' Reports**

Executive Summary

The purpose of this report is for information purposes only.

Fiscal Impact

There is no fiscal impact from this report.

Strategic Plan Compliance

The recommendation complies with the SAM Strategic Plan Goal 4: *“A well-organized, motivated, and well-trained staff with an effective Board of Directors are the most important keys to success for SAM.”*

Background and Discussion/Report

This item is placed on the agenda to allow for any reports from the Directors.

Staff Recommendation

Staff recommends that the Board of Directors receive the report.

Supporting Documents

None

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	



**SEWER AUTHORITY MID-COASTSIDE
Staff Report**

TO: Honorable Board of Directors
FROM: Kishen Prathivadi, General Manager
SUBJECT: **Topics for Future Agenda Board Consideration**

Executive Summary

The purpose of this report is for information purposes only.

Fiscal Impact

There is no fiscal impact from this report.

Strategic Plan Compliance

The recommendation complies with the SAM Strategic Plan Goal 4: *“A well-organized, motivated, and well-trained staff with an effective Board of Directors are the most important keys to success for SAM.”*

Background and Discussion/Report

This item is placed on the agenda to allow for the Board’s continuing review of items for future agendas.

Staff Recommendation

Staff recommends that the Board of Directors receive the report.

Supporting Documents

Attachment A: List of Future Agenda Items

BOARD MEMBERS:	M. Clark	B. Dye	R. Lohman
	D. Penrose	D. Ruddock	K. Slater-Carter
ALTERNATE MEMBERS:	S. Boyd	E. Suchomel	P. Dekker
	J. Harvey	H. Rarback	

SEWER AUTHORITY MID-COASTSIDE
Future Agenda Items

	Items	Requested / Required By	Priority	Scheduled for	Status / Notes
1	Draft Public Records Act Policy	Ruddock		10/11/21	
2	Draft Policy for Minutes	Penrose		10/11/21	
3	Recycled Water	MA		TBD	
4	Strategic Plan Workshop	Board		TBD	
5	Board Reviews Proposed 5-Year CIP 2021 - 2025	FC		10/11/21	
6	Board Adopts 5-Year CIP 2021 - 2025	FC		10/11/21	
7	Closed Session - General Manager's Review	Board		11/9/20	Completed
8	Quarterly Investments Report	GC		5/24/21	Completed
9	Updated Aging Reports	Board		9/13/21	
10	Effects of Drought on Treatment Plant	BOC		9/13/21	
11	Senate Bill 9 (Housing Development) and Senate Bill 10(Planning and Zoning)	Board		9/27/21	
12	Odor Control Issues at Portola PS	Board		9/13/21	

FC = Finance Committee

GC = Government Code

MA = Member Agency

BOC = Board Operations Committee